



1015-2024 ADDENDUM 1

SUPPLY OF SLIDE GATES AND WEIR GATES FOR WASTEWATER

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: January 9, 2025
BY: Ian Griffin
TELEPHONE NO. 204-792-8560

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B9.1.1(c) to read: Provincial and Federal taxes [except the Goods and Services Tax (GST) and **Manitoba Retail Sales Tax (MRST)** which shall be extra where applicable] and all charges governmental or otherwise paid; and

PART E – SPECIFICATIONS

Revise: E3.1(a)(v) to read: **Golden Harvest Inc.**

Add: E3.1(a)(vi): **Or approved equivalent.**

NMS SPECIFICATIONS

Section 40 05 90 Stainless Steel Gates and Appurtenances

Revise: 2.2.1.5 to read: **Golden Harvest Inc.**

Add: 2.2.1.6: **Or approved equivalent.**

Revise: 2.4.5.9 to read: Provide the stem in accordance with AWWA C561, to withstand in tension the loads caused by an **36kg** (80 lb) effort on the manual crank or handwheel without exceeding 25% of the ultimate tensile strength of the stem material.