



1037-2024 ADDENDUM 2

DONCASTER OUTFALL CHAMBER UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: March 11, 2025
BY: Lunide Milius-Alphonse
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

NMS Specifications

Section 40 91 00 Automation – Process Measurement Devices

Revise: 2.6.1.1 to read: **VEGAPULS C 23 or approved equal in accordance with B7.**

Add: 2.6.1.1a Approved equal in accordance with B7: Siemens LR120.

Revise 2.6.9.1 to read: **VEGAPULS C 23: EECOL Reference Order #: RA-222 B6M.**

Add 2.6.9.2 Siemens LR120: Trans-West Process & Solutions.