B SIZE - 279mm x 432mm

LAST SAVE: 2024/03/19 – 8:00am
PATH: M:\M-Data\84\00 City of Winnipeg\005 – Conway Lift Station\Autodesk\ACAD\A1.4 LOOP DIAGRAM.dwg

SETTINGS:
UNBALANCE = 10%
LINE VOLTAGE = 600
TRIP DELAY = 1 SEC
RESTART DELAY = 0.6 SEC

ENGINEERS
GEOSCIENTISTS
MANITOBA
Certificate of Authorization
MPE, a division of Englobe Corp.
No. 4968 Date: MAR 19, 2024

NOTES:

1. GROUND SHIELDING AT ONLY THE NON–FIELD END UNLESS OTHERWISE SHOWN.
2. CONNECT WIRES AS SHOWN AND COIL SPARE WIRE WITHIN CP–L81.

NO.	REVISIONS	DATE	DSGN	CHECK
8				
7				
6				
5				
4				
3				
2				
1				
0	ISSUED FOR CONSTRUCTION	2024-03-19	J.A.S.	R.G.O.

MPE
a division of Englobe

DESIGNED BY: J. SWAIN	CHECKED BY: R. OFSTIE
DRAWN BY: J. SWAIN	APPROVED BY: R. OFSTIE
SCALE: NTS	DATE: 2024–03–19
ISSUED FOR CONSTRUCTION BY:	DATE:
CONSULTANT NO.:	

ENGINEER'S SEAL
PROVINCE OF MANITOBA
R.G OFSTIE
Member 44405
REGISTERED PROFESSIONAL ENGINEER
MARCH 21, 2024

Winnipeg
THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

CONWAY LIFT PUMPING STATION
2024 UPGRADES
LOOP DIAGRAM
600V POWER FAIL ALARM RELAY
ESL–L711

CITY DRAWING NUMBER
1–0131L–A0042–001–00