B SIZE - 279mm x 432mm

FIELD (MAIN FLOOR)	PLC CONTROL PANEL CP-L81 (MAIN FLOOR)

ALARM SETPOINT	TEMPERATURE
HIGH TEMPERATURE	35°C
LOW TEMPERATURE	5°C

ENGINEERS
GEOSCIENTISTS
MANITOBA
Certificate of Authorization
MPE, a division of Englobe Corp.
No. 4968 Date: MAR 19, 2024

NOTES:

1. GROUND SHIELDING AT ONLY THE NON-FIELD END UNLESS OTHERWISE SHOWN.
2. THREE-WIRE RTD CONNECTIONS NOT SHOWN.

NO.	REVISIONS	DATE	DSGN	CHECK
8				
7				
6				
5				
4				
3				
2				
1				
0	ISSUED FOR CONSTRUCTION	2024-03-19	J.A.S.	R.G.O.

MPE a division of Englobe

DESIGNED BY: J. SWAIN	CHECKED BY: R. OFSTIE
DRAWN BY: J. SWAIN	APPROVED BY: R. OFSTIE
SCALE: NTS	DATE: 2024-03-19
ISSUED FOR CONSTRUCTION BY:	DATE:
CONSULTANT NO.:	

ENGINEER'S SEAL

PROVINCE OF MANITOBA
R.G OFSTIE
Member 44405
REGISTERED PROFESSIONAL ENGINEER

MARCH 21, 2024

Winnipeg

THE CITY OF WINNIPEG

WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

CONWAY LIFT PUMPING STATION
2024 UPGRADES

LOOP DIAGRAM

MAIN FLOOR TEMPERATURE TRANSMITTER
TT-L691

CITY DRAWING NUMBER
1-0131L-A0039-001-00

LAST SAVE: 2024/03/19 - 8:06am
PATH: M:\H-Data\P4\00 City of Winnipeg\005 - Conway LIft Station\Autodesk\ACAD\A1.4 LOOP DIAGRAM.dwg