

NOTES :

CONSTRUCTION STANDARDS

TO BE CONSTRUCTED IN ACCORDANCE WITH MANITOBA HYDRO DISTRIBUTION AND SUBTRANSMISSION STANDARDS, LATEST EDITION.
NO MAJOR CHANGE SHALL BE MADE WITHOUT APPROVAL OF THE DESIGN ENGINEER OR DELEGATE.

INSTALL NEW STREET LIGHTS AND CABLE ON ALIGNMENT AS SHOWN.

INSTALL NEW GROUND RODS AS PER CD 50-5

ALL STREET LIGHT CABLE TO BE INSTALLED IN 2" CONDUIT

UPON DISCONNECTION BY MB HYDRO THE CONTRACTOR SHALL INSTALL TEMPORARY #6 OVERHEAD FEED IN ORDER TO MAINTAIN LIGHTING DURING CONSTRUCTION. AT THE END OF CONSTRUCTION TEMPORARY OVERHEAD SHALL BE DISCONNECTED BY THE CONTRACTOR.

U/G SL CABLE TO BE MINIMUM 1.0m AWAY FROM ALL OTHER UTILITIES UNLESS OTHERWISE NOTED

MB HYDRO SHALL CUT, CAP AND ABANDON ORIGINAL FEED TO THE STREET LIGHTS PRIOR TO REMOVAL, ALL FINAL CONNECTIONS WILL BE COMPLETED BY MB HYDRO.

CONTACT	NAME	PHONE NUMBER	E-MAIL ADDRESS
DESIGN	DAVID RIBACHUK	204-365-7100	DRIBACHUK@HYDRO.MB.CA
DESIGN ENGINEER	KEVIN VANDENBERGH	431-334-9777	KVANDENBERGH@HYDRO.MB.CA
PORTFOLIO PM	DARIN WACH	204-481-2881	DWACH@HYDRO.MB.CA
ENERGY SERVICE MANAGER	RYAN AUBRY	204-360-7821	RAUBRY@HYDRO.MB.CA
U/G CONSTRUCTION	JEFF BREAKLEY	204-871-2000	JBREAKLEY@HYDRO.MB.CA
OH CONSTRUCTION	BRYAN SANGSTER	204-485-4889	BSANGSTER@HYDRO.MB.CA
HYDRO GAS			
SEWER/ROVERS			
PERMITS			
CONTRACT			
DISTRICT ENG TECH	PHILIP BRUCE	204-365-3037	PBRUCE@HYDRO.MB.CA



CONTACT "CLICK BEFORE YOU DIG MANITOBA" AT ClickBeforeYouDigMB.com
THREE FULL WORKING DAYS
PRIOR TO CONSTRUCTION FOR LOCATION OF WATER, WASTEWATER, LAND DRAINAGE UTILITIES AND MANITOBA HYDRO UTILITIES

PRELIMINARY NOT TO BY USED FOR CONSTRUCTION

NO.	DATE	REVISIONS	BY	CHKD	APP.

DRAWING NUMBER	REFERENCE DRAWINGS	DRAW	D.R.
		CHECK	
		SCALE	1:250
		DATE	2024 05 30

AREA	5101	MANITOBA HYDRO DISTRIBUTION ENGINEERING
STATION NUMBER	N/A	WO# P-40061 NETWORK # 4308467
FEEDER NUMBER	N/A	CSC - CITY CENTRE
		COW - MCADAM (SINCLAIR TO ARLINGTON)
SYSTEM VOLTAGE	120 V	CUSTOMER SERVICE PROJECT SALVAGE 3-25' STREET LIGHTS AND INSTALL 4-25' STREET LIGHTS

B1 SIZE - 1000 x 700