



BENCHMARK
ELEV=232.172m
74M638 - TBLT. IN S. WALL OF DUFFERIN SCHOOL
545 ALEXANDER AVE., 2.4m W. OF S.E. COR. OF BLDG.

| WATER SERVICE INFORMATION | | | | | |
|---------------------------|-------------------------------|---------------------------------|---|-------------------------------|-------------------|
| ADDRESS | PIPE SIZE & MATERIAL (STREET) | PIPE SIZE & MATERIAL (PROPERTY) | STOP COCK LOCATION SHORT & LONG MEASUREMENT | CORP. LOCATION FROM STOP COCK | REMARKS |
| 598 ALEXANDER AVE | | | 1.2 M W/EBL & 4.1 M W/WEL | | RECONNECT SERVICE |
| 592 ALEXANDER AVE | 25 CU | 25 CU | 15' WEL HOUSE & 29' EWL GUNNELL | 11' W OF S/C | RECONNECT SERVICE |
| 588 ALEXANDER AVE | 20 CU | 12 LEAD | 6.5' EWL HOUSE & 12.5' EEL GUNNELL | 1'6" E OF S/C | RECONNECT SERVICE |
| 586 ALEXANDER AVE | 20 CU | | 4.86m E/WLL & 12.4m E/EEL GUNNELL ST | 2.3m E OF CS | RECONNECT SERVICE |
| 584 ALEXANDER AVE | 20 CU | 20 CU | 6.0m WELL | OPP S/C | RECONNECT SERVICE |
| 578 ALEXANDER AVE | 20 CU | 20 PVC | 109' EWL HOUSE & 115.5' EEL GUNNELL | 2' 6" E OF S/C | RECONNECT SERVICE |
| 574 ALEXANDER AVE | 20 CU | 16 LEAD | 4' W/WL HOUSE & 79' EEL GUNNELL | OPP S/C | RECONNECT SERVICE |
| 572 ALEXANDER AVE | 20 CU | 20 CU | 4.1 M E/WBL & 5 M E/WLL | 0.6M E S/C | RECONNECT SERVICE |
| 568 ALEXANDER AVE | 20 CU | 20 CU | 1.0m W/EBL | OPP CS | RECONNECT SERVICE |
| 564 ALEXANDER AVE | 20 CU | 12 LEAD | 76" EEL BUSHNELL & 149" EEL HOUSE | 5'6" W OF S/C | RECONNECT SERVICE |
| 562 ALEXANDER AVE | 20 CU | 12 LEAD | OPP W/L HOUSE & 79" EEL BUSHNELL | 4'3" W OF S/C | RECONNECT SERVICE |
| 589 ALEXANDER AVE | 20 CU | 12 LEAD | 179" WEL STORE & 306" EEL GUNNELL | 1' E OF S/C | RECONNECT SERVICE |
| 573 ALEXANDER AVE | | 20 CU | 0.3m W/EBL | | RECONNECT SERVICE |
| 569 ALEXANDER AVE | 20 CU | 20 CU | 8.5' WEL HOUSE & 98.5' W/WL BUSHNELL | 0.5' E OF S/C | RECONNECT SERVICE |
| 567 ALEXANDER AVE | 20 CU | 12 LEAD | 0.5 EWL HOUSE & 67.5' W/WL BUSHNELL | 1.5' W OF S/C | RECONNECT SERVICE |
| 563 ALEXANDER AVE | 20 CU | 20 CU | 24' WEL HOUSE & 28' W/WL BUSHNELL | OPP ST COCK | RECONNECT SERVICE |
| 561 ALEXANDER AVE | 20 CU | 20 CU | 12' NSL HOUSE & 53' NNL ALEXANDER | OPP S/C | OUTSIDE LIMITS |

NOTE: CHAINAGES SHOWN ARE ALONG CENTERLINE OF ROW

NOTE: VALVES TO BE INSTALLED COUNTER-CLOCKWISE TO CLOSE

FOR INDEX SEE D-16971



METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
Stantec Consulting Ltd.
No. 1301

LOCATION APPROVED
UNDERGROUND STRUCTURES

SUPV. U/G STRUCTURES COMMITTEE DATE

NOTE:
LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.

VERTICAL DATUM: CGVD28 (HT2.0 Geoid)
HORIZONTAL DATUM: NAD83 (June 1990), Zone 14

| NO. | ISSUED FOR TENDER | DATE | BY |
|-----|-------------------|------------|------|
| 00 | ISSUED FOR TENDER | 2024.04.29 | R.S. |



DESIGNED BY: R.S.
CHECKED BY: W.B.
DRAWN BY: M.R.
APPROVED BY: R.S.
SCALE: HORIZONTAL 1:250, VERTICAL 1:50
RELEASED FOR CONSTRUCTION: S.C. 2024.04.26
DATE: 2024.03.29

ENGINEER'S SEAL

CONSULTANT DRAWING NUMBER
C-203

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

2024 WATER MAIN RENEWALS
CONTRACT 7
ALEXANDER AVENUE
11.5 W OF GUNNELL STREET TO
7.9 E OF BUSHNELL STREET

SHEET 6 OF 13
CITY DRAWING NUMBER
D-16975