



243-2024 ADDENDUM 2

OUTDOOR CANTILEVER RACKING FOR EQUIPMENT STORAGE AT 960 THOMAS AVENUE – WFMA VEHICLE REPAIRS SHOP AND YARD

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: April 24, 2024
BY: Victorino Mendoza
TELEPHONE NO. 204 918 1480

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- | | | |
|------|----------|---|
| Add: | D2.2 (i) | The contractor to use zinc-rich primer and gray top-coat for the structural steel finish. |
| | D2.2 (j) | For the steel deck, factory stock colored & coated corrugated steel panels are acceptable (such as supplied by Vicwest). |
| | D2.2 (k) | The anchor bolt design is to be part of the engineer stamped steel shop drawing submittal. Hilti epoxy & threaded rods could be accepted as part of their submittal. The J-bolts are shown for reference purposes. Coordination will be required to ensure the reinforcing steel in the concrete slab is not compromised when using post-installed anchors. |