



286-2024B ADDENDUM 1

FERRY ROAD AND RIVERBEND COMBINED SEWER RELIEF – CONTRACT 6

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: 2024-12-20
BY: Mike Levreault
TELEPHONE NO. 204-954-6927

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, January 30, 2025.

PART E – SPECIFICATIONS

Add: E36.2.13 Further to City of Winnipeg Sewer By-law 106/2018 "Concentration Limits for Discharges", all water discharged from the Contractor's operations into natural waterways, combined sewer or land drainage sewers shall not exceed a Total Suspended Solids concentration of 350.0 mg/l and not exceed the maximum particle size that can pass through a 6.0 mm screen.

APPENDICES

Replace: Appendix A	Geotechnical Baseline Report
Add: Appendix G	Boulders Encountered in past Ferry Road Contracts
Add: Appendix H	Water Quality Analysis