



375-2024 ADDENDUM 5

CONSTRUCTION OF TRUNK AND LDS SEPARATION – COCKBURN & CALROSSIE SEWER RELIEF (CONTRACT 13)

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
TENDER**

ISSUED: August 23, 2024
BY: John Minkevich
TELEPHONE NO. 204-896-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE TENDER AND SHALL FORM A PART
OF THE CONTRACT DOCUMENTS**

Template Version: A20190115

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Tender and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

FORM B

Replace: 375-2024 Addendum 3_eForm_B-Prices.xlsx with 375-2024 Addendum 5_eForm_B-Prices.xlsx. The following is a summary of changes incorporated in the replacement eForm_B-Prices:

- Revised Pay Item A.15 a) to read “Up to 1.5m long”
- Added Pay Item A.15 a) i) to read “150” with “Approximate quantity” to read 1
- Added Pay Item A.15 a) ii) to read “300” with “Approximate quantity” to read 1
- Revised Pay Item A.15 b) to read “Longer than 1.5m long”
- Added Pay Item A.15 b) i) to read “150” with “Approximate quantity” to read 11.0
- Added Pay Item A.15 b) ii) to read “300” with “Approximate quantity” to read 12.0
- Revised Pay Item A.19 f) to read “Vertical Bends (SD-005)”
- Added Pay Item A.21 “Connection to Ex. Catch Basin Lead, a) 300 mm” with “Approximate quantity” to read 1.
- Revised Pay Item B.2 a) i), “Approximate quantity” to read 1.5 vt. m
- Added Pay Item D.2 a) i) “New Manhole on Existing Sewer, 2400 mm Dia x 2.44 m high base (MH 227) with “Approximate quantity” to read 3 vt.m.
- Removed Pay Item D.2 b) ii) “2400 mm Dia x 2.44 m high base (MH 227)”
- Revised Pay Item D.2 b) iv) to be D.2 b) iii) and read “2700 mm Dia x 2.44 m high base (MH 224)”
- Revised Pay Item D.8 a) “Approximate quantity” to read 10
- Removed Pay Item D.17 b) “Connect to Existing Sewer”
- Revised Pay Item D.13 to read “Connection to Existing Manhole (MH 210A)”

- Revised Pay Item D16 c) to read “Vertical Bends (SD-005)”
- Removed Pay Item D.17 c) “Bends (SD-004)”
- Item numbering has been updated.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D20.3 to read: The City intends to award this Contract by **November 1, 2024**.

PART E – SPECIFICATIONS

Revise: E16.1(a) to read: This Specification supplements and amends City of Winnipeg Standard Construction Specification CW 2130 Gravity Sewers and shall cover the installation of large diameter manholes and **new manholes on existing pipes**.

Add: E16.5(b) to read: **(b) New Manhole on Existing Sewer**

Construction of new manholes on existing sewers shall be measured on a vertical metre basis for each diameter of “New Manhole on Existing Sewer” listed on Form B: Prices by base diameter, base height, and associated riser sections. The price shall include, but not be limited to, excavation, shoring, backfill, connections to existing pipes (including new pipes to connect to existing pipes), reducers, adjusting rings, frames and covers, benching, rungs, couplings and all appurtenances, and miscellaneous metals and materials.

QUESTIONS AND ANSWERS

- Q1: On sheet LD-13000 there appear to be typos for the 300 mm LDS work south of Carter Avenue. Should the regraded pipe actually be 300 mm and not 250 mm? How do we get paid for the connection to the existing 300 mm pipe?
- A1: Yes, the regraded pipe should be 300 mm and is already included in the Form B: A.8 b) i) quantities for 300 mm pipe. The connection will be paid out in a new line item in the Form B (A.21 a) Connection to Ex. Catch Basin Lead).