



389-2024 ADDENDUM 2

PROFESSIONAL CONSULTING SERVICES FOR PRELIMINARY DESIGN OF THE SHOAL LAKE INTAKE STRUCTURE UPGRADES AND FALCON RIVER VENTURI SUPERSTRUCTURE REPLACEMENT

ISSUED: June 3, 2024
BY: Connor Fedorchuk
TELEPHONE NO. 431-294-7868

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Add: D11.8.5(a)(iii) For Proposal purposes, assume the Consultant will need to be on site for eight (8) hours for the assessment.
- Add: D11.8.13(a)(ii) The duration of the investigation shall be determined by the Consultant in the approved plan from Technical Memorandum #2 (D11.7). For Proposal purposes, assume the Consultant will need to be on site for sixteen (16) hours for the investigation.

APPENDICES

- Add: Appendix E – Site Investigation Photos

Note: This appendix is available electronically by request to the Consulting Contract Administrator after completion of a Non-Disclosure Agreement.

QUESTIONS AND ANSWERS

- Q1: Who is responsible for procuring the contractor(s) for the excavations and repairs described in D11.8.3(a)(iii), and for procuring the commercial diving service described in D11.8.5(a)(i)? Do the contractors need to be named in the Proposal?
- A1: The Consultant will be responsible for procuring contractors and the commercial diving service, although these parties do not need to be named in the Proposal. Refer to the Material Testing Allowance described in D13 for details.
- Q2: Does the Consultant need to estimate costs for the excavations described in D11.8.3(a)(iii) in their Proposal?
- A2: No, these costs will be determined by the Consultant and approved by the Consulting Contract Administrator during the course of the project and will be paid for using the Material Testing Allowance described in D13.
- Q3: Could a barge be to transport equipment to the site?
- A3: No, the site is only accessible by the Greater Winnipeg Water District (GWWD) Railway.

Q4: Is the Staff House at the site available to the Consultant for overnight stays?

A4: Yes, however, the Consultant is responsible for providing their own meals and following the Staff House rules.

Q5: How often are the intake stoplogs and low lift pump chamber inlet stoplogs used?

A5: On average, the intake stoplogs are used once or twice a year, and the low lift pump chamber inlet stoplogs are used once a year.

Q6: Have there been any recent Manitoba Hydro service upgrades at the site?

A6: No, there have been no known upgrades to the Manitoba Hydro service.