



459-2024 ADDENDUM 01

ENVIRONMENTAL SOIL REMEDIATION – 145 OSBORNE STREET, WINNIPEG, MANITOBA

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 5, 2024
BY: Alfred Chan
TELEPHONE NO. 204 259-1679

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

QUESTIONS AND ANSWERS

Q1: Item 4.2.1 in the Remedial Plan (RP) references the use of both a hydrocarbon resistant liner and low permeable clay liner be used, while Figure 2 in the Remedial Plan shows only a low permeable clay liner on the south side of the excavation. Could you please confirm if both are required or just the low permeable clay liner?

A1: The south side of the excavation should be backfilled with the minimum requirement of a low permeable clay liner. Please disregard the additional recommendation for a hydrocarbon resistant liner in the RP.