LAST SAVE: 2024/03/15 – 9:53am
PATH: M:\N-Data\84\00 City of Winnipeg\006 – Renfrew Outfall Gate Chamber Upgrades\AutoDesk\ACAD\a1.9 loop diagram3.DWG - 279mm x 432mm

FIELD (ELECTRICAL CABINET)	PLC CONTROL PANEL CP-G81 (ELECTRICAL CABINET)

SETTINGS:
UNBALANCE = 10%
LINE VOLTAGE = 600
TRIP DELAY = 1 SEC
RESTART DELAY = 0.6 SEC

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
MPE, a division of Englobe Corp.
No. 4968 Date: MAR 15, 2024

NOTES:

1. SHIELDING TO BE ISOLATED AND TAPED BACK AT INDICATED END ONLY.

NO.	REVISIONS	DATE	DSGN	CHECK
7				
6				
5				
4				
3				
2				
1				
0	ISSUED FOR CONSTRUCTION	2024.03.15	J.A.S.	R.G.O.

MPE a division of Englobe

DESIGNED BY: J. SWAIN	CHECKED BY: R. OFSTIE
DRAWN BY: D. MCMILLAN	APPROVED BY: R. OFSTIE
SCALE: NOT TO SCALE	DATE: 2024-03-15
ISSUED FOR CONSTRUCTION BY:	DATE:
CONSULTANT NO.:	

ENGINEER'S SEAL
PROVINCE OF MANITOBA
R.G. OFSTIE
Member 44405
REGISTERED PROFESSIONAL ENGINEER
MARCH 18, 2024

Winnipeg
THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

RENFREW OUTFALL GATE CHAMBER
2024 UPGRADES
LOOP DIAGRAM
600 VAC POWER FAIL RELAY
ESL-G711

CITY DRAWING NUMBER
1-0240G-A0015-001