LAST SAVE: 2024/03/15 – 9:53am
PATH: M:\N-Data\84\00 City of Winnipeg\006 – Renfrew Outfall Gate Chamber Upgrades\AutoDesk\ACAD\a1.9 loop diagram.DWG - 279mm x 432mm

FIELD
(ELECTRICAL CABINET)

PLC CONTROL PANEL CP-G81
(ELECTRICAL CABINET)

ALARM SETPOINT	TEMPERATURE
HIGH TEMPERATURE	40°C
LOW TEMPERATURE	0°C

ENGINEERS GEOSCIENTISTS MANITOBA
Certificate of Authorization
MPE, a division of Englobe Corp.
No. 4968 Date: MAR 15, 2024

NOTES:

1. SHIELDING TO BE ISOLATED AND TAPED BACK AT INDICATED END ONLY.

NO.	REVISIONS	DATE	DSGN	CHECK
7				
6				
5				
4				
3				
2				
1				
0	ISSUED FOR CONSTRUCTION	2024.03.15	J.A.S.	R.G.O.

MPE a division of Englobe

DESIGNED BY: J. SWAIN	CHECKED BY: R. OFSTIE
DRAWN BY: D. MCMILLAN	APPROVED BY: R. OFSTIE
SCALE: NOT TO SCALE	DATE: 2024-03-15
ISSUED FOR CONSTRUCTION BY:	DATE:
CONSULTANT NO.:	

ENGINEER'S SEAL
PROVINCE OF MANITOBA
R.G OFSTIE
Member 44405
REGISTERED PROFESSIONAL ENGINEER
MARCH 18, 2024

Winnipeg
THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

RENFREW OUTFALL GATE CHAMBER
2024 UPGRADES

LOOP DIAGRAM

ELECTRICAL CABINET TEMPERATURE TRANSMITTER
TT-G681

CITY DRAWING NUMBER
1-0240G-A0014-001