



556-2024B ADDENDUM 12

ST. JAMES CIVIC CENTER FACILITY EXPANSION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: November 25, 2024
BY: Janelle Fillion, LM-ESP
TELEPHONE NO. 204 942-0681

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

QUESTIONS AND ANSWERS

- Q1: On Drawing EP2.1 there are two data racks. One in Electrical 1:27 and one in a closet in Corridor 1:20. Can you please provide clarification on what cables go to what rack?
- A1: Data Rack in IT Closet off of Corridor 1:21 serves Support Services 1:12, Administration 1:13, Reception 1:14, Copy/Print Room 1:15, Executive Director 1:16, Program Coordinator 1:17, Shared Office 1:18, Clinic 1:19/1:20, Corridor 1:21 and Member Lounge 1:22.
- Data Rack in Electrical Room 1:27 serves all other spaces in the main building addition.
- Data in the northeast addition (Office 1:37 to Staff Room 1:36) to be routed to the existing Data Rack in the Basement Network Room.