



1 MAIN FLOOR PLAN
 E1.0 SCALE: 1/16" = 1'-0"

LEGEND	
	HEAT DETECTOR (FIXED TEMP)
	MANUAL PULL STATION
	FIRE ALARM SIGNAL HORN
	FIRE ALARM SIGNAL HORN & STROBE - WALL MOUNTED
	FIRE ALARM STROBE - WALL MOUNTED
	ISOLATOR
	MONITORING MODULE
	END OF LINE RESISTOR
	LINEAR HEAT CABLE (RISER SYMBOL)
	SYSTEM PANELBOARD - SURFACE MOUNT/FLUSH MOUNT
	LINEAR HEAT CABLE
	EXISTING TO REMAIN

- SCOPE OF WORK**
- A. EXISTING SPRINKLER SYSTEM TO BE DECOMMISSIONED FOR REPAIRS. HEAT DETECTION TO BE PROVIDED THROUGHOUT AS REQUIRED TO PROVIDE SUFFICIENT COVERAGE. SPACE WILL BE CONSIDERED UNHEATED AND UNSPRINKLERED WHILE SPRINKLER SYSTEM IS DOWN.
 - B. PROVIDE LINEAR HEAT DETECTION OVER THE BACK OF STAGE AREA ATTACHED TO SPRINKLER PIPING AT HIGH LEVEL.
 - C. PROVIDE LINER HEAT/ SPOT TYPE HEAT DETECTORS IN ALL STORAGE ROOMS/WAREHOUSE AREAS.

- DRAWING NOTES: #**
1. HEAT DETECTORS TO BE KIDDE FENWELL (CAT. #27021) TYPICAL.
 2. LINEAR HEAT DETECTION TO BE SAFE CABLE LINEAR HEAT DETECTOR (CAT. #1C190) TYPICAL.
 3. LINEAR HEAT CABLE TO BE MOUNTED TO SPRINKLER PIPING WITH MANUFACTURER APPROVED TIE STRAPS. EXTEND LINEAR HEAT DETECTION TO END OF LINE RESISTOR WITH NORMAL WIRING METHODS TO ACCESSIBLE LOCATION ON MAIN FLOOR.
 4. PROVIDE ADDRESSABLE MONITORING MODULES IN MAIN ELECTRICAL ROOM FOR LINEAR HEAT DETECTION CABLE.
 5. EXISTING ADDRESSABLE NOTIFIER PANEL.
 6. EXTEND LINEAR HEAT DETECTION TO END OF LINE RESISTOR WITH NORMAL WIRING METHODS TO ACCESSIBLE LOCATION ON MAIN FLOOR.
 7. PROVIDE LINEAR HEAT CABLE ALONG LIGHT DECK WALKWAY CEILING. EXTEND LINEAR HEAT DETECTION TO END OF LINE RESISTOR WITH NORMAL WIRING METHODS TO ACCESSIBLE LOCATION ON MAIN FLOOR.
 8. CONNECT NEW HEAT DETECTORS TO EXISTING FLOOR AREA DEVICES.
 9. CONNECT NEW HEAT DETECTORS TO EXISTING DEVICES AT TOP OF STAIR.

No.	ISSUED FOR CONSTRUCTION REVISION/DESCRIPTION	TN BY	DATE
0			24/05/03

DRAWN	DATE	CHECKED	DESIGNED	APPROVED	DWG
TN	2024-XX-XX	SM	TN	APPROVAL	

THE CITY OF WINNIPEG
 PLANNING, PROPERTY AND
 DEVELOPMENT DEPARTMENT
 MUNICIPAL ACCOMMODATIONS DIVISION
 3-65 GARRY STREET, R3C 4K4

PROJECT
**RAINBOW STAGE
 FIRE ALARM UPGRADES**
 2021 MAIN ST
 SHEET TITLE
**FIRE ALARM RENO
 MAIN FLOOR PLAN**

SCALE	PROJECT No:	SHEET No:
AS SHOWN	2022-006	E1.0