



## 648-2024 ADDENDUM 2

### 598 PLINGUET ROOF REPLACEMENT

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: August 27, 2024  
BY: Joemar Razal  
TELEPHONE NO. (204) 599-1269

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **August 30, 2024.**

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D2.2(b)(iv) to read: Supply and installation of insulation to meet average R-25 value:

- Top insulation: Sopra-ISO Plus 2" – adhered with duotack.
- Sloped Insulation: EPS Type 2, minimum 1.5% slope - adhered with duotack.

Add: D2.2(b)(xv)

Siplast Roofing products have been approved as an equal material alternative as per the listed items:

- Siplast Paradiene 20 TSSA as equivalent to Colvent 830
- Siplast Parafor 30 TG Cap as equivalent to Sopraply Traffic Cap 4.0
- Siplast Paradiene 20 SA as equivalent to Sopraflash Flam Stick
- Siplast Paratherm CG as equivalent to Sopra-ISO Plus Insulation
- Siplast Parafast Adhesive 1.5ltr as equivalent to Duotack 1.5ltr
- Siplast EPS-Plastifab as equivalent to EPS Type 2

Revise: D16.1 to read: The Contractor shall achieve Substantial Performance by November 11, 2024

Revise: D17.1 to read: The Contractor shall achieve Total Performance by November 25, 2024