



Appendix D ADDENDUM 02

LEAD CONTAMINATED SOIL REMEDIATION AT WESTON COMMUNITY CENTRE HOCKEY RINK AND MISSION PARK, WINNIPEG, MANITOBA

ISSUED: September 27, 2024
BY: Alfred Chan
TELEPHONE NO. 204-259-1679

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, October 3, 2024.

PART E – SPECIFICATIONS

Revise: E1.4: The following are applicable to the Work:

<u>Specification No.</u>	<u>Specification Title</u>
CW3110-R19	<i>Subgrade, Sub-base and Base Course Construction (dated December 2014) (Appendix E)</i>
<u>Drawing No.</u>	<u>Drawing Name/Title</u>
A1 & A9	<i>Outdoor Hockey Rink Layout Plan & Rink Base Construction, Specifications (Appendix D).</i>

Revise: E8.3(b) to read: Place aggregate fill material on continuous layers and construct sub-grade, sub-base and base course at the Weston CC excavation as per the City of Winnipeg specification CW3110-R19 (Sub-grade, sub-base and base course construction) (**Appendix E**) and detail 1/A1 (Figure A1, Appendix D).

DRAWINGS

Replace: Appendix D _Drawing_A1 & A9 with 4BAppendix D _Addendum_02 Drawing A1 & A9

APPENDICES

Add: Appendix_E CW3110-R19 – *Subgrade, Sub-base and Base Course Construction*

QUESTIONS AND ANSWERS

Q1: Specifications section E8.3(b) states that City of Winnipeg specification CW 3110 (*Sub-grade, sub-base and base course construction*) applies for restoring the Weston CC excavation. Can CW3110-R19 be used instead of CW3110-R22?

A1: Yes, the most up to date revision, CW3110-R22, is applicable but CW3110-R19 (attached in Appendix E) is also acceptable.