



694-2024 ADDENDUM 3

BRANCH 1 AQUEDUCT UNDERDRAIN OUTFALL REPAIRS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: 2024-10-25
BY: A. Braun
TELEPHONE NO. 204 955-1210

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Revise: E18.3.9 to read: Flexible rubber backflow valves shall be Checkmate UltraFlex by Red Valve, EVR MwStop Check Valve, or approved equal in accordance with B7.

Add: E25.7.2 TPR work on AQ-U00000174 requires access to UMH116-0108 on CPKC property as shown on drawing 1-0751N-C0012-001. The City will be obtaining an access permit to facilitate the development of this work site. The Contractor shall then install fencing to separate the work area from CPKC operations. The fencing shall be installed prior to the commencement of the work at this site and must remain in place until completion. Railway flagging is required for installation of the fencing and must be scheduled through the Contact Administrator. Railway flagging is not required for the work, once the fencing is in place. The duration of work at this site (Contractor mobilization to demobilization) is anticipated to be 14 Calendar Days. The extents of the fencing are to be reviewed and mutually agreed upon between all parties including Stantec, the City, the Contractor, and CPKC.