



755-2024 ADDENDUM 3

PROFESSIONAL CONSULTING SERVICES FOR ARMSTRONG DETAILED DESIGN AND CONTRACT ADMINISTRATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: November 7, 2024
BY: Patrick Coote
TELEPHONE NO. 204 986-2456

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace: 4B755-2024 Form B: Prices with 4B755-2024 Addendum 3 - Form B: Prices R1. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Revise Items No. 5: Approximate Quantity to 6,000

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, November 13, 2024.

QUESTIONS AND ANSWERS

Q1: Can you provide clarification on the size of the proposed land drainage sewer (LDS) on Main Street as there are discrepancies indicated in the Armstrong Preliminary Design Report?

A1: The proposed LDS on Main Street is intended to be 900mm, located upstream of the 600mm and 375mm LDS per P.23 and P.24 of the LDS drawing set, LDS 23-11-07.pdf. Please disregard other references that indicate otherwise.