



811-2024 ADDENDUM 2

2024 WATER MAIN RENEWALS – CONTRACT 11

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: February 19 2025
BY: Ryan Gama, C.E.T.
TELEPHONE NO. 204 986-2336

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

811-2024 Addendum 1 incorrectly referenced the Adjustments for Changes in Laws, Taxes, or Tariffs clauses as D30. The Adjustments for Changes in Laws, Taxes, or Tariffs clauses are D37.

D30 is Traffic Control and Maintenance of Access and remains the same as posted in the Tender.

Delete: D37.3

PART E – SPECIFICATIONS

Add the following Section and Clauses:

CROSS-LINKED POLYETHYLENE (PEXa) WATER SERVICE PIPE.

E8 CROSS-LINKED POLYETHYLENE (PEXa) WATER SERVICE PIPE

- E8.1 Cross-Linked Polyethylene (PEXa) water service pipe may be used as a direct replacement for copper water service pipe. The following conditions apply to PEXa water service pipe:
- a) Approved Cross-Linked Polyethylene (PEXa) water service pipe is Rehau Municipex.
 - b) Cross-Linked Polyethylene (PEXa) water service piping is not to be installed in any locations where the depth of cover is less than 2.1m.
 - c) Tracer wire is not required for standard Cross-Linked Polyethylene (PEXa) water service piping installations; however, the contract administrator reserves the right to request tracer wire in locations where it is deemed necessary.
 - d) Installation of Cross-Linked Polyethylene (PEXa) water service pipe shall conform to the most current revision of the City of Winnipeg Standard Construction Specifications, CW2110, and SD-012 as applicable.
- E8.2 Measurement and Payment
- a) No separate measurement or payment will be made for Cross-Linked Polyethylene (PEXa) water service pipe as a replacement for copper water service pipe. Water services shall be measured and paid for at the Contact Unit Price for “Water Services” at the applicable size, as identified in Form B.

- b) No separate measurement or payment will be made for tracer wire installed with Cross-Linked Polyethylene (PEXa) water service pipe.

FORM B: PRICES

Replace: 811-2024 Addendum 1 – Form B with 811-2024 Addendum 2 – Form B. The following is a summary of changes incorporated in the replacement Form B: Prices:

Form B(R2): A.4 a) i) – Tee size changed to 300mm x 150mm x 150mm.

A.10 a) i) – Blank cell corrected to “150mm”.

Page numbering on some forms may be changed as a result.

QUESTIONS AND ANSWERS

- Q1: Can Municipex water service pipe be used in place of the copper water service pipe specified on the drawings?
- A1: Yes. As of January 31, 2025, Municipex is an approved product and can be used in place of the copper water service pipe specified on the drawings.