



929-2024 ADDENDUM 1

SUPPLY OF TRANSFORMERS – GENERAL CONSTRUCTION PACKAGE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: 11-22-2024
BY: Saro Boghosian
TELEPHONE NO. 204 477 8381

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, December 10, 2024.

QUESTIONS AND ANSWERS

Q1: Please confirm a FOB point. Main street NEWPCC or staging yard?

A1: FOB "Free Of Board" would be at NEWPCC "North End Water Pollution Control Centre" at 2230 Main St, Winnipeg, MB R2V 4T8.

Q2: Special gasketing for cold weather requirements?

A2: Vendor to provide a suitable gasket that shall maintain weathertight seal from -40C to +40C ambient and prevent ingress of moisture and humidity. Refer to Specification 26 12 13, Section 2.6.7.

Q3: Special or specific manufacturer for tap changer?

A3: No specific manufacturer however the tap changer shall meet the performance in Specification 26 12 13, Section 2.6.3.5.

Q4: Specific oil requirements or limitations?

A4: Insulating oil shall be EnviroTemp FR3 as outlined in Specification 26 12 13, Section 2.4.3.