



929-2024 ADDENDUM 2

SUPPLY OF TRANSFORMERS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: 12-04-2024
BY: Saro Boghosian
TELEPHONE NO. 204 477 8381

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

- Revise: E3 to read: E3. APPROVED PRODUCTS
- E3.1 Subject to E1.3, the following products are approved:
 - (a) Partner Technologies Incorporated (PTI).
 - (b) Eaton (Cooper Power Series) Substation Transformers.
 - (c) Boundary Electric.
 - (d) ETAC Service & Supply
 - (e) Or approved equal.

NMS SPECIFICATIONS

Section 26 12 13 - Liquid Filled, Medium Voltage Transformers:

- Revise: 2. to read: 2. PRODUCTS
- 2.1 Acceptable Manufacturers
 - 1. Partner Technologies Incorporated (PTI).
 - 2. Eaton (Cooper Power Series) Substation Transformers.
 - 3. Boundary Electric.
 - 4. ETAC Service & Supply
 - 5. Or approved equal.

QUESTIONS AND ANSWERS

- Q1: Regarding 2.6.7.2 of Section 26 12 13, does the customer want kirk key provisions on the primary ATC and they provide the lock and key? Or are they asking us to coordinate the lock and key with the upstream feeder breaker?
- A1: Coordinate the lock and key with the upstream feeder breaker existing Key. Only one lock and Kirk key will be required for each transformer.