


1 PARTIAL MAIN FLOOR PLAN - FIRE PROTECTION - DEMOLITION
 M1.3 SCALE: 1/16"=1'-0"

GENERAL NOTES

- A. ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- B. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.
- C. PRIOR TO DEMOLISHING AND REMOVAL OF THE EXISTING EQUIPMENT, COORDINATE WITH THE CITY. RETURN EQUIPMENT TO THE CITY AS REQUIRED.
- D. REFER TO ROOF DETAILS AND SPECIFICATIONS FOR ALL NEW AND CAPPED OPENINGS.
- E. THE WORK AREA IS OCCUPIED 24/7. DURING THE HOURS OF 7:00 AM TO 2:30 PM, IT IS THE BUSIEST TIME FOR THE AREA AND IT IS PREFERRED THAT NO MORE THAN TWO HOIST SPACES ARE IMPACTED BY THE SCOPE OF WORK BUT ADDITIONAL HOISTS MAY BE IMPACTED WITH SUFFICIENT NOTICE AND APPROVAL. DURING THE HOURS OF 2:30 PM TO 7:00 AM, THE AREA IS LESS BUSY AND APPROVAL FOR ADDITIONAL HOISTS TO BE IMPACTED WILL BE MORE EASILY OBTAINED. COORDINATE WITH THE CITY PRIOR TO COMMENCEMENT OF WORK. UPON COMPLETION OF WORK AT THE END OF EACH SHIFT, CLEAN UP THE AREA OF WORK TO ENSURE THE HOISTS ARE NOT IMPACTED.
- F. FOR DRAWING CLARITY, NOT ALL MECHANICAL EQUIPMENT, PIPING AND DUCTWORK HAS BEEN SHOWN.
- G. CAUTION SHOULD BE TAKEN TO PREVENT SILICA RELEASE AND FUMES INSIDE THE GARAGE.

DEMOLITION KEY NOTES #

- 1. DEMOLISH AND REMOVE UPRIGHT SPRINKLER HEADS COVERING BELOW MECHANICAL EQUIPMENT BEING REMOVED. CONFIRM EXACT LOCATION ON SITE.
- 2. SPRINKLER AT HIGH LEVEL (NOT SHOWN) TO REMAIN.
- 3. EXISTING SPRINKLER PIPE SHOWN FOR GENERAL INFORMATION.
- 4. EXISTING SPRINKLER BRANCH PIPE AND UPRIGHT SPRINKLER HEADS IN THE WAY OF NEW STRUCTURAL BEAM TO BE DEMOLISHED AND REMOVED. REFER TO NEW CONSTRUCTION DRAWING.
- 5. EXISTING SPRINKLER PIPE IN THE WAY OF NEW STRUCTURAL BEAM TO BE DEMOLISHED APPROXIMATELY AS SHOWN. FINAL LOCATION TO BE DETERMINED ON SITE AFTER COORDINATING WITH STRUCTURAL DIVISION. REFER TO NEW CONSTRUCTION DRAWING.



KEY PLAN
 SCALE: NTS

6			
5			
4			
3			
2			
1			
0	ISSUED FOR CONSTRUCTION	JH	23/01/25
NO.	Description	BY	DDMMYY



Winnipeg Transit

Project Title
TRANSIT MAINTENANCE AND REPAIR BUILDING MECHANICAL UPGRADE - CENTRE HIGH BAY
 WINNIPEG MANITOBA

Drawing Title
PARTIAL MAIN FLOOR PLAN - FIRE PROTECTION - DEMOLITION

Drawn By	Checked By	Approved By
API/KS	JH	JH
Scale	Date	Project No.
AS INDICATED	DECEMBER 2024	24-256-01
Revision Number	Drawing Number	Sheet Order
0	M1.3	3 OF 10