


## **GENERAL NOTES**

- A. ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- B. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.
- C. PRIOR TO DEMOLISHING AND REMOVAL OF THE EXISTING EQUIPMENT, COORDINATE WITH THE CITY. RETURN EQUIPMENT TO THE CITY AS REQUIRED.
- D. FOR DRAWING CLARITY, NOT ALL MECHANICAL EQUIPMENT, PIPING AND DUCTWORK HAS BEEN SHOWN.

## DEMOLITION KEY NOTES #

- MUA INSIDE BUILDING SHOWN FOR GENERAL INFORMATION AND COORDINATION. DEMOLISH AND REMOVE EXISTING MUA AND ASSOCIATED DUCTWORK, VENTING AND INTAKE. REPAIR AND SEAL ROOF OPENING. REFER TO ROOFING SPECIFICATION/
- DEMOLISH AND REMOVE EXISTING EXHAUST FAN AND ASSOCIATED DUCTWORK. REPAIR AND SEAL ROOF OPENING. REFER TO ROOFING SPECIFICATION/DETAILS.
- 3. DEMOLISH AND REMOVE EXISTING NON FUNCTIONAL EXHAUST FAN AND ASSOCIATED DUCTWORK. REPAIR AND SEAL ROOF OPENING. REFER TO ROOFING SPECIFICATION/DETAILS.
- 4. EXISTING EXHAUST FAN TO REMAIN.
- 5. EXISTING HRU TO REMAIN.
- 6. EXISTING LADDER TO BE REMOVED. REFER TO STRUCTURAL DRAWINGS.



KEY PLAN

SCALE: NTS

6			
5			
4			
3			
2			
1			
0	ISSUED FOR CONSTRUCTION	JH	23/01/25
NO.	Description	BY	DD/MM/YY





HORROCKS Member 24767



Project Title

TRANSIT MAINTENANCE AND REPAIR BUILDING MECHANICAL UPGRADE - CENTRE HIGH BAY WINNIPEG MANITOBA

PARTIAL ROOF PLAN -**VENTILATION -**DEMOLITION

Drawn By	Checked By	Approved By
AP/ KS	JH	JH
Scale AS INDICATED	Date DECEMBER 2024	Project No. 24-256-01
Revision Number	Drawing Number	Sheet Order
0	M1.5	5 OF 10