

**Gas Fired Radiant Heaters**

NO.	LOCATION	MANUFACTURER	MODEL	LENGTH Feet	INPUT (MBH)	OPTIONS
IH 23	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 24	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 29	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 32	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	40 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 33	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 34	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 35	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 36	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 37	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 40	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.
IH 41	Maintenan & Repair Building - Centre High Bay	Superior Radiant	UA	50 ft long	150	c/w lower radiant shield for coverage distance on tube. Provide thermostat and relay kits to complete the control. Mount thermostat to meet AHJ's requirements.

**Gas Fired Radiant Heater Schedule**



Project: **Transit Maintenance and Repair Building Mechanical Upgrade - Centre High Bay**

File: 24-256-01 Designer: AJ  
Date: Jan-25 Sheet: **MS-3**