



GENERAL NOTES:

1. SOPRAMASTIC SP2 MUST EXCEED 25 MM (1 INCH) OVER SOPRAMASTIC BLOCK.
2. THE DISTANCE BETWEEN THE BLOCK INNER WALL AND THE PENETRATIONS MUST HAVE AT LEAST 25 MM (1 INCH).



DRAWING:		SOPRAMASTIC BLOCK SYSTEM (HZ.)	
CLIENT:		-	
PROJECT:		1005-2016	
SCALE:	N.T.S	SHEET NO:	RD-1