



947-2024 ADDENDUM 4

PROFESSIONAL CONSULTING SERVICES FOR TYLEHURST LIFT STATION UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: 2025-01-21
BY: Kevin Sapiak
TELEPHONE NO. (431) 278-0876

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D4.3 to read: The funds available for this Contract is \$ **600,000.00**.
- Revise: D6.2 to read: The City of Winnipeg has adopted Manitoba Building Code (**2024** edition), **which adopts National Building Code (2020 edition)**. All designs shall comply with the latest building code editions.
- Revise: D8.5 (c) (iv) to read: The existing Lift Station superstructure will be not be large enough to accommodate new equipment and code spacing requirements. Provide design for a new superstructure sufficient in size and layout to adequately accommodate the proposed installation of all required above grade equipment and components, etc. The building shall be insulated and be code compliant with all building codes. The new structure shall be designed with trusses to be a gable roof, complete with metal roofing, eavestroughs and downspouts along with a double main entrance door. Provide seismic calculations for the new buildings required as part of Manitoba Building Code **2024 and National Building Code 2020**.
- Revise: D8.5 (c) (xvi) to read: Provide seismic calculations for the new buildings required as part of Manitoba Building Code (**2024**) and **National Building Code (2020)**.