



- DEMOLITION NOTES:**
- (A) COORDINATE WITH MANITOBA HYDRO TO DISCONNECT AND REMOVE THE EXISTING 600V SERVICE UTILITY METER. PATCH AND REPAIR ENCLOSURE WITH STEEL PLATES AND GASKETS. PAINT TO MATCH. PROVIDE DEMOLITION OF THE EXISTING OUTDOOR UTILITY METER, CONDUITS AND CABLING. CONSULT WITH MANITOBA HYDRO IF METER SHOULD BE KEPT, OTHERWISE DISPOSE OF METER.
 - (B) CONTRACTOR TO COORDINATE WITH MANITOBA HYDRO TO REMOVE THE 5kV CABLES TO THE EXISTING TRANSFORMER. CONTRACTOR TO SOFT DIG, EXCAVATE AND EXPOSE CABLE.
 - (C) CONTRACTOR TO REMOVE THE NEUTRAL-GROUND LINK AT THE SERVICE ENTRANCE.

- MANITOBA HYDRO SCOPE OF WORK:**
1. DEMOLISH THE UTILITY CABLE FEEDING THE 5kV TRANSFORMER.



NO.	REVISIONS	DATE	DESIGN	CHECK
01	ISSUED FOR TENDER AND CONSTRUCTION	2024/12/20	PG	VE

AtkinsRéalis 148 Nature Park Way, Winnipeg, Manitoba Canada R3P 0X7 204-786-8080		ENGINEER'S SEAL
DESIGNED BY: P. GILL	CHECKED BY: V. ELIMBAN	
DRAWN BY: K. MOHAMMED	APPROVED BY: D. BECKER	
SCALE: N.T.S.	ISSUED FOR CONSTRUCTION BY: B. SOLOWAY	
DATE: 2024/07/18	DATE: 2024/12/20	
CONSULTANT NO.: 701408		

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

COLONY FLOOD PUMPING STATION
 2025 TRANSFORMER REMEDIATION UPGRADES
 SINGLE LINE DIAGRAM
 DEMOLITION

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0128F-E0001	001	01	A1