



- DEMOLITION NOTES:**
- (A) COORDINATE WITH MANITOBA HYDRO TO DISCONNECT AND REMOVE THE EXISTING 600V SERVICE UTILITY METER. PATCH AND REPAIR ENCLOSURE WITH STEEL PLATES AND GASKETS. PAINT TO MATCH. PROVIDE DEMOLITION OF THE EXISTING OUTDOOR UTILITY METER, CONDUITS AND CABLING. CONSULT WITH MANITOBA HYDRO IF METER SHOULD BE KEPT, OTHERWISE DISPOSE OF METER.
 - (B) CONTRACTOR TO COORDINATE WITH MANITOBA HYDRO TO REMOVE THE 5KV CABLES TO THE EXISTING TRANSFORMER. CONTRACTOR TO SOFT DIG, EXCAVATE AND EXPOSE CABLE.
 - (C) CONTRACTOR TO REMOVE THE NEUTRAL-GROUND LINK AT THE SERVICE ENTRANCE.

- MANITOBA HYDRO SCOPE OF WORK:**
1. DEMOLISH THE UTILITY CABLE FEEDING THE 5KV TRANSFORMER.

**ENGINEERS
 GEOSCIENTISTS
 MANITOBA**
 Certificate of Authorization
AtkinsRéalis Canada Inc.
 No. 4489

NO.	REVISIONS	DATE	DESIGN	CHECK
01	ISSUED FOR TENDER AND CONSTRUCTION	2024/12/20	PG	VE

AtkinsRéalis
 148 Nature Park Way, Winnipeg, Manitoba
 Canada R3P 0X7 204-786-8080

DESIGNED BY: P. GILL
 DRAWN BY: K. MOHAMMED
 SCALE: N.T.S.
 DATE: 2024/07/18
 CONSULTANT NO.: 701408

CHECKED BY: V. ELIMBAN
 APPROVED BY: D. BECKER
 ISSUED FOR CONSTRUCTION BY: B. SOLOWAY
 DATE: 2024/12/20

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

MISSION FLOOD PUMPING STATION
 2025 TRANSFORMER REMEDIATION UPGRADES
 SINGLE LINE DIAGRAM
 DEMOLITION

CITY DRAWING NUMBER: 1-0163F-E0001
 SHEET: 001
 REV: 01
 SIZE: A1