



# 1042-2025 ADDENDUM 4

## TYLEHURST LIFT STATION UPGRADES 2026

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL**

ISSUED: 2026-03-06  
BY: Curtis Rawsthorne  
TELEPHONE NO. (431) 554-2606

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

### **PART B – BIDDING PROCEDURES**

Revise B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **March 13, 2026**.

### **PART E – SPECIFICATIONS**

Add E45.1 (i): Shoring shop drawings and designs for excavations.

### **QUESTIONS AND ANSWERS**

Q1: Can we request shoring shop drawing submittal be included as an expedited item upon award?

A1: These have been added and will be reviewed as an expedited shop drawing.

Q2: Are the existing valves 1 & 2 considered in an operational state currently or non-operational, or unknown?

A2: They have been recently exercised and found to be operational.

Q3: Is the existing 300mm overflow pipe from existing valve 1 required to be operational to flow to the CS during the Mar-Oct season?

A3: No. This existing pipe is not intended to be used at any time.

Q4: NMS specifications 01 91 13 and 01 91 13.13 list a commissioning agent to be used. Can the General Contractor and/or Subcontractors be designated as the commissioning agent?

Q4: Yes, this is acceptable.