



## 118-2025 ADDENDUM 2

### 2025 WATER MAIN RENEWALS – CONTRACT 1

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: March 5, 2025  
BY: Nick Tebinka, E.I.T.  
TELEPHONE NO. 204 259-1875

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **FORM B: PRICES**

Replace: 118-2025 Form B: Prices with 118-2025 Addendum 2 - Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Revise Items A.11 a), B.11 a)

Page numbering on some forms may be changed as a result.

#### **PART D – SUPPLEMENTAL CONDITIONS**

Add: D34.2 Notwithstanding C13.2 or D34.1, the Contract Administrator may permit the warranty period for a portion or portions of the Work to begin prior to the date of Total Performance if:

a) a portion of the Work cannot be completed because of unseasonable weather or other conditions reasonably beyond the control of the Contractor but that portion does not prevent the balance of the Work from being put to its intended use.

D34.2.1 In such case, the date specified by the Contract Administrator for the warranty period to begin shall be substituted for the date specified in C13.2 for the warranty period to begin.

Revise: D34.1 to read: Notwithstanding C13.2, the warranty period shall begin on the date of Total Performance and shall expire one (1) year thereafter unless extended pursuant to C13.2.1 or C13.2.2, in which case it shall expire when provided for thereunder.

#### **PART E – SPECIFICATIONS**

Add: E16 Cross Linked Polyethylene (PEXa) Water Service Pipe

##### **E16. CROSS LINKED POLYETHYLENE (PEXA) WATER SERVICE PIPE**

E16.1 Cross-Linked Polyethylene (PEXa) water service pipe may be used as a direct replacement for copper water service pipe. The following conditions apply to PEXa water service pipe. Approved Cross-Linked Polyethylene (PEXa) water service piping is Rehau Municipex.

- (a) Cross-Linked Polyethylene (PEXa) water service piping is not to be installed in any locations where the depth of cover is less than 2.1m.
- (b) Tracer wire is not required for standard Cross-Linked Polyethylene (PEXa) water service piping installations; however, the contract administrator reserves the right to request tracer wire in locations where it is deemed necessary.
- (c) Installation of Cross-Linked Polyethylene (PEXa) water service pipe shall conform to the most current revision of the City of Winnipeg Standard Construction Specifications, CW2110, and SD-012 as applicable.

E16.2 Measurement and Payment

- (d) No separate measurement or payment will be made for Cross-Linked Polyethylene (PEXa) water service pipe as a replacement for copper water service pipe. Water services shall be measured and paid for at the Contract Unit Price for "Water Services" at the applicable size, as identified in Form B: Prices.
- (e) No separate measurement or payment will be made for tracer wire installed with Cross-Linked Polyethylene (PEXa) water service pipe.