

30-2025 ADDENDUM 3

NEWPCC UV UPGRADE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: April 4, 2025
BY: Sarah Alexander, P.Eng.
TELEPHONE NO. 204-928-8328

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

DRAWINGS

Replace: 30-2025 _Drawing_ 1-0101U-S0012-001-03-R4 with 30-2025 _Addendum_3 _Drawing-1-0101U-S0012-001-03-R5

30-2025 _Drawing_ U2-S104-R0 with 30-2025 _Addendum_3 _Drawing-U2-S104-R1

30-2025 _Drawing_ UD-E101-R0 with 30-2025 _Addendum_3 _Drawing-UD-E101-R1

30-2025 _Drawing_ Y0-C101-R0 with 30-2025 _Addendum_3 _Drawing-Y0-C101-R1

NMS SPECIFICATIONS

Section 01 79 00 Demonstration and Training

Revise: 1.5.9 to read: Acceptable videographer is Dynacom Communications (George Gamvrelis, (204) 895-8080, dynacom@mts.net) or approved equal in accordance with B7.

Section 01 91 31 Commissioning Plan

Revise: 1.2.13 to read: Commissioning Agent: third-party Agent of the Contractor with a minimum of ten (10) years of experience in overseeing successful commissioning of water or wastewater treatment systems, satisfactory to the Contract Administrator. The Contractor shall submit credentials of proposed third-party Commissioning Agent to the Contract Administrator for review within four (4) weeks of Contract Award. The Commissioning Agent is responsible for the oversight and execution of Commissioning.

Revise: 1.2.17 to read: Detailed Commissioning Plan: Commissioning Plan developed by the Contractor and Commissioning Agent from the Base Commissioning Plan to be submitted and reviewed by the Contract Administrator, as described in Item 3.2. Unless defined as "Base Commissioning Plan", all other instances of "Commissioning Plan" refer to the Detailed Commissioning Plan.

Add: 1.3.5 Qualifications of the third-party Commissioning Agent to be submitted and accepted by the Contract Administrator as per Item 1.2.13.

Section 23 37 13 Diffusers, Registers and Grilles

Revise: 2.4.3.4 to read: Price Industries

Add: 2.4.3.5 Or approved equal in accordance with B7.

QUESTIONS AND ANSWERS

Q1: Drawing 1-0101U-S0012-001-03 REV4, shows detail 1 - cutting of existing wall. Is this applicable only to channel 2 or for all the channels?

A1: Detail 1 on Drawing 1-0101U-S0012-001-03 R5 applies to all channels.