



## 313-2025 ADDENDUM 3

### ST. CHARLES SEWER DISTRICT WASTEWATER SEWER

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: April 30, 2025  
BY: Andre Dumont  
TELEPHONE NO. 204 590-9096

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **FORM B: PRICES**

Replace: 313-2025 Addendum 1 - Form B (R1): Prices with 313-2025 Addendum 3 - Form B (R2): Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R2): Add Item B.2.b) Tie-Ins and Approaches

Form B(R2): Quantity for Item B.2.a) Main Line Paving Type 1A changed from 326.0 tonnes to 256.0 tonnes

Page numbering on some forms may be changed as a result.

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, May 7, 2025.

#### **PART E – SPECIFICATIONS**

Replace: E16.4 Measurement and Payment

E16.4 Seeding

E16.4.1 The Contractor shall complete seeding within the PTH 100 right-of-way to restore all existing surface areas disturbed by construction activities including but not limited to areas disturbed by construction equipment, excavations, development of site access and where construction materials were stockpiled, in accordance with CW 3520.

Add: E16.5 Measurement and Payment

E16.5 Measurement and Payment

E16.5.1 Completion of the PTH 100 Crossing will be paid on a lump sum basis as listed in the Form B: Prices.

E16.5.2 Payment will be made at the Contract Unit Price for "PTH 100 Crossing" as listed in the Form B: Prices.

E16.5.3 Payment for PTH 100 casing and carrier pipe installation shall include the following:

(a) Design, supply, installation, and removal of shoring;

- (b) Erection of all temporary fencing;
- (c) Development of site access;
- (d) Excavation and disposal of all unused excavated material;
- (e) Maintaining ditch flows around excavation;
- (f) Supply and installation of casing pipe;
- (g) Supply and installation of 450mm wastewater sewer pipe in a casing pipe;
- (h) Supply and installation of casing spacers, and end seals;
- (i) Supply and placement of backfill;
- (j) Supply and placement of grass seed;
- (k) Any and all other work and materials specified herein and required to complete the work as specified.

Add: E17.6.1(f)

- (f) Notwithstanding E17.6.1(b), E17.6.1(c) and E17.6.1(d), the Contractor shall be aware of potential groundwater inflow rates up to 5.8 l/s per 100 linear m of fully excavated shaft on Site.

Add: E17.7(e)

- (g) Costs associated with groundwater inflow rates up to 5.8 l/s per 100 linear m of fully excavated shaft shall be considered incidental to the Work in accordance with CW 2030 Section 4.1. No separate measurement or payment will be made.

## **QUESTIONS AND ANSWERS**

Q1: With Dewatering now being an allowance of \$300,000.00, will additional groundwater testing be required to establish inflow rates (in the upper sandy silt till) be required. Will all engineering required for this item be covered in this allowance. Clarify if there are any cost for dewatering that would be considered incidental to sewer work.

A1: Additional groundwater testing is required per E17.6.1(b). Per E17.7(c), the additional groundwater testing and all associated reporting (including engineering) shall be considered incidental to the Work. Per E17.7(d), costs for dewatering in excess of 5.8 l/s per 100 m of excavation based on the recommendations from the Contractor's Professional Engineer or Geoscientist groundwater testing report shall be paid for under the cash allowance for "Excess Groundwater Dewatering". Costs unrelated to Work performed in E17.6.1 will be considered incidental to the Work in accordance with CW 2030 Section 4.1. Inflow rates up to 5.8 l/s per 100 linear m of full excavated shaft as presented in the Hydrogeological Report in Appendix B is considered incidental to the contract – per Addendum 3 E17.7(e).

Q2: Looking at your quantities for Item B.5 Sodding of 280m2. Wondering if any consideration has been taken for the PTH100 Crossing. I do not believe restoration, the way I am reading the specifications is incidental to the Crossing Item. Access road will need to be built to access the shaft locations, thus requiring a significant amount of restoration. Also, I do not believe sodding would be required in this ditch, Top Soil & Seed might be more appropriate option.

A2: Per Addendum 2 E16.4.1, seeding within the PTH 100 right-of-way shall be completed in accordance with CW 3520. Per Addendum 2 E16.5.3(j), supply and placement of grass seed shall be included in the Contract Unit Price for "PTH 100 Crossing" as listed in the Form B: Prices.