



415-2025 ADDENDUM 6

CHLORINE VENTILATION UPGRADES AT REGIONAL PUMPING STATIONS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 8th, 2025
BY: Drew Murray
TELEPHONE NO. 204 986-2492

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The submission Deadline is 12:00 noon Winnipeg Time, July 11th, 2025

PART D – SUPPLEMENTAL CONDITIONS

Revise: D20.4 to read: The City intends to award this Contract by August 15th, 2025.

NMS SPECIFICATIONS

Section 23 05 00 Common Work Results for HVAC

Revise: 3.2.1 to read: Clean interior and exterior of all systems.

Add: 3.2.2 Duct cleaning should be done to SMACNA Cleanliness Basic Level.

Add: 3.2.3 Duct cleaning should be performed with high powered vacuum machines. Protect equipment which may be harmed by excessive dirt with filters or by bypass during cleaning. Provide adequate access into duct work for cleaning purposes.

Add: 3.2.4 All duct cleaning shall be performed by NADCA certified technician. Supply and return ducts shall be cleaned in accordance with NADCA General Specifications for the Cleaning of Commercial Heating, Ventilation, and Air Conditioning Systems.