



415-2025 ADDENDUM 7

CHLORINE VENTILATION UPGRADES AT REGIONAL PUMPING STATIONS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 11th, 2025
BY: Drew Murray
TELEPHONE NO. 204 986-2492

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The submission Deadline is 12:00 noon Winnipeg Time, July 17th, 2025

DRAWINGS

The following modifications were made which require the Drawings listed below to be addended.

Replace: 415-2025 Drawing 1-0630M-E0075-001-R0 with 415-2025 Addendum 7 Drawing 1-0630M-E0075-001-R1
Replace: 415-2025 Drawing 1-0630M-E0080-001-R0 with 415-2025 Addendum 7 Drawing 1-0630M-E0080-001-R1
Replace: 415-2025 Drawing 1-0630M-M0034-001-R0 with 415-2025 Addendum 7 Drawing 1-0630M-M0034-001-R1
Replace: 415-2025 Drawing 1-0640C-S0008-002-R0 with 415-2025 Addendum 7 Drawing 1-0640C-S0008-002-R1
Replace: 415-2025 Drawing 1-0640C-C0002-001-R0 with 415-2025 Addendum 7 Drawing 1-0640C-C0002-001-R1

NMS SPECIFICATIONS

Section 23 34 00.3 HVAC Fans (Unoccupied Exhaust Fans Specification)

Revise: 2.6.11 to read: Fan shall be model FCE-D as manufactured by COOK Fan Corporation or approved equal in accordance with B7.

Delete 2.6.12

Delete 2.6.13

Section 26 29 23 Variable Frequency Drives

Revise: 1.3.1 to read: Voltage: 120V input/ 208V output.

Revise: 1.3.2 to read: Single phase input/ Three phase output.