



63-2025B ADDENDUM 2

CONSTRUCTION OF NEW SOUTH WINNIPEG RECREATION CAMPUS PHASE 1

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: January 14, 2026
BY: Liane Wychreschuk
TELEPHONE NO. 204 515-0780 x 404

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

NMS SPECIFICATIONS

Section 20 05 00 General Instructions for Mechanical Sections

Delete 1.10.

Section 26 05 01 General Instructions for Electrical Sections

Revise 1.23.1 to read: Refer to 01 25 00 Substitution Procedures.

Delete 1.23.4.

Section 26 51 13 Lighting Equipment

Revise 1.3.1. to read: The lighting equipment for this project and specified herein has been carefully selected for its ability to meet the project's luminous environment requirements. Manual and computer calculations have been performed to ensure that the lighting equipment that has been specified complies with established criteria. The Contract Administrator reserves the right not to accept any alternates or substitutions in accordance with the requirements of the Luminaire Schedule. If alternates or substitutions are entertained, then it is the responsibility of the Contractor/Supplier to provide: a comparison table showing the specified and the proposed luminaire performance information, IES files for the proposed luminaires, the information required herein, and detailed layouts and lighting calculations demonstrating that the performance of the alternate luminaire meets or exceeds the original lighting design while not consuming any additional energy. The Contractor/Supplier is responsible to ensure the light levels provided in the alternate submittal package will achieve the design light levels.

Section 26 51 14 Sports and Recreational Lighting

Revise: 2.1. to read: The lighting equipment for this project and specified herein has been carefully selected for its ability to meet the project's luminous environment requirements. Manual and computer calculations have been performed to ensure that the lighting equipment that has been specified complies with the established criteria.

Section 27 00 05.10 General Instructions for Telecommunications Sections

Delete 1.7.

QUESTIONS AND ANSWERS

Q1: Can you please confirm if this project will be subject to the recent Manitoba Jobs Agreement.

A1: Manitoba Jobs Agreement is not applicable to this tender.