

EQUIPMENT NO.		R-H-AHU-01		R-H-AHU-03										
Make		CONDAIR		CONDAIR										
Model		RS 180/550-600/3		RS 090/550-600/3'										
Air Handler Served		R-AHU-01		R-AHU-03										
Airflow Rate	cfm	L/s	21,000	9,912	8,700	4,106	--	--	--	--	--	--	--	--
Outdoor Airflow Rate	cfm	L/s	13,000	6,136	8,700	4,106	--	--	--	--	--	--	--	--
Winter Space Temperature	°F	°C	72.0	22.2	72.0	22.2	--	--	--	--	--	--	--	--
Winter Space Humidity	% RH		30		41									
Summer Space Temperature	°F	°C	75.0	23.9	75.0	23.9	--	--	--	--	--	--	--	--
Summer Space Humidity	% RH		50		50									
Water Requirements	Lb/hr	Kg/hr	180	82	90	41	--	--	--	--	--	--	--	--
Steam Pressure	psia	kPa		--		--	--	--	--	--	--	--	--	--
Power Requirements	MBH	kW	219	64.10	109	32.00	--	--	--	--	--	--	--	--
Heater Type			Resistive		Resistive									
Remarks														
EQUIPMENT NO.														
Make														
Model														
Air Handler Served														
Airflow Rate	cfm	L/s		--		--	--	--	--	--	--	--	--	--
Outdoor Airflow Rate	cfm	L/s		--		--	--	--	--	--	--	--	--	--
Winter Space Temperature	°F	°C		--		--	--	--	--	--	--	--	--	--
Winter Space Humidity	% RH													
Summer Space Temperature	°F	°C		--		--	--	--	--	--	--	--	--	--
Summer Space Humidity	% RH													
Water Requirements	Lb/hr	Kg/hr		--		--	--	--	--	--	--	--	--	--
Steam Pressure	psia	kPa		--		--	--	--	--	--	--	--	--	--
Power Requirements	hp	kW		--		--	--	--	--	--	--	--	--	--
Remarks														

