



639-2025 ADDENDUM 2

CONSTRUCTION OF THE TACHE BOOSTER PUMPING STATION AQUEDUCT DRAIN CHAMBER

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: August 14, 2025
BY: Matt Krentz, C.E.T.
TELEPHONE NO. 204-346-4226

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART E – SPECIFICATIONS

Add: E12.2.11(d) Available record information indicates cast iron drain piping internal diameter of 406 mm (16") with coal-tar varnish coating. Contractor to confirm sizing in the field prior to procurement.

DRAWINGS

Replace: 639-2025 _Drawing_1-0660Y-C0001-001-R0 with 639-2025 _Addendum_2 Drawing 1-0660Y-C0001-001-R1

Replace: 639-2025 _Drawing_1-0660Y-S0001-001-R0 with 639-2025 _Addendum_2 Drawing 1-0660Y-S0001-001-R1