



708-2025 ADDENDUM 1

WOODBINE AVENUE WASTEWATER SEWER REPLACEMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: August 26, 2025
BY: Jordan Thompson
TELEPHONE NO. 204-477-5381

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace: 708-2025 Form B: Prices with 708-2025 Addendum 1 - Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): A.4 a) revised Unit to m³.

Form B(R1): Add Item C.7.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, August 29, 2025.

PART E – SPECIFICATIONS

Revise: E13.4.2 (a) to read: Water levels within the interceptor sewer are partially controlled by pump operations at NEWPCC. The City will endeavour to lower water levels within the interceptor system through modifying the NEWPCC pumping operations in accordance with D22.

Revise: E13.5 to read: The work specified herein will be considered incidental to the Work and will not be measured for payment. No additional payment will be made.

Add: E18.2 (c) Formwork, Reinforcing Steel and Concrete

(i) As per CW 2160.

Add: E18.2 (d) Concrete Mix Design

(i) As per CW 2160.

Add: E18.2 (e) Extrudable Waterstop

(i) Gun Grade extrudable polyurethane based waterstop, SikaSwell S2 by Sika, or Approved Equal in accordance with B7.

Add: E18.3 (d) Reinforcing steel Shop Drawings and concrete mix design in accordance with CW 2160.

Revise: E18.4 (c) to read: Contractor shall remove the portion of 900 mm diameter manhole riser and install a new 1500 mm diameter manhole riser down to new 250 mm connection drop pipe. Provide a cast-in-place concrete manhole base for transition from new riser to existing, as shown on the Drawings.

DRAWINGS

Replace: 708-2025 _Drawing_13631-R0 with 708-2025 _Addendum_1 Drawing_13631-R1