



979-2025 ADDENDUM 3

CHLORINE VENTILATION UPGRADES AT REGIONAL PUMPING STATIONS

ISSUED: January 12th, 2026
BY: Drew Murray
TELEPHONE NO. 204 986-2492

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

NMS SPECIFICATIONS

Add: Section 44 66 33 Network Cabling.

QUESTIONS AND ANSWERS

Q1: Drawings 1-0630M-A0031, 1-0630M-A0032, 1-0630M-A0033 & 1-0630M-A0037 which are referenced on drawings 1-0630M-E0026 & 1-0630M-E0027 & 1-0630M-E0029 respectively are not on the drawing index for Maclean Pumping Station and do not appear to be in the provided package. Please advise if this it to be included.

A1: Drawings 1-0630M-A0026, 1-0630M-A0027, and 1-0630M-A0029 are existing City of Winnipeg drawings and only the work shown within the revision clouds are part of the scope of work. The drawing numbers referenced in the question are associated with existing infrastructure on the drawings and do not contain revision clouds and is not part of the scope of work. This is applicable to all drawings with revision clouds.

Q2: Looking for information on type and number of strands for the fibre optic cables to be pulled at Hurst and Mcphillips? Please advise.

A2: Each fibre cable specified will be 2 strands, OM3, Multi Mode. All fibre cables shall be tested in accordance to current code requirements. Fibre network cable specification 446633 has been included as part of the addendum.