



MAIN FLOOR DEMOLITION – ELEV 233.334
SCALE: 1:75

1-0650M-E0058	ELECTRICAL FIRE ALARM, LEGEND AND DETAILS
DRAWING NUMBER	REFERENCE DRAWINGS

METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES
0.0 0.75 1.5 3.0 4.5
1:75

AtkinsRéalis
ENGINEERS
GEOSCIENTISTS
MANITOBA
Certificate of Authorization
AtkinsRéalis Canada Inc.
No. 4489

GENERAL NOTES:

1. THE CONTRACTOR IS RESPONSIBLE TO REMOVE ALL EQUIPMENT ASSOCIATED WITH THE EXISTING FIRE ALARM SYSTEM. NOT ALL EQUIPMENT/DEVICES/WIRING ARE SHOWN.
2. EXISTING FIRE ALARM DEVICES ARE TO BE REMOVED AFTER NEW SYSTEM IS INSTALLED IN ORDER TO MAINTAIN FIRE ALARM PROTECTION IN THE BUILDING. EXISTING CONNECTIONS TO THE FIRE ALARM CONTROL PANEL FROM THE PLC SHOULD BE RE-ROUTED TO NEW FIRE ALARM PANEL FOR MONITORING.

DEMOLITION NOTES:

- (A) DEMOLISH EXISTING HEAT DETECTOR AND ALL ASSOCIATED WIRING/CONDUIT.
- (B) DEMOLISH EXISTING SMOKE DETECTOR AND ASSOCIATED WIRING/CONDUIT.
- (C) DEMOLISH EXISTING MANUAL PULL STATIONS AND ASSOCIATED WIRING/CONDUIT.
- (D) DEMOLISH EXISTING FIRE ALARM BELL AND ASSOCIATED WIRING/CONDUIT.
- (E) DEMOLISH EXISTING FIRE ALARM PANEL AND ALL ASSOCIATED WIRING/CONDUIT.

		AtkinsRéalis		ENGINEER'S SEAL	THE CITY OF WINNIPEG	
		148 Nature Park Way, Winnipeg, Manitoba Canada R3P 0X7 204-786-8080				
DESIGNED BY:	B. WILKS	CHECKED BY:	V. ELIMBAN			
DRAWN BY:	J. GRAGASIN	APPROVED BY:	V. ELIMBAN			
SCALE:	1:75	ISSUED FOR CONSTRUCTION				
DATE:	2023/05/15	BY:	M. SKINNER			
		DATE:	2025/04/30			
00	ISSUED FOR TENDER AND CONSTRUCTION	VE	VE			
NO. REVISIONS		DATE	DESIGN CHECK	CONSULTANT NO.:		
CITY DRAWING NUMBER						
1-0650M-E0059		SHEET	REV.	SIZE		
100		001	00	A1		

Winnipeg THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

HURST PUMPING STATION
CHLORINE SYSTEM UPGRADES
ELECTRICAL FIRE ALARM PLAN
MAIN FLOOR
DEMOLITION