



MAIN FLOOR PLAN  
SCALE: 1 : 50

#### DEMOLITION NOTES

- (A) REMOVE EXISTING EXHAUST FAN (FN-3), LOUVRE AND DAMPER.
- (B) REMOVE EXISTING EXHAUST FAN (FN-4), LOUVRE AND DAMPER.
- (C) REMOVE EXISTING EXHAUST FAN (FN-1), LOUVRE AND DAMPER.
- (D) REMOVE EXISTING EXHAUST FAN (FN-2), LOUVRE AND DAMPER.
- (E) REMOVE EXISTING MOTORIZED DAMPER AND LOUVRE.
- (F) EXISTING 5kW ELECTRICAL WALL HEATER TO REMAIN.
- (G) EXISTING THERMOSTAT AND WIRING TO REMAIN.
- (H) EXISTING RWL AT HIGH LEVEL TO REMAIN.
- (J) EXISTING EYEWASH STATION TO REMAIN. REMOVE DCW PIPING AND DHW PIPING TO SAFETY SHOWER/EYEWASH. REMOVE EXISTING MIXING VALVE.
- (K) EXISTING HOT WATER TANK TO BE REMOVED.
- (L) EXISTING FLOOR DRAIN TO REMAIN.
- (M) FLOOR DRAIN TO BE FILLED AND ABANDONED.

#### DEMOLITION NOTES

- (N) EXISTING DRAIN PIPE/VENT TO REMAIN.
- (P) EXISTING CONCRETE FLOOR TO BE REMOVED AS SHOWN. EXISTING FLOOR DRAIN AND PIPE TO BE REMOVED. PREPARE SITE FOR NEW DRAIN PIPE.
- (Q) EXISTING HOSE BIB TO BE REMOVED AND EXISTING DCW SUPPLY TO BE MODIFIED TO SUIT NEW PLUMBING REQUIREMENTS.

#### GENERAL NOTES

1. DRAWING INFORMATION BASED ON HISTORICAL DRAWING AND SITE INVESTIGATIONS.
2. INSULATION ON ALL EXISTING DOMESTIC WATER, FRESH AIR INTAKE, RAIN WATER LEADER, CONDENSATE AND DRAIN PIPE FITTINGS MAY CONTAIN ASBESTOS MATERIALS. REFER TO EXISTING ASBESTOS REPORTS TO CONFIRM.
3. MASONRY BLOCK WALLS, CEILING OR WALL HARD PLASTERS AND CERAMIC FLOOR TILES MAY CONTAIN ASBESTOS.

DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------

METRIC  
WHOLE NUMBERS INDICATE MILLIMETRES  
DECIMALIZED NUMBERS INDICATE METRES  
0.0 0.5 1.0 2.0 3.0  
1:50

ENGINES  
GEOLOGISTS  
MANITOBA  
Certificate of Authorization  
AtkinsRéalis Canada Inc.  
No. 4489

00	ISSUED FOR TENDER AND CONSTRUCTION	2025/04/30	TS	SN
NO. REVISIONS	DATE DESIGN CHECK	CONSULTANT NO.: 694715-3000-45DD-1001		

**AtkinsRéalis**  
148 Nature Park Way, Winnipeg, Manitoba  
Canada R3P 0X7 204-786-8080  
DESIGNED BY: T. SHAW CHECKED BY: S. NORSWORTHY  
DRAWN BY: M. GAUDINO APPROVED BY: S. NORSWORTHY  
SCALE: AS NOTED ISSUED FOR CONSTRUCTION  
DATE: 2023-03-06 DATE: 2025/04/30  
CONSULTANT NO.: 694715-3000-45DD-1001

ENGINEER'S SEAL

**THE CITY OF WINNIPEG**  
**Winnipeg** WATER AND WASTE DEPARTMENT  
MCPHILLIPS PUMPING STATION  
CHLORINE SYSTEM UPGRADE  
MECHANICAL  
REMOVALS  
CITY DRAWING NUMBER  
1-0640C-M0001 SHEET REV. SIZE  
001 00 A1