

CONSTRUCTION STANDARDS

MUNICIPAL EXCAVATION STANDARDS

- ** DISCLAIMER ****
THE INDICATION OF OTHER PARTIES ON THIS DRAWING ARE FOR TRENCH
LOCATION PURPOSES ONLY. REFER TO THE OTHER PARTY'S DRAWINGS FOR
DESIGN DETAILS.

CONTACT	NAME	PHONE NUMBER	E-MAIL ADDRESS
DESIGN	PATRIC LEBECQUE	918-3807	plebecque@mcw.com
DESIGN ENGINEER	KRESTA ZUMEL	779-7900	kzumel@mcw.com
MH DESIGN ENGINEER	SCOTT WHALEY	204 761-4906	swhaley@hydro.mb.ca
MAJOR ACCOUNT ADVISOR	RYAN AUBRY	323-3097	raubry@hydro.mb.ca
U/G CONSTRUCTION	BRENT KROEKER	204-360-4275	bckroeker@hydro.mb.ca
U/G CONSTRUCTION	DEAN ADAMS	360-5712	dadams@hydro.mb.ca
DISTRICT ENG TECH	PHIL BRUCE	360-3073	pbruce@hydro.mb.ca


AUTHORITY	NOTIFIED	NOT REQ'D	OBTAINED
DEPT. OF HIGHWAYS		X	
COWMUNICIPAL APPROVALS	2026-		2026-
M.T.S.		X	
GAS		X	
EASEMENTS		X	
CONTROL CENTER		X	
RAILWAY		X	
CATV		X	
DISTRICT	2026-		2026-

NOT TO BE USED
FOR CONSTRUCTION

PRIOR TO CONSTRUCTION FOR LOCATION OF EXISTING
WATER, WASTEWATER AND LAND DRAINAGE UTILITIES

INSTALLED			
Quantity	Fixture Type	Wattage	Pole Type
4	LED	40	EXCLUSIVE
0	LED	50	SHARED
0	LED	60	EXCLUSIVE
0	LED	90	EXCLUSIVE
0	LED	150	EXCLUSIVE
0	LED	209	EXCLUSIVE

REMOVED			
Quantity	Fixture Type	Wattage	Pole Type
3	LED	45	EXCLUSIVE
0	LED	73	EXCLUSIVE
0	LED	150	EXCLUSIVE
0	LED	209	EXCLUSIVE
0	LED	400	SHARED



REEL NUMBER	MANUFACTURER	MANUFACTURE DATE

NO.	DAT	REVISIONS	BY	CK D.	APP	AREA NUMBER 5202	MANITOBA HYDRO DISTRIBUTION ENGINEERING					
00	2026-0	ISSUE TO CONSTRUCTION	PRL				STATION NUMBER 1505	WO# P:42605 NETWORK # 4309380				
							FEEDER NUMBER	CSC: CITY CENTRE CUSTOMER SERVICE PROJECT: CITY OF WINNIPEG ROAD RENEWAL - WEATHERDON AVE INSTALL 4-25' DAVITS WITH 40W LED LUMINAIRES, #4 AL CN IN 50MM CONDUIT				
							SYSTEM VOLTAGE 2.4/4.16KV					
DRAWING NUMBER		REFERENCE DRAWINGS				DRAW	P.R.L.			1-04707-DC-50000-0691	SHT 01	REV. 00
		City Of Winnipeg Approval				CHECK						
						SCAL	1:750					
						DAT	2026-02-11					