



## 326-2026 ADDENDUM 1

### NEWPCC SLUDGE CAKE PUMP UPGRADE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: April 28, 2026  
BY: Prasan Silva  
TELEPHONE NO. 204 998 2278

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART D – SUPPLEMENTAL CONDITIONS:**

Revise: D2.2 (a) (i) to read:

Disconnect and remove existing power units 5 and 6 and associated piping, electrical, controls, etc.  
Remove and dispose of hydraulic oil in an approved disposal facility. Allow the City to remove any internal components they wish keep as spare parts prior to disposal of the units.

#### **NMS Specifications:**

##### **Section 23 21 00 Sludge Pump Powerpack**

Add: 3.4.1.3 The Contractor shall provide the initial fill of ISO 46 hydraulic oil (Hydrex AW 46) required for the hydraulic power packs.