



**THE CITY OF WINNIPEG**

**TENDER**

**TENDER NO. 33-2026**

**2026 LOCAL STREET RENEWAL PROGRAM- CHANCELLOR DRIVE, KINGS  
DRIVE, AND VARIOUS OTHER LOCATIONS**

## TABLE OF CONTENTS

### PART A - BID SUBMISSION

- Form A: Bid/Proposal
- Form B: Prices
- Form G1: Bid Bond and Agreement to Bond

### PART B - BIDDING PROCEDURES

B1. Contract Title	1
B2. Submission Deadline	1
B3. Enquiries	1
B4. Confidentiality	1
B5. Addenda	1
B6. Substitutes	2
B7. Bid Components	3
B8. Bid	3
B9. Prices	4
B10. Disclosure	4
B11. Conflict of Interest and Good Faith	4
B12. Qualification	5
B13. Bid Security	7
B14. Opening of Bids and Release of Information	7
B15. Irrevocable Bid	8
B16. Withdrawal of Bids	8
B17. Evaluation of Bids	8
B18. Award of Contract	8

### PART C - GENERAL CONDITIONS

C0. General Conditions	1
------------------------	---

### PART D - SUPPLEMENTAL CONDITIONS

#### General

D1. General Conditions	1
D2. Scope of Work	1
D3. Contract Administrator	3
D4. Contractor's Supervisor	3
D5. Furnishing of Documents	4

#### Submissions

D6. Authority to Carry on Business	4
D7. Safe Work Plan	4
D8. Insurance	4
D9. Contract Security	5
D10. Subcontractor List	6
D11. Detailed Work Schedule	6
D12. Requirements for Site Accessibility Plan	7

#### Schedule of Work

D13. Commencement	8
D14. Working Days	8
D15. Restricted Work Hours	9
D16. Work By Others	9
D17. Sequence of Work	9
D18. Critical Stages	10
D19. Substantial Performance	10
D20. Total Performance	10
D21. Liquidated Damages	10
D22. Scheduled Maintenance	11

**Control of Work**

D23. Job Meetings	11
D24. Prime Contractor – The Workplace Safety and Health Act (Manitoba)	11
D25. The Workplace Safety and Health Act (Manitoba) – Qualifications	11

**Payment**

D26. Fuel Price Adjustment	11
----------------------------	----

**Warranty**

D27. Warranty	12
---------------	----

**Indemnity**

D28. Indemnity	13
----------------	----

**Third Party Funding**

D29. Funding From The Manitoba Recreational Trails Association Inc. Form J: Subcontractor List	13 15
---	----------

**PART E - SPECIFICATIONS**

**General**

E1. Applicable Specifications and Drawings	1
E2. Mobilization and Demobilization Payment	3
E3. Geotechnical Report	4
E4. Protection Of Existing Trees	4
E5. Traffic Control	5
E6. Traffic Management	6
E7. Refuse and Recycling Collection	6
E8. Pedestrian Safety	7
E9. Water Obtained From the City	7
E10. Surface Restorations	8
E11. Infrastructure Signs	8

**Technical**

E12. Asphalt Pavement Special Provisions	8
E13. City of Winnipeg Revised Standard Details	8
E14. Sidewalk Expansion Joints	8
E15. Hauling and Placement of Granular B Recycled Concrete Aggregate	9
E16. Tree and Shrub Removal	11
E17. Kings Park Site Furnishings	12
E18. Removal of Interlocking Paving Stones	13
E19. Precast Concrete Parking Curbs	13
E20. Curbs For Asphalt Pavement	14
E21. Supply and Install Watermain and Water Service Insulation	15
E22. Stump Grinding	16
E23. Parking Lot Line Painting	17
E24. Manitoba Hydro Gas Information	17
E25. Installation of Street Lighting and Associated Works	17

**Appendix “A” – Geotechnical Report**

**Appendix “B” – Asphalt Pavement Special Provisions**

**Appendix “C” – City of Winnipeg Revised Standard Details**

**Appendix “D” – Manitoba Hydro Streetlighting Standards**

**Appendix “E” – Safe Excavation and Safety Watch Guidelines**

**Appendix “F” – GELCAP Kit**

**Appendix “G” – Electric and/or Natural Gas Facilities Locate**

**Appendix “H” – Manitoba Hydro Job Plan- Engineering and Construction**

**Appendix “I” – Manitoba Hydro Network Commissioning Report**

**Appendix “J” – Manitoba Hydro Gas Information**

**Appendix “K” – University of Manitoba Tree Protection Specification**

## **PART B - BIDDING PROCEDURES**

### **B1. CONTRACT TITLE**

B1.1 2026 Local Street Renewal Program- Chancellor Drive, Kings Drive, and Various Other Locations

### **B2. SUBMISSION DEADLINE**

B2.1 The Submission Deadline is 12:00 noon Winnipeg time, March 26, 2026.

B2.2 The Contract Administrator or the Manager of Purchasing may extend the Submission Deadline by issuing an addendum at any time prior to the time and date specified in B2.1.

### **B3. ENQUIRIES**

B3.1 All enquiries shall be directed to the Contract Administrator identified in D3.1.

B3.2 If the Bidder finds errors, discrepancies or omissions in the Tender, or is unsure of the meaning or intent of any provision therein, the Bidder shall notify the Contract Administrator of the error, discrepancy or omission, or request a clarification as to the meaning or intent of the provision at least five (5) Business Days prior to the Submission Deadline.

B3.3 Responses to enquiries which, in the sole judgment of the Contract Administrator, require a correction to or a clarification of the Tender will be provided by the Contract Administrator to all Bidders by issuing an addendum.

B3.4 Responses to enquiries which, in the sole judgment of the Contract Administrator, do not require a correction to or a clarification of the Tender will be provided by the Contract Administrator only to the Bidder who made the enquiry.

B3.5 The Bidder shall not be entitled to rely on any response or interpretation received pursuant to B3 unless that response or interpretation is provided by the Contract Administrator in writing.

B3.6 Any enquiries concerning submitting through MERX should be addressed to:  
MERX Customer Support  
Phone: 1-800-964-6379  
Email: merx@merx.com

### **B4. CONFIDENTIALITY**

B4.1 Information provided to a Bidder by the City or acquired by a Bidder by way of further enquiries or through investigation is confidential. Such information shall not be used or disclosed in any way without the prior written authorization of the Contract Administrator. The use and disclosure of the confidential information shall not apply to information which:

- (a) was known to the Bidder before receipt hereof; or
- (b) becomes publicly known other than through the Bidder; or
- (c) is disclosed pursuant to the requirements of a governmental authority or judicial order.

B4.2 The Bidder shall not make any statement of fact or opinion regarding any aspect of the Tender to the media or any member of the public without the prior written authorization of the Contract Administrator.

### **B5. ADDENDA**

B5.1 The Contract Administrator may, at any time prior to the Submission deadline, issue addenda correcting errors, discrepancies or omissions in the Tender, or clarifying the meaning or intent of any provision therein.

- B5.2 The Contract Administrator will issue each addendum at least two (2) Business Days prior to the Submission Deadline, or provide at least two (2) Business Days by extending the Submission Deadline.
- B5.3 Addenda will be available on the MERX website at [www.merx.com](http://www.merx.com).
- B5.4 The Bidder is responsible for ensuring that they have received all addenda and is advised to check the MERX website for addenda regularly and shortly before the Submission Deadline, as may be amended by addendum.
- B5.5 The Bidder shall acknowledge receipt of each addendum in Paragraph 10 of Form A: Bid/Proposal. Failure to acknowledge receipt of an addendum may render a Bid non-responsive.
- B5.6 Notwithstanding B3, enquiries related to an Addendum may be directed to the Contract Administrator indicated in D3.

## **B6. SUBSTITUTES**

- B6.1 The Work is based on the Plant, Materials and methods specified in the Tender.
- B6.2 Substitutions shall not be allowed unless application has been made to and prior approval has been granted by the Contract Administrator in writing.
- B6.3 Requests for approval of a substitute will not be considered unless received in writing by the Contract Administrator at least five (5) Business Days prior to the Submission Deadline.
- B6.4 The Bidder shall ensure that any and all requests for approval of a substitute:
- (a) provide sufficient information and details to enable the Contract Administrator to determine the acceptability of the Plant, Material or method as either an approved equal or alternative;
  - (b) identify any and all changes required in the applicable Work, and all changes to any other Work, which would become necessary to accommodate the substitute;
  - (c) identify any anticipated cost or time savings that may be associated with the substitute;
  - (d) certify that, in the case of a request for approval as an approved equal, the substitute will fully perform the functions called for by the general design, be of equal or superior substance to that specified, is suited to the same use and capable of performing the same function as that specified and can be incorporated into the Work, strictly in accordance with the proposed work schedule and the dates specified in the Supplemental Conditions for Substantial Performance and Total Performance;
  - (e) certify that, in the case of a request for approval as an approved alternative, the substitute will adequately perform the functions called for by the general design, be similar in substance to that specified, is suited to the same use and capable of performing the same function as that specified and can be incorporated into the Work, strictly in accordance with the proposed work schedule and the dates specified in the Supplemental Conditions for Substantial Performance and Total Performance.
- B6.5 The Contract Administrator, after assessing the request for approval of a substitute, may in their sole discretion grant approval for the use of a substitute as an “approved equal” or as an “approved alternative”, or may refuse to grant approval of the substitute.
- B6.6 The Contract Administrator will provide a response in writing, at least two (2) Business Days prior to the Submission Deadline, to the Bidder who requested approval of the substitute.
- B6.6.1 The Contract Administrator will issue an Addendum, disclosing the approved materials, equipment, methods and products to all potential Bidders. The Bidder requesting and obtaining the approval of a substitute shall be responsible for disseminating information regarding the approval to any person or persons they wish to inform.

- B6.7 If the Contract Administrator approves a substitute as an “approved equal”, any Bidder may use the approved equal in place of the specified item.
- B6.8 If the Contract Administrator approves a substitute as an “approved alternative”, any Bidder bidding that approved alternative may base their Total Bid Price upon the specified item but may also indicate an alternative price based upon the approved alternative. Such alternatives will be evaluated in accordance with B17.
- B6.9 No later claim by the Contractor for an addition to the Total Bid Price because of any other changes in the Work necessitated by the use of an approved equal or an approved alternative will be considered.

## **B7. BID COMPONENTS**

- B7.1 The Bid shall consist of the following components:
- (a) Form A: Bid;
  - (b) Form B: Prices;
  - (c) Form G1: Bid Bond and Agreement to Bond.
- B7.2 All components of the Bid shall be fully completed or provided, and submitted by the Bidder no later than the Submission Deadline, with all required entries made clearly and completely.
- B7.3 The Bid shall be submitted electronically through MERX at [www.merx.com](http://www.merx.com).
- B7.3.1 Bids will **only** be accepted electronically through MERX.
- B7.4 Bidders are advised that inclusion of terms and conditions inconsistent with the Tender document, including the General Conditions, will be evaluated in accordance with B17.1(a).

## **B8. BID**

- B8.1 The Bidder shall complete Form A: Bid/Proposal, making all required entries.
- B8.2 Paragraph 2 of Form A: Bid/Proposal shall be completed in accordance with the following requirements:
- (a) if the Bidder is a sole proprietor carrying on business in their own name, their name shall be inserted;
  - (b) if the Bidder is a partnership, the full name of the partnership shall be inserted;
  - (c) if the Bidder is a corporation, the full name of the corporation shall be inserted;
  - (d) if the Bidder is carrying on business under a name other than their own, the business name and the name of every partner or corporation who is the owner of such business name shall be inserted.
- B8.2.1 If a Bid is submitted jointly by two or more persons, each and all such persons shall identify themselves in accordance with B8.2.
- B8.3 In Paragraph 3 of Form A: Bid/Proposal, the Bidder shall identify a contact person who is authorized to represent the Bidder for purposes of the Bid.
- B8.4 Paragraph 13 of Form A: Bid/Proposal shall be signed in accordance with the following requirements:
- (a) if the Bidder is a sole proprietor carrying on business in their own name, it shall be signed by the Bidder;
  - (b) if the Bidder is a partnership, it shall be signed by the partner or partners who have authority to sign for the partnership;
  - (c) if the Bidder is a corporation, it shall be signed by their duly authorized officer or officers;

- (d) if the Bidder is carrying on business under a name other than their own, it shall be signed by the registered owner of the business name, or by the registered owner's authorized officials if the owner is a partnership or a corporation.

B8.4.1 The name and official capacity of all individuals signing Form A: Bid/Proposal should be entered below such signatures.

B8.5 If a Bid is submitted jointly by two or more persons, the word "Bidder" shall mean each and all such persons, and the undertakings, covenants and obligations of such joint Bidders in the Bid and the Contract, when awarded, shall be both joint and several.

## **B9. PRICES**

B9.1 The Bidder shall state a price in Canadian funds for each item of the Work identified on Form B: Prices.

B9.2 The quantities listed on Form B: Prices are to be considered approximate only. The City will use said quantities for the purpose of comparing Bids.

B9.3 The quantities for which payment will be made to the Contractor are to be determined by the Work actually performed and completed by the Contractor, to be measured as specified in the applicable Specifications.

B9.4 Payments to Non-Resident Contractors are subject to Non-Resident Withholding Tax pursuant to the Income Tax Act (Canada).

B9.5 The Bidder shall enter the Total Bid Price from Form B: Prices into the Total Bid Price field in MERX.

B9.5.1 Bidders are advised that the calculation indicated in B17.4 will prevail over the Total Bid Price entered in MERX.

B9.6 Form B: Prices is organized into Parts: Part 1 of the Work, Part 2 of the Work, and Part 3 of the Work. Bidders shall provide a total price for each Part and, on the summary sheet, a Total Bid Price consisting of the sum of prices for Part 1, Part 2, and Part 3.

## **B10. DISCLOSURE**

B10.1 Various Persons provided information or services with respect to this Work. In the City's opinion, this relationship or association does not create a conflict of interest because of this full disclosure. Where applicable, additional material available as a result of contact with these Persons is listed below.

B10.2 The Persons are:

- (a) N/A

## **B11. CONFLICT OF INTEREST AND GOOD FAITH**

B11.1 Further to C3.3, Bidders, by responding to this Tender, declare that no Conflict of Interest currently exists, or is reasonably expected to exist in the future.

B11.2 Conflict of Interest means any situation or circumstance where a Bidder or employee of the Bidder proposed for the Work has:

- (a) other commitments;
- (b) relationships;
- (c) financial interests; or
- (d) involvement in ongoing litigation;

that could or would be seen to:

- (i) exercise an improper influence over the objective, unbiased and impartial exercise of the independent judgment of the City with respect to the evaluation of Bids or award of the Contract; or
  - (ii) compromise, impair or be incompatible with the effective performance of a Bidder's obligations under the Contract;
- (e) has contractual or other obligations to the City that could or would be seen to have been compromised or impaired as a result of their participation in the Tender process or the Work; or
- (f) has knowledge of confidential information (other than confidential information disclosed by the City in the normal course of the Tender process) of strategic and/or material relevance to the Tender process or to the Work that is not available to other bidders and that could or would be seen to give that Bidder an unfair competitive advantage.

**B11.3** In connection with their Bid, each entity identified in B11.2 shall:

- (a) avoid any perceived, potential or actual Conflict of Interest in relation to the procurement process and the Work;
- (b) upon discovering any perceived, potential or actual Conflict of Interest at any time during the Tender process, promptly disclose a detailed description of the Conflict of Interest to the City in a written statement to the Contract Administrator; and
- (c) provide the City with the proposed means to avoid or mitigate, to the greatest extent practicable, any perceived, potential or actual Conflict of Interest and shall submit any additional information to the City that the City considers necessary to properly assess the perceived, potential or actual Conflict of Interest.

**B11.4** Without limiting B11.3, the City may, in their sole discretion, waive any and all perceived, potential or actual Conflicts of Interest. The City's waiver may be based upon such terms and conditions as the City, in their sole discretion, requires to satisfy itself that the Conflict of Interest has been appropriately avoided or mitigated, including requiring the Bidder to put into place such policies, procedures, measures and other safeguards as may be required by and be acceptable to the City, in their sole discretion, to avoid or mitigate the impact of such Conflict of Interest.

**B11.5** Without limiting B11.3, and in addition to all contractual or other rights or rights at law or in equity or legislation that may be available to the City, the City may, in their sole discretion:

- (a) disqualify a Bidder that fails to disclose a perceived, potential or actual Conflict of Interest of the Bidder or any of their employees proposed for the Work;
- (b) require the removal or replacement of any employees proposed for the Work that has a perceived, actual or potential Conflict of Interest that the City, in their sole discretion, determines cannot be avoided or mitigated;
- (c) disqualify a Bidder or employees proposed for the Work that fails to comply with any requirements prescribed by the City pursuant to B11.4 to avoid or mitigate a Conflict of Interest; and
- (d) disqualify a Bidder if the Bidder, or one of their employees proposed for the Work, has a perceived, potential or actual Conflict of Interest that, in the City's sole discretion, cannot be avoided or mitigated, or otherwise resolved.

**B11.6** The final determination of whether a perceived, potential or actual Conflict of Interest exists shall be made by the City, in their sole discretion.

## **B12. QUALIFICATION**

**B12.1** The Bidder shall:

- (a) undertake to be in good standing under The Corporations Act (Manitoba), or properly registered under The Business Names Registration Act (Manitoba), or otherwise properly registered, licensed or permitted by law to carry on business in Manitoba; and

- (b) be financially capable of carrying out the terms of the Contract; and
  - (c) have all the necessary experience, capital, organization, and equipment to perform the Work in strict accordance with the terms and provisions of the Contract.
- B12.2 The Bidder and any proposed Subcontractor (for the portion of the Work proposed to be subcontracted to them) shall:
- (a) be responsible and not be suspended, debarred or in default of any obligations to the City. A list of suspended or debarred individuals and companies is available on the Information Connection page at The City of Winnipeg, Corporate Finance, Purchasing Division website at <https://www.winnipeg.ca/matmgt/Templates/files/debar.pdf>
- B12.3 The Bidder and/or any proposed Subcontractor (for the portion of the Work proposed to be subcontracted to them) shall:
- (a) have successfully carried out work similar in nature, scope and value to the Work; and
  - (b) be fully capable of performing the Work required to be in strict accordance with the terms and provisions of the Contract; and
  - (c) have a written workplace safety and health program if required pursuant to The Workplace Safety and Health Act (Manitoba);
  - (d) have completed the Accessible Customer Service online training required by the Accessibility for Manitobans Act (AMA) (see B12.5 and C6.19)
- B12.4 Further to B12.3(c), the Bidder shall, within five (5) Business Days of a request by the Contract Administrator, provide proof satisfactory to the Contract Administrator that the Bidder/Subcontractor has a workplace safety and health program meeting the requirements of The Workplace Safety and Health Act (Manitoba), by providing:
- (a) Written confirmation of a safety and health certification meeting SAFE Work Manitoba's SAFE Work Certified Standard (e.g., COR™ and SECOR™) in the form of:
    - (i) a copy of their valid Manitoba COR certificate and Letter of Good Standing (or Manitoba equivalency) as issued under the Certificate of Recognition (COR) Program administered by the Construction Safety Association of Manitoba or by the Manitoba Heavy Construction Association's WORKSAFELY™ COR™ Program; or
    - (ii) a copy of their valid Manitoba SECOR™ certificate and Letter of Good Standing (or Manitoba equivalency) as issued under the Small Employer Certificate of Recognition Program (SECOR™) administered by the Construction Safety Association of Manitoba or by the Manitoba Heavy Construction Association's WORKSAFELY™ COR™ Program; or
  - (b) a report or letter to that effect from an independent reviewer acceptable to the City. A list of acceptable reviewers and the review template are available at [https://www.winnipeg.ca/matmgt/Safety/safety\\_consultant.stm](https://www.winnipeg.ca/matmgt/Safety/safety_consultant.stm).
- B12.5 Further to B12.3(d), the Bidder acknowledges that they and all Subcontractors have obtained training required by the Accessibility for Manitobans Act (AMA) available at <https://accessibilitymb.ca/resources-events-and-training/online-training.html> for anyone that may have any interaction with the public on behalf of the City of Winnipeg.
- B12.6 The Bidder shall submit, within three (3) Business Days of a request by the Contract Administrator, proof satisfactory to the Contract Administrator of the qualifications of the Bidder and of any proposed Subcontractor.
- B12.7 The Bidder shall provide, on the request of the Contract Administrator, full access to any of the Bidder's equipment and facilities to confirm, to the Contract Administrator's satisfaction, that the Bidder's equipment and facilities are adequate to perform the Work.

### **B13. BID SECURITY**

- B13.1 The Bidder shall include in their Bid Submission bid security in the form of a digital bid bond, in the amount of at least ten percent (10%) of the Total Bid Price, and agreement to bond of a company registered to conduct the business of a surety in Manitoba, in Form G1: Bid Bond and Agreement to Bond, available at: <https://www.winnipeg.ca/media/4929/>.
- B13.2 Bid security shall be submitted in a digital format meeting the following criteria:
- (a) The version submitted by the Bidder must have valid digital signatures and seals;
  - (b) The version submitted by the Bidder must be verifiable by the City with respect to the totality and wholeness of the bond form, including: the content; all digital signatures and digital seals; with the surety company, or an approved verification service provider of the surety company.
  - (c) The version submitted must be viewable, printable and storable in standard electronic file formats compatible with the City, and in a single file. Allowable formats include pdf.
  - (d) The verification may be conducted by the City immediately or at any time during the life of the bond and at the discretion of the City with no requirement for passwords or fees.
  - (e) The results of the verification must provide a clear, immediate and printable indication of pass or fail regarding B13.2(a).
- B13.3 Bonds failing the verification process will not be considered to be valid and the bid shall be determined to be non-responsive in accordance with B17.1(a).
- B13.4 Bonds passing the verification process will be treated as original and authentic.
- B13.4.1 If the Bidder submits alternative bids, the bid security shall be in the amount of the specified percentage of the highest Total Bid Price submitted.
- B13.5 The bid security of the successful Bidder and the next two lowest evaluated responsive and responsible Bidders will be released by the City when a Contract for the Work has been duly formed with the successful Bidder and the contract securities are furnished as provided herein. The bid securities of all other Bidders will be released when a Contract is awarded.
- B13.6 The bid securities of all Bidders will be released by the City as soon as practicable following notification by the Contract Administrator to the Bidders that no award of Contract will be made pursuant to the Tender.

### **B14. OPENING OF BIDS AND RELEASE OF INFORMATION**

- B14.1 Bids will not be opened publicly.
- B14.2 Following the submission deadline, the names of the Bidders and their Total Bid Prices (unevaluated, and pending review and verification of conformance with requirements) will be available on the MERX website at [www.merx.com](http://www.merx.com).
- B14.3 After award of Contract, the name(s) of the successful Bidder(s) and their Contract amount(s) will be available on the MERX website at [www.merx.com](http://www.merx.com).
- B14.4 The Bidder is advised that any information contained in any Bid may be released if required by The Freedom of Information and Protection of Privacy Act (Manitoba), by other authorities having jurisdiction, or by law or by City policy or procedures (which may include access by members of City Council).
- B14.4.1 To the extent permitted, the City shall treat as confidential information, those aspects of a Bid Submission identified by the Bidder as such in accordance with and by reference to Part 2, Section 17 or Section 18 or Section 26 of The Freedom of Information and Protection of Privacy Act (Manitoba), as amended.

**B15. IRREVOCABLE BID**

- B15.1 The Bid(s) submitted by the Bidder shall be irrevocable for the time period specified in Paragraph 11 of Form A: Bid/Proposal.
- B15.2 The acceptance by the City of any Bid shall not release the Bids of the next two lowest evaluated responsive Bidders and these Bidders shall be bound by their Bids on such Work until a Contract for the Work has been duly formed and the contract securities have been furnished as herein provided, but any Bid shall be deemed to have lapsed unless accepted within the time period specified in Paragraph 11 of Form A: Bid/Proposal.

**B16. WITHDRAWAL OF BIDS**

- B16.1 A Bidder may withdraw their Bid without penalty prior to the Submission Deadline.

**B17. EVALUATION OF BIDS**

- B17.1 Award of the Contract shall be based on the following bid evaluation criteria:
- (a) compliance by the Bidder with the requirements of the Tender, or acceptable deviation therefrom (pass/fail);
  - (b) qualifications of the Bidder and the Subcontractors, if any, pursuant to B12 (pass/fail);
  - (c) Total Bid Price;
  - (d) economic analysis of any approved alternative pursuant to B6.
- B17.2 Further to B17.1(a), the Award Authority may reject a Bid as being non-responsive if the Bid is incomplete, obscure or conditional, or contains additions, deletions, alterations or other irregularities. The Award Authority may reject all or any part of any Bid, or waive technical requirements or minor informalities or irregularities, if the interests of the City so require.
- B17.2.1 Any bid with an apparent imbalance between the unit prices in Part 1, Part 2, and Part 3 may be determined to be non-responsive and rejected by the Award Authority in their sole discretion, acting reasonably.
- B17.3 Further to B17.1(b), the Award Authority shall reject any Bid submitted by a Bidder who does not demonstrate, in their Bid or in other information required to be submitted, that they are qualified.
- B17.4 Further to B17.1(c), the Total Bid Price shall be the sum of the quantities multiplied by the unit prices for each item shown on Form B: Prices.
- B17.4.1 Further to B17.1(a), in the event that a unit price is not provided on Form B: Prices, the City may determine the unit price by dividing the Amount (extended price) by the approximate quantity, for the purposes of evaluation and payment.
- B17.4.2 Where MRST is shown on Form B as a separate line item, if that Line item is not completed, the MRST shall be considered to be included in the Total Bid Price.
- B17.4.3 Bidders are advised that the calculation indicated in B17.4 will prevail over the Total Bid Price entered in MERX.

**B18. AWARD OF CONTRACT**

- B18.1 The City will give notice of the award of the Contract or will give notice that no award will be made.
- B18.2 The City will have no obligation to award a Contract to a Bidder, even though one or all of the Bidders are determined to be qualified, and the Bids are determined to be responsive.

- B18.2.1 Without limiting the generality of B18.2, the City will have no obligation to award a Contract where:
- (a) the prices exceed the available City funds for the Work;
  - (b) the prices are materially in excess of the prices received for similar work in the past;
  - (c) the prices are materially in excess of the City's cost to perform the Work, or a significant portion thereof, with their own forces;
  - (d) only one Bid is received; or
  - (e) in the judgment of the Award Authority, the interests of the City would best be served by not awarding a Contract.
- B18.3 The Work of this Contract is contingent upon Council approval of sufficient funding in the 2026 Capital Budget. If the Capital Budget approved by Council does not include sufficient funding for the Work, the City will have no obligation to award a Contract.
- B18.4 Where an award of Contract is made by the City, the award shall be made to the qualified Bidder submitting the lowest evaluated responsive Bid, in accordance with B17.
- B18.4.1 Following the award of contract, a Bidder will be provided with information related to the evaluation of their Bid upon written request to the Contract Administrator.
- B18.5 As noted in D2 and identified in Form B: Prices, the Work of Parts 2 and 3 will be contingent upon the City receiving approved funding for the Work. If sufficient funding for Parts 2 and 3 Work is not approved the City shall have the right to eliminate all or any portion of Parts 2 or 3 Work in accordance with D2.

## PART C - GENERAL CONDITIONS

### C0. GENERAL CONDITIONS

- C0.1 The *General Conditions for Construction* (Revision 2025-11-01) are applicable to the Work of the Contract.
- C0.1.1 The *General Conditions for Construction* are available on the Information Connection page at The City of Winnipeg, Corporate Finance, Purchasing Division website at [http://www.winnipeg.ca/matmgt/gen\\_cond.stm](http://www.winnipeg.ca/matmgt/gen_cond.stm)
- C0.2 A reference in the Tender to a section, clause or subclause with the prefix “C” designates a section, clause or subclause in the *General Conditions for Construction*.

## **PART D - SUPPLEMENTAL CONDITIONS**

### **GENERAL**

#### **D1. GENERAL CONDITIONS**

D1.1 In addition to the General Conditions for Construction, these Supplemental Conditions are applicable to the Work of the Contract.

#### **D2. SCOPE OF WORK**

D2.1 The Work to be done under the Contract shall consist of three parts:

- (a) Part 1 – City Funded Work
- (b) Part 2 – Manitoba Hydro Funded Work
- (c) Part 3 – Third-Party Funded Work.

##### **Part 1 – City Funded Work**

D2.2 Part 1 – City Funded Work shall consist of:

- (a) Asphalt Reconstruction
  - (i) Chancellor Drive (north leg) from Markham Road to 1662 Chancellor Drive.
- (b) Pavement Rehabilitation
  - (i) Kings Drive from 30 m north of Seier Bay to Kilkenny Drive.
  - (ii) Kings Park Roads and Parking Lot.
  - (iii) La Porte Drive/ Rue Le Maire Alley.
  - (iv) Lamirande Place/ Dubois Place Alley.
- (c) Thin Bituminous Overlay (TBO)
  - (i) Carrigan Place from Ulster Street to end.
  - (ii) Peacock Place from Lake Grove Bay to end.
- (d) Asphalt Paths
  - (i) Kings Drive from Parkwood Place to Freedman Crescent.
- (e) Sidewalk Renewals
  - (i) Kirkbridge Drive from Tim Sale Drive to #630 Kirkbridge Drive.
  - (ii) Bairdmore Boulevard from Sandusky Drive to Kinlock Lane.
  - (iii) Leeds Avenue Cut-Thru from Baylor Avenue to Newcastle Road.
  - (iv) Killarney Avenue Cut-Thru from Magdalene Bay to Loyola Bay.
  - (v) Bryn Mawr Road Cut-Thru from Mount Allison Bay to Lafayette Bay.
  - (vi) Silverstone Avenue from Dalhousie Drive to Laval Drive.
  - (vii) Ryerson Cut-Thru from Rochester Avenue to Public Lane.
  - (viii) Tunis Bay Cut-Thru from Public Lane to Patricia Avenue.
- (f) Transit Stop Improvements
  - (i) Tim Sale Drive at Stan Bailie Drive/ Kirkbridge Drive.
  - (ii) Bairdmore Boulevard at Sandusky Drive.
  - (iii) Dalhousie Drive between Allegheny Drive and Silverstone Avenue.

### **Part 2 – Manitoba Hydro Funded Work**

D2.3 Part 2 – Manitoba Hydro Funded Work shall consist of:

- (a) Street Lighting and Associated Work
  - (i) Chancellor Drive (north leg) from Markham Road to 1662 Chancellor Drive

### **Part 3 – Third-Party Funded Work**

D2.4 Part 3 – Third Party Funded Work shall consist of:

- (a) Asphalt Paths
  - (i) Kings Park paths.

D2.5 The City currently has no approved funding in the Capital Budget for Parts 2 and 3 of the Work, but is anticipating receiving notification about funding for both prior to Commencement. Parts 2 and 3 of the Work is contingent upon the City receiving sufficient funding.

D2.5.1 Further to C7.1, if notice of sufficient funding is not received, the City shall have the right to eliminate all or any portion of Parts 2 and 3, and the Contract Price will be reduced accordingly.

D2.5.2 Further to C7.5, C7.5.1, and C7.6, a reduction in the Contract Price pursuant to D2.5.1 shall not be considered in calculating the aggregate reduction in the Contract Price for purposes of C7.5.

D2.5.3 If all or any portion of Parts 2 and 3 is eliminated pursuant to D2.5.1, the time periods stipulated in D19 for Substantial Performance of the Work and in D20 for Total Performance of the Work will be reduced proportionally by the Contract Administrator acting reasonably.

D2.6 The major components of the Work are as follows:

- (a) Asphalt Reconstruction
  - (i) Removal of Existing Pavement;
  - (ii) Excavation;
  - (iii) Manhole Repairs;
  - (iv) Installation of catch basins and leads;
  - (v) Watermain Service Insulation;
  - (vi) Compaction of sub-grade;
  - (vii) Installation of subdrains;
  - (viii) Placement of separation/ filtration geotextile fabric and Class A geogrid;
  - (ix) Hauling and placement of Granular B Recycled Concrete Aggregates;
  - (x) Placement of base course (Granular A) materials;
  - (xi) Adjustment of existing manholes and appurtenances;
  - (xii) Construct concrete barrier curb for asphalt pavement (180 mm height);
  - (xiii) Placement of asphalt pavement (Type MS1 (55 mm thick) and MS2 (70 mm thick));
  - (xiv) Renewal of concrete sidewalks; and
  - (xv) Topsoil and Sod
- (b) Pavement Rehabilitation
  - (i) Planing existing asphalt overlay (if applicable);
  - (ii) Full depth concrete repairs of existing joints and slabs;
  - (iii) Renewal of existing curbs;
  - (iv) Adjustment of existing catch basins, manholes, and other appurtenances;
  - (v) Catch basin lead repairs;
  - (vi) Placement of pavement repair fabric;

- (vii) Placement of asphalt overlay (Type MS1, thicknesses vary by location);
- (viii) Renewal of concrete sidewalks; and
- (ix) Topsoil and Sod.
- (c) Thin Bituminous Overlay (TBO)
  - (i) Full depth concrete repairs of existing joints and slabs;
  - (ii) Renewal of existing curbs;
  - (iii) Adjustment of existing catch basins, manholes, and other appurtenances;
  - (iv) Placement of asphalt overlay (Type MS1, average thickness 40 mm);
  - (v) Renewal of concrete sidewalks; and
  - (vi) Topsoil and Sod.
- (d) Asphalt Paths
  - (i) Removal of Existing Pavement;
  - (ii) Excavation;
  - (iii) Compaction of sub-grade;
  - (iv) Placement of separation/ filtration geotextile fabric and Class B geogrid;
  - (v) Placement of sub-base and base course (Granular A) materials;
  - (vi) Placement of asphalt pavement (Type MS1, thickness 75 mm- one lift); and
  - (vii) Topsoil and Sod.
- (e) Sidewalk Renewals
  - (i) Renewal of 100 mm concrete sidewalk; and
  - (ii) Topsoil and Sod.
- (f) Transit Stop Improvements
  - (i) Removal of existing concrete sidewalk;
  - (ii) Construction of 150 mm reinforced concrete sidewalk; and
  - (iii) Topsoil and Sod.
- (g) Street Lighting and Associated Work
  - (i) Removal of existing street lighting poles and bases;
  - (ii) Installation of concrete bases; and
  - (iii) Installation of new street lighting cables (trenching, boring, and/or overhead) and poles (including connections).

### **D3. CONTRACT ADMINISTRATOR**

D3.1 The Contract Administrator is Stantec Consulting, represented by:

Dylan Mourant  
Transportation Project Manager  
Telephone No. 204-489-5900  
Email Address dylan.mournat@stantec.com

D3.2 At the pre-construction meeting, Dylan Mourant will identify additional personnel representing the Contract Administrator and their respective roles and responsibilities for the Work.

### **D4. CONTRACTOR'S SUPERVISOR**

D4.1 At the pre-construction meeting, the Contractor shall identify their designated supervisor and any additional personnel representing the Contractor and their respective roles and responsibilities for the Work.

D4.2 At least two (2) Business Days prior to the commencement of any Work on the site, the Contractor shall provide the Contract Administrator with a phone number where the supervisor

identified in D4.1 or an alternate can be contacted twenty-four (24) hours a day to respond to an emergency.

#### **D5. FURNISHING OF DOCUMENTS**

D5.1 Upon award of the Contract, the Contractor will be provided with 'issued for construction' Contract Documents electronically, including Drawings in PDF format only.

#### **SUBMISSIONS**

#### **D6. AUTHORITY TO CARRY ON BUSINESS**

D6.1 The Contractor shall be in good standing under The Corporations Act (Manitoba), or properly registered under The Business Names Registration Act (Manitoba), or otherwise properly registered, licensed or permitted by law to carry on business in Manitoba, or if the Contractor does not carry on business in Manitoba, in the jurisdiction where the Contractor does carry on business, throughout the term of the Contract, and shall provide the Contract Administrator with evidence thereof upon request.

#### **D7. SAFE WORK PLAN**

D7.1 The Contractor shall provide the Contract Administrator with a Safe Work Plan at least five (5) Business Days prior to the commencement of any Work on the Site.

D7.2 The Safe Work Plan shall be prepared and submitted in the format shown in the City's template which is available on the Information Connection page at The City of Winnipeg, Corporate Finance, Purchasing Division website at <http://www.winnipeg.ca/matmgt/safety/default.stm>

D7.3 Notwithstanding B12.4 at any time during the term of the Contract, the City may, at their sole discretion and acting reasonably, require an updated COR Certificate or Annual Letter of good Standing. A Contractor, who fails to provide a satisfactory COR Certificate or Annual Letter of good Standing, will not be permitted to continue to perform any Work.

#### **D8. INSURANCE**

D8.1 The Contractor shall provide and maintain the insurance coverage during the performance of the work, unless indicated otherwise below:

- (a) commercial general liability insurance, in the amount of at least two million dollars (\$2,000,000.00) inclusive, with The City of Winnipeg, Manitoba Recreational Trails Association, its officers, directors, employees and agents are to be added as additional insureds, with a cross-liability clause, contractual liability, unlicensed motor vehicle liability (contractor's equipment), non-owned automobile liability and products and completed operations endorsement, to remain in place at all times during the performance of the Work and throughout the Warranty period. If required, the University of Manitoba is to be added as an additional insured.
- (b) if applicable, Automobile Liability Insurance covering all motor vehicles, owned and operated and used or to be used by the Contractor directly or indirectly in the performance of the Work. The Limit of Liability shall not be less than \$2,000,000 inclusive for loss or damage including personal injuries and death resulting from any one accident or occurrence;
- (c) all risks Installation Floater carrying adequate limits to cover all machinery, equipment, supplies and/or materials intended to enter into and form part of any installation.
- (d) Property insurance for all machinery and equipment, including field offices and portable toilets used by the contractors directly or indirectly in the performance of the work on the project that may be owned, rented, leased or borrowed.

D8.2 Deductibles shall be borne by the Contractor.

- D8.3 All policies shall be taken out with insurers licensed to carry on business in the Province of Manitoba.
- D8.4 All subcontractors performing work on the project shall provide the contractor with evidence of insurances as outlined in Section D8.1 (a) and (b) above and be registered with Workers Compensation Board of Manitoba. Such evidence to be maintained during the performance of the work. The Contractor shall provide the contract administrator with evidence of the same prior to the commencement of any work.
- D8.5 The Contractor shall provide:
- (a) The certificate of insurance, in a form satisfactory to the Supervisor of Insurance, to:  
  
The City of Winnipeg  
Risk Management  
Insurance Section  
185 King Street, 3<sup>rd</sup> Floor  
Winnipeg, MB R3B 1J1
  - (b) The Contract Administrator with a copy of the certificate of insurance.  
  
At least two (2) Business Days of notification of the award of the Contract prior to the commencement of any Work on the Site.
- D8.6 The Contractor shall not cancel, materially alter, or cause each policy to lapse without providing at least thirty (30) Calendar Days prior written notice to the Supervisor of Insurance.

## **D9. CONTRACT SECURITY**

- D9.1 The Contractor shall provide and maintain the performance bond and the labour and material payment bond until the expiration of the warranty period in the form of:
- (a) a performance bond of a company registered to conduct the business of a surety in Manitoba, in the amount of fifty percent (50%) of the Contract Price; and
  - (b) labour and material payment bond of a company registered to conduct the business of a surety in Manitoba, in an amount equal to fifty percent (50%) of the Contract Price.
- D9.1.1 Bonds are available at:
- (a) Performance Bond <https://www.winnipeg.ca/media/4928/>
    - (i) Performance Bond – Schedule A - Form of Notice  
<https://www.winnipeg.ca/media/4831/>
    - (ii) Performance Bond – Schedule B – Surety’s Acknowledgement  
<https://www.winnipeg.ca/media/4832/>
    - (iii) Performance Bond – Schedule C – Surety’s Position  
<https://www.winnipeg.ca/media/4833/>
  - (b) Labour & Material Payment Bond <https://www.winnipeg.ca/media/4930/>
    - (i) L&M Bond – Schedule A – Notice of Claim  
<https://www.winnipeg.ca/media/4834/>
    - (ii) L&M Bond – Schedule B – Acknowledgement of a Notice  
<https://www.winnipeg.ca/media/4835/>
    - (iii) L&M Bond – Schedule C – Surety’s Position  
<https://www.winnipeg.ca/media/4836/>
- D9.1.2 Where the contract security is a performance bond, it may be submitted in hard copy or digital format. If submitted in digital format the contract security must meet the following criteria:
- (a) the version submitted by the Contractor must have valid digital signatures and seals;

- (b) the version submitted by the Contractor must be verifiable by the City with respect to the totality and wholeness of the bond form, including: the content; all digital signatures and digital seals; with the surety company, or an approved verification service provider of the surety company.
- (c) the version submitted must be viewable, printable and storable in standard electronic file formats compatible with the City, and in a single file. Allowable formats include pdf.
- (d) the verification may be conducted by the City immediately or at any time during the life of the bond and at the discretion of the City with no requirement for passwords or fees.
- (e) the results of the verification must provide a clear, immediate and printable indication of pass or fail regarding D9.1(b).

D9.1.3 Digital bonds failing the verification process will not be considered to be valid and may be determined to be an event of default in accordance with C18.1. If a digital bond fails the verification process, the Contractor may provide a replacement bond (in hard copy or digital format) within seven (7) Calendar Days of the City's request or within such greater period of time as the City in their discretion, exercised reasonably, allows.

D9.1.4 Digital bonds passing the verification process will be treated as original and authentic.

D9.2 The Contractor shall provide:

- (a) the required Contract Security to:

The City of Winnipeg  
Legal Services Department  
185 King Street, 3<sup>rd</sup> Floor  
Winnipeg, MB R3B 1J1

- (b) The Contract Administrator with copies of the required Contract Security.

within seven (7) Calendar Days of notification of the award of the Contract and prior to the commencement of any Work on the Site.

D9.3 The Contractor shall, as soon as practicable after entering into a contract with a Subcontractor:

- (a) give the Subcontractor written notice of the existence of the labour and material payment bond in D9.1(b); and
- (b) post a notice of the bond and/or a copy of that bond in a conspicuous location at the Site of the Work.

## **D10. SUBCONTRACTOR LIST**

D10.1 The Contractor shall provide the Contract Administrator with a complete list of the Subcontractors whom the Contractor proposes to engage (Form J: Subcontractor List) at or prior to a pre-construction meeting, or at least two (2) Business Days prior to the commencement of any Work on the Site.

## **D11. DETAILED WORK SCHEDULE**

D11.1 The Contractor shall provide the Contract Administrator with a detailed work schedule at least two (2) Business Days prior to the commencement of any Work on the Site.

D11.2 If, prior to submitting the Detailed Work Schedule, the Contractor does not receive notification pursuant to D13.5 that all or some portion of Parts 2 and 3 of the Work may be commenced, they shall complete the Detailed Work Schedule for only Part 1 of the Work assuming that, if all of Part 2 and 3 is eliminated, the time periods stipulated in D19 for Substantial Performance of

the Work and in D20 for Total Performance of the Work will be reduced by ten (10) Working Days

- D11.3 If, after submitting the Detailed Work Schedule, the Contractor receives notification that all or any portion of Part 2 and 3 of the Work may be commenced, they shall submit a revised Detailed Work Schedule no later than two (2) Business Days from receipt of the notification
- D11.4 The detailed work schedule shall consist of the following:
- (a) a Gantt chart for the Work.  
acceptable to the Contract Administrator.
- D11.5 Further to D11.4(a), the Gantt chart shall show the time on a weekly basis, required to carry out the Work of each trade, or specification division. The time shall be on the horizontal axis, and the type of trade shall be on the vertical axis.

## **D12. REQUIREMENTS FOR SITE ACCESSIBILITY PLAN**

- D12.1 The Contractor shall provide the Contract Administrator with an Accessibility Plan at least five (5) Business Days prior to the commencement of any Work on the Site.
- D12.2 The Accessibility Plan shall demonstrate how the Contractor will accommodate the safe passage of pedestrians and cyclists in accordance with the Manual of Temporary Traffic Control, the Contract Drawings, Staging Plans, and Streets By-Law No. 1481/77 at all times for the duration of the Construction. Unless noted in the Contract, the Accessibility Plan must include a written plan for the following:
- (a) How the Contractor will maintain at least one crossing in each direction for each intersection (one north/south crosswalk and one east/west crosswalk).
  - (b) How the Contractor will maintain access to bus stops within the site.
  - (c) How the Contractor will maintain access to pedestrian corridors and half signals.
  - (d) How the Contractor will maintain cycling facilities.
  - (e) How the Contractor will maintain access to residents and businesses unless otherwise noted in the Contract.
  - (f) Any required detour signage at adjacent crossings to facilitate sidewalk or active transportation pathway closures.
- D12.3 The Accessibility Plan may also include figures, sketches, or drawings to demonstrate the proposed plan.
- D12.4 The Accessibility Plan shall include written details on how the Contractor intends to review, maintain, and document all items related to the Accessibility Plan on-site during Construction, including, but not limited to:
- (a) Signage
  - (b) Temporary Ramping
  - (c) Transit Stops
  - (d) Detour Signage
- D12.5 At minimum, the Contractor shall review the site conditions on a daily basis to ensure that all features related to the Accessibility Plan are in place. The site review is intended to correct deficiencies as a result of unforeseen events such as wind, traffic, or the general public. Deficiencies that are direct result of the Contractors actions must be corrected immediately.
- D12.6 Any changes to the Accessibility Plan must be approved by the Contract Administrator.
- D12.7 Upon request from the Contract Administrator, the Contractor shall provide records demonstrating that the site has been maintained.

- D12.8 Deficiencies as a direct result of actions by the Contractor that are not immediately corrected and/or failure to produce records that demonstrate that the site was maintained in compliance with the Accessibility Plan may result in a pay adjustment via the monthly Progress Payment. The rate of pay adjustment will be as per the following schedule:
- (a) First Offence – A warning will be issued and documented in the weekly or bi-weekly site meeting.
  - (b) Second Offence – A field instruction to immediately correct the site will be issued by the Contract Administrator.
  - (c) Third and subsequent Offences – A pay reduction will be issued in the amount of \$250.00 per instance and per day.

## **SCHEDULE OF WORK**

### **D13. COMMENCEMENT**

- D13.1 The Contractor shall not commence any Work until they are in receipt of an award letter from the Award Authority authorizing the commencement of the Work.
- D13.2 The Contractor shall not commence any Work on the Site until:
- (a) the Contract Administrator has confirmed receipt and approval of:
    - (i) evidence of authority to carry on business specified in D6;
    - (ii) evidence of the workers compensation coverage specified in C6.17;
    - (iii) the twenty-four (24) hour emergency response phone number specified in D4.2.
    - (iv) the Safe Work Plan specified in D7;
    - (v) evidence of the insurance specified in D8;
    - (vi) evidence of the contract security specified in D8.1;
    - (vii) the subcontractor list specified in D10;
    - (viii) the detailed work schedule specified in D11;
    - (ix) the Requirements for Site Accessibility Plan specified in D11.1; and
    - (x) the direct deposit application form specified in C12.20.
  - (b) the Contractor has attended a pre-construction meeting with the Contract Administrator, or the Contract Administrator has waived the requirement for a pre-construction meeting.
- D13.3 The Contractor shall not commence the Work on the Site before June 8, 2026, and shall commence the Work on Site no later than June 12, 2026, as directed by the Contract Administrator and weather permitting.
- D13.4 The Contractor shall not commence work within Kings Park (Kings Park Road, parking lot, or the Asphalt Paths until August 10, 2026.
- D13.5 The Contractor shall not commence Part 2 or Part 3 of the Work as described in D2 and identified in Form B: Prices, unless they have received notification from the Contract Administrator that the City has received notice of sufficient funding from the Province.
- D13.6 The City intends to award this Contract by May 22, 2026.

### **D14. WORKING DAYS**

- D14.1 Further to C1.1(xx);
- D14.1.1 The Contract Administrator will determine daily if a Working Day has elapsed and will record their assessment. On a weekly basis the Contract Administrator will provide the Contractor with a record of the Working Days assessed for the preceding week. The Contractor shall sign each report signifying that they agree with the Contract Administrator's determination of the Working Days assessed for the report period.

D14.1.2 Work done to restore the Site to a condition suitable for Work, shall not be considered “work” as defined in the definition of a Working Day.

D14.1.3 When the Work includes two or more major types of Work that can be performed under different atmospheric conditions, the Contract Administrator shall consider all major types of Work in determining whether the Contractor was able to work in assessing Working Days.

#### **D15. RESTRICTED WORK HOURS**

D15.1 Further to 3.10 of CW 1130, the Contractor shall require written permission forty-eight (48) hours in advance from the Contract Administrator for any work to be performed between 2000 hours and 0700 hours, or on Saturdays, Sundays, Statutory Holidays and or Civic Holidays.

#### **D16. WORK BY OTHERS**

D16.1 Further to C6.26, the Contractor’s attention is directed to the fact that other Contractors, the personnel of Utilities and the staff of the City may be working within the project limit, approach roadway, adjacent roadways or right-of-way. The activities of these agencies may coincide with the Contractors execution of work and it will be the Contractor’s responsibility to cooperate to the fullest extent with other personnel working in the area, and such cooperation is an obligation of the Contractor under the terms of Contract.

D16.2 Work by others on or near the Site will include but not necessarily be limited to:

- (a) Manitoba Hydro – as required;
- (b) Manitoba Hydro, Gas Division – relocation and/ or lowering/ rock wrapping of underground main and services as required;
- (c) City of Winnipeg Parks and Open Space Division staff will be present at Kings Park during construction.
- (d) Bell/MTS, Rogers– adjustments to plant as required;
- (e) City of Winnipeg Traffic Services - installation of new traffic signage and line painting; and
- (f) City of Winnipeg Geomatics Branch – various work on survey infrastructure.

D16.3 Further to D16.1 the Contractor shall cooperate and coordinate all activities with all parties performing required Work by Others. The Contractor must include and accommodate Work by Others identified in D16.2 or additional parties, in their construction schedule as per D11 and accommodate the necessary area on Site required for the Work by Others to complete the Work.

#### **D17. SEQUENCE OF WORK**

D17.1 Further to C6.1, the sequence of work shall comply with the following:

D17.1.1 Providing that the Work on each street is completed in a similar order to the order that the Work was commenced in, the Contractor will be permitted to have a maximum of three (3) streets under construction at any one time. Completion of a street means that all of the necessary concrete, asphalt including approaches and landscaping Work is completed to the satisfaction of the Contract Administrator.

D17.1.2 Where the Contractor utilizes two (2) or more crews that work independently on the same major component of the Work as identified in D2, the Contract Administrator may approve an increase to the maximum number of streets under construction at any time.

D17.1.3 Placing the topsoil and finished grading of all boulevard and median areas shall be completed prior to commencing construction of asphaltic concrete overlays, including scratch courses.

D17.1.4 The staging of all streets shall be in accordance with the Traffic Staging and Signage Figures included in E1.4.

**D18. CRITICAL STAGES**

D18.1 The Contractor shall achieve critical stages of the Work in accordance with the following requirements:

(a) Kings Drive from the south side of Silverstone Avenue to Freedman Crescent shall be completed, including topsoil and sod, prior to August 31, 2026.

D18.2 When the Contractor considers the Work associated with the critical stages to be completed, the Contractor shall arrange, attend and assist in the inspection of the Work with the Contract Administrator for purposes of verifying Completion. Any defects or deficiencies in the Work noted during that inspection shall be remedied by the Contractor at the earliest possible instance and the Contract Administrator notified so that the Work can be re-inspected.

D18.3 The date on which the critical stages Work has been accepted by the Contract Administrator as being completed to the requirements of the Contract is the date on which completion of the critical stages has been achieved.

**D19. SUBSTANTIAL PERFORMANCE**

D19.1 The Contractor shall achieve Substantial Performance within seventy (70) consecutive Working Days of the commencement of the Work as specified in D13.

D19.2 When the Contractor considers the Work to be substantially performed, the Contractor shall arrange, attend and assist in the inspection of the Work with the Contract Administrator for purposes of verifying Substantial Performance. Any defects or deficiencies in the Work noted during that inspection shall be remedied by the Contractor at the earliest possible instance and the Contract Administrator notified so that the Work can be re-inspected.

D19.3 The date on which the Work has been certified by the Contract Administrator as being substantially performed to the requirements of the Contract through the issue of a certificate of Substantial Performance is the date on which Substantial Performance has been achieved.

**D20. TOTAL PERFORMANCE**

D20.1 The Contractor shall achieve Total Performance within seventy five (75) consecutive Working Days of the commencement of the Work as specified in D13.

D20.2 When the Contractor or the Contract Administrator considers the Work to be totally performed, the Contractor shall arrange, attend and assist in the inspection of the Work with the Contract Administrator for purposes of verifying Total Performance. Any defects or deficiencies in the Work noted during that inspection shall be remedied by the Contractor at the earliest possible instance and the Contract Administrator notified so that the Work can be re-inspected.

D20.3 The date on which the Work has been certified by the Contract Administrator as being totally performed to the requirements of the Contract through the issue of a certificate of Total Performance is the date on which Total Performance has been achieved.

**D21. LIQUIDATED DAMAGES**

D21.1 If the Contractor fails to achieve Critical Stages, Substantial Performance or Total Performance in accordance with the Contract by the days fixed herein for same, the Contractor shall pay the City the following amounts per Working Day for each and every Working Day following the days fixed herein for same during which such failure continues:

(a) Critical Stage D18.1(a) – three thousand five hundred dollars (\$3,500);

(b) Substantial Performance – three thousand five hundred dollars (\$3,500);

(c) Total Performance – one thousand eight hundred dollars (\$1,800).

D21.2 The amounts specified for liquidated damages in D21.1 are based on a genuine pre-estimate of the City's losses in the event that the Contractor does not achieve critical stages, Substantial Performance or Total Performance by the days fixed herein for same.

D21.3 The City may reduce any payment to the Contractor by the amount of any liquidated damages assessed.

## **D22. SCHEDULED MAINTENANCE**

D22.1 The Contractor shall perform the following scheduled maintenance in the manner and within the time periods required by the Specifications:

(a) Sod maintenance as specified in CW 3510; and

(b) Reflective crack maintenance during the warranty period as specified in CW 3250.

D22.2 Determination of Substantial Performance and Total Performance shall be exclusive of scheduled maintenance identified herein. All scheduled maintenance shall be completed prior to the expiration of the warranty period. Where the scheduled maintenance cannot be completed during the warranty period, the warranty period shall be extended for such period of time as it takes the Contractor to complete the scheduled maintenance.

## **CONTROL OF WORK**

### **D23. JOB MEETINGS**

D23.1 Regular weekly job meetings will be held at the Site. These meetings shall be attended by a minimum of one representative of the Contract Administrator, one representative of the City and one representative of the Contractor. Each representative shall be a responsible person capable of expressing the position of the Contract Administrator, the City and the Contractor respectively on any matter discussed at the meeting including the Work schedule and the need to make any revisions to the Work schedule. The progress of the Work will be reviewed at each of these meetings.

D23.2 The Contract Administrator reserves the right to cancel any job meeting or call additional job meetings whenever they deem it necessary.

### **D24. PRIME CONTRACTOR – THE WORKPLACE SAFETY AND HEALTH ACT (MANITOBA)**

D24.1 Further to C6.27, the Contractor shall be the Prime Contractor and shall serve as, and have the duties of the Prime Contractor in accordance with The Workplace Safety and Health Act (Manitoba).

### **D25. THE WORKPLACE SAFETY AND HEALTH ACT (MANITOBA) – QUALIFICATIONS**

D25.1 Further to B12.4, the Contractor/Subcontractor must, throughout the term of the Contract, have a Workplace Safety and Health Program meeting the requirements of The Workplace Safety and Health Act (Manitoba). At any time during the term of the Contract, the City may, at their sole discretion and acting reasonably, require updated proof of compliance, as set out in B12.4.

## **PAYMENT**

### **D26. FUEL PRICE ADJUSTMENT**

D26.1 The Contract is subject to a fuel price adjustment which will be calculated monthly based on eligible Work completed utilizing the following mathematical formulas;

(a) where the price of fuel has increased -  $((CFI/BFI)-1.15) \times Q \times FF$ ; and

(b) where the price of fuel has decreased -  $((CFI/BFI)-0.85) \times Q \times FF$ ; where

- (i) BFI = base fuel index
- (ii) CFI = current fuel index
- (iii) FF = fuel factor
- (iv) Q = monetary value of Work applied in the calculation.

D26.1.1 Eligible Work will be determined in accordance with D26.5.

D26.1.2 The base fuel index (BFI) will be the retail price of fuel identified on the Submission Deadline based on latest published "Monthly average retail prices for gasoline and fuel by geography" for Winnipeg, published by [Statistics Canada, Table 18-10-0001-01](#). The BFI is a blended rate based on 15% regular unleaded gasoline at self-service filling stations and 85% diesel fuel at self-service filling stations.

D26.1.3 The current fuel index (CFI) based on the above blended rate will be determined for each monthly progress estimate and applied on the following progress estimate as a change order once rates are published by Statistics Canada.

D26.1.4 A Fuel Factor (FF) rate of the monetary value of all eligible Work completed that month based on the Contract unit prices will be used to calculate the assumed apportioned cost of fuel.

D26.2 Fuel cost adjustments may result in additional payment to the Contractor or credit to the City within the Contract by way of a monthly change order.

D26.3 The fuel escalation or de-escalation adjustment will not be applied if the CFI is within  $\pm 15\%$  of the BFI.

D26.4 Fuel escalation adjustments will not be considered beyond the Substantial Performance/Critical Stages except where those dates/Working Days are adjusted by change order. Fuel de-escalation adjustments will apply for Work that extends beyond the dates/Working Days specified for Substantial Performance/Critical Stages.

D26.5 The Fuel Factor (FF) rates will be set as follows:

- (a) The Fuel Factor rate shall be set at 2.7% of the monetary value of all Work based on unit prices.

## WARRANTY

### D27. WARRANTY

D27.1 Notwithstanding C13.2, the warranty period shall begin on the date of Total Performance and shall expire one (1) years thereafter for pavement rehabilitation, thin bituminous overlay (TBO), asphalt paths, sidewalk renewals and transit top improvement locations as listed in D2, and two (2) years thereafter for asphalt reconstruction works, unless extended pursuant to C13.2.1 or C13.2.2, in which case it shall expire when provided for thereunder.

D27.2 Notwithstanding C13.2 or D27.1, the Contract Administrator may permit the warranty period for a portion or portions of the Work to begin prior to the date of Total Performance if:

- (a) a portion of the Work cannot be completed because of unseasonable weather or other conditions reasonably beyond the control of the Contractor but that portion does not prevent the balance of the Work from being put to its intended use.

D27.2.1 In such case the date specified by the Contract Administrator for the warranty period to begin shall be substituted for the date specified in C13.2 for the warranty period to begin.

## INDEMNITY

### D28. INDEMNITY

D28.1 Indemnity shall be as stated in C17.

## THIRD PARTY FUNDING

### D29. FUNDING FROM THE MANITOBA RECREATIONAL TRAILS ASSOCIATION INC.

- D29.1 A portion of the funding for the Work of the Contract is being provided by The Manitoba Recreational Trails Association Inc. ("MRTA"). As such, C24 of the General Conditions for Construction is replaced by the following terms and conditions.
- D29.2 In addition to the indemnity obligations outlined in C17, the Contractor agrees to indemnify and save harmless MRTA and its officers, directors, employees and agents from and against all claims, liabilities, and demands of any kind with respect to an injury to persons (including, without limitation, death) damage or loss to or destruction of property, economic loss or infringement of rights caused by or arising directly or indirectly from:
- (i) the Work or the Contract;
  - (ii) the performance of the Contract or the breach of any terms or condition of the Contract by the Contractor or its directors, officers, employees or agents; and
  - (iii) any omission or wilful or negligent act of the Contractor or its directors, officers, employees or agents.
- D29.3 The Contractor agrees that in no event will MRTA its respective officers, servants, employees or agents be held liable for any damages in contract, tort (including negligence) or otherwise, for:
- (a) any injury to any Person, including, but not limited to, death, economic loss or infringement of rights;
  - (b) any damage to or loss or destruction of property of any Person; or
  - (c) any obligation of any Person, including, but not limited to, any obligation arising from a loan, capital lease or other long-term obligation; in relation to this Contract or the Work.
- D29.4 The Contractor shall maintain and preserve accurate and complete records in respect of this Contract and the Work, including all accounting records, financial documents, copies of contracts with other parties and other records relating to this Contract and the Work during the term of the Contract and for at least seven (7) years after Total Performance. Those records bearing original signatures or professional seals or stamps must be preserved in paper form; other records may be retained in electronic form. The Contractor shall permit the City of Winnipeg and MRTA to monitor the Work during the term. In addition to the record keeping and inspection obligations outlined in C6, the Contractor shall keep available for inspection and audit at all reasonable times while this Contract is in effect and until at least seven (7) years after Total Performance, all records, documents, and contracts referred to in this D29.4 for inspection, copying and audit by the City of Winnipeg, and the MRTA and their respective representatives and auditors, and to produce them on demand; to provide reasonable facilities for such inspections, copying and audits, to provide copies of and extracts from such records, documents, or contracts upon request by the City of Winnipeg, the MRTA and their respective representatives and auditors, and to promptly provide such other information and explanations as may be reasonably requested by the City of Winnipeg, and/or the MRTA from time-to-time.
- D29.5 The Contractor consents to the City providing a copy of the Contract Documents to the MRTA upon request.
- D29.6 The Contractor shall comply with all applicable legislation and standards, whether federal, provincial, or municipal, including (without limitation) labour, environmental, and human rights laws, in the course of providing the Work.

- D29.7 The Contractor shall properly account for the Work provided under this Contract and payment received in this respect, prepared in accordance with generally accepted accounting principles in effect in Canada, including those principles and standards approved or recommended from time-to-time by the Chartered Professional Accountants of Canada or the Public Sector Accounting Board, as applicable, applied on a consistent basis.
- D29.8 The Contractor represents and warrants that no current or former public servant or public office holder, to whom the Value and Ethics Code for the Public Sector, the Policy on Conflict of Interest and Post Employment, or the Conflict of Interest Act applies, shall derive direct benefit from this Contract, including any employment, payments, or gifts, unless the provision or receipt of such benefits is in compliance with such codes and the legislation.
- D29.9 The Manitoba Recreational Trails Association Inc., and its officers, directors, employees, and agents shall be added as additional insureds with respect to the insurance policies named in D8.1(a) in respect to the activities performed under this Contract.

**FORM J: SUBCONTRACTOR LIST**  
 (See D10)

2026 LOCAL STREET RENEWAL PROGRAM- CHANCELLOR DRIVE, KINGS DRIVE, AND VARIOUS  
 OTHER LOCATIONS

<u>Portion of the Work</u>	<u>Name</u>	<u>Address</u>
<b>Supply of Materials</b>		
Concrete		
Asphalt		
Base Course		
Sub-Base Material		
Paving Stones		
Sod		
Catchbasins		
Pavement Repair Fabric		
Separation/ Filtration Fabric		
Class A Geogrid		
Frames & Covers		
Drainage Pipe		
<b>Installation/Placement</b>		
Concrete		
Asphalt		
Excavation		
Base Course		
Sub-Base Material		
Paving Stones		
Catchbasin and CB Lead Installation		
Sewer Televising		
Tree Removals		
Landscaping		
<b>OTHERS</b>		

## PART E - SPECIFICATIONS

### GENERAL

#### E1. APPLICABLE SPECIFICATIONS AND DRAWINGS

- E1.1 These Specifications shall apply to the Work.
- E1.2 *The City of Winnipeg Standard Construction Specifications* in their entirety, whether or not specifically listed on Form B: Prices, shall apply to the Work.
- E1.2.1 *The City of Winnipeg Standard Construction Specifications* is available on the Information Connection page at The City of Winnipeg, Corporate Finance, Purchasing Division website at <http://www.winnipeg.ca/matmgt/Spec/Default.stm>
- E1.2.2 The version in effect three (3) Business Days before the Submission Deadline shall apply.
- E1.2.3 Further to C2.4(d), Specifications included in the Tender shall govern over *The City of Winnipeg Standard Construction Specifications*.
- E1.3 Bidders are reminded that requests for approval of substitutes as an approved equal or an approved alternative shall be made in accordance with B6. In every instance where a brand name or design specification is used, the City will also consider approved equals and/or approved alternatives in accordance with B6.
- E1.4 The following are applicable to the Work:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>	<u>Drawing (Original) Sheet Size</u>
1	Cover Sheet- Location Plan & Drawing List	A1
2	Peacock Place, Paving and Grading, Lake Grove Bay to East Limit	A1
3	Chancellor Drive, Horizontal Geometry, Sta 0+450 to Sta 0+750	A1
4	Chancellor Drive, Horizontal Geometry, Sta 0+750 to Markham Rd	A1
5	Chancellor Drive, Paving and Grading, Sta 0+450 to Sta 0+580	A1
6	Chancellor Drive, Paving and Grading, Sta 0+580 to Sta 0+700	A1
7	Chancellor Drive, Paving and Grading, Sta 0+700 to Sta 0+820	A1
8	Chancellor Drive, Paving and Grading, Sta 0+820 to Sta 0+930	A1
9	Chancellor Drive, Paving and Grading, Sta 0+930 to Markham Rd	A1
10	Carrigan Place, Paving and Grading, West Limit to Ulster St	A1
11	Lamirande Place Alley, Paving and Grading, Nolan Ave to Sta 0+230	A1
12	Lamirande Place Alley, Paving and Grading, Sta 0+230 to Sta 0+350	A1
13	Lamirande Place Alley, Paving and Grading, Sta 0+350 to Champagne Cr	A1
14	Dubois Pl/ Champagne Cr Alley, Paving and Grading, Lamirande Pl Alley to Champagne Dr	A1

<u>Drawing No.</u>	<u>Drawing Name/Title</u>	<u>Drawing (Original) Sheet Size</u>
15	Le Maire Street Alley, Paving and Grading, Le Maire Street to Sta 0+120	A1
16	Le Maire Street Alley, Paving and Grading, Sta 0+120 to Sta 0+250	A1
17	Le Maire Street Alley, Paving and Grading, Sta 0+250 to Sta 0+380	A1
18	Le Maire Street Alley, Paving and Grading, Sta 0+380 to Sta 0+500	A1
19	Le Maire Street Alley, Paving and Grading, Sta 0+500 to Le Maire Street	A1
20	Ducharme Avenue, Paving and Grading, West Limit to Rue Le Maire	A1
21	Kings Drive, Paving and Grading, Sta 0+090 to Sta 0+240	A1
22	Kings Drive, Paving and Grading, Sta 0+240 to Sta 0+360	A1
23	Kings Drive, Paving and Grading, Sta 0+360 to Sta 0+480	A1
24	Kings Drive, Paving and Grading, Sta 0+480 to Sta 0+600	A1
25	Kings Drive, Paving and Grading, Sta 0+600 to Sta 0+730	A1
26	Kings Drive, Paving and Grading, Sta 0+730 to Freedman Cr	A1
27	Kings Park, Site Plan	A1
28	Kings Park Road, Paving and Grading, Sta 0+980 to Sta 1+110	A1
29	Kings Park Road, Paving and Grading, Sta 1+110 to Sta 1+220	A1
30	Kings Park Road, Paving and Grading, Sta 1+220 to Sta 1+320	A1
31	Kings Park Road, Paving and Grading, Sta 1+320 to Sta 1+450	A1
32	Kings Park Pathway, Horizontal Geometry, Sta 1+000 to Sta 1+340	A1
33	Kings Park Pathway, Horizontal Geometry, Sta 1+340 to Sta 1+490	A1
34	Kings Park Pathway, Paving and Grading, Sta 1+000 to Sta 1+130	A1
35	Kings Park Pathway, Paving and Grading, Sta 1+130 to Sta 1+250	A1
36	Kings Park Pathway, Paving and Grading, Sta 1+250 to Sta 1+360	A1
37	Kings Park Pathway, Paving and Grading, Sta 1+360 to Sta 1+490	A1
38	Transit Stop Improvements- Tim Sale Drive @ Stan Bailie Drive/ Kirkbridge Drive	A1
39	Transit Stop Improvements- Bairdmore Boulevard @ Sandusky Drive	A1
40	Transit Stop Improvements- Dalhousie Drive between Allegheny Drive & Silverstone Avenue	A1
41	Sidewalk Renewals- Various Locations	A1

<u>Drawing No.</u>	<u>Drawing Name/Title</u>	<u>Drawing (Original) Sheet Size</u>
Figure 1	Traffic Staging & Signage- Drawing List, Legend and General Notes	11" x 17"
Figure 2	Traffic Staging & Signage- Peacock Place	11" x 17"
Figure 3	Traffic Staging & Signage- Chancellor Drive – Stage 1	11" x 17"
Figure 4	Traffic Staging & Signage- Chancellor Drive – Stage 2	11" x 17"
Figure 5	Traffic Staging & Signage- Carrigan Place	11" x 17"
Figure 6	Traffic Staging & Signage- Lamirande Place – Stage 1	11" x 17"
Figure 7	Traffic Staging & Signage- Lamirande Place – Stage 2	11" x 17"
Figure 8	Traffic Staging & Signage- Le Maire Street – Stage 1	11" x 17"
Figure 9	Traffic Staging & Signage- Le Maire Street – Stage 2	11" x 17"
Figure 10	Traffic Staging & Signage- Kings Drive – Stage 1A	11" x 17"
Figure 11	Traffic Staging & Signage- Kings Drive – Stage 1B	11" x 17"
Figure 12	Traffic Staging & Signage- Kings Drive – Stage 2A	11" x 17"
Figure 13	Traffic Staging & Signage- Kings Drive – Stage 2B	11" x 17"

## **E2. MOBILIZATION AND DEMOBILIZATION PAYMENT**

### DESCRIPTION

- E2.1 This Specification shall cover all operations relating to the mobilization and demobilization of the Contractor to the project location(s).
- E2.2 The Work to be done by the Contractor under this Specification shall include the furnishing of all superintendence, overhead, labour, materials, equipment, tools, supplies, and all things necessary for and incidental to the satisfactory performance and completion of all Works as hereinafter specified.
- E2.3 The inclusion of a payment item for the Work under this Specification shall not release or reduce the responsibilities of the Contractor under any other specification in this Contract.

### SCOPE OF WORK

- E2.4 Further to C12 of the General Conditions, where Mobilization and Demobilization is included as a bid item, it shall consist of the following, as applicable:
- (a) Mobilization shall include, but not be limited to:
- (i) All activities and associated costs for transportation of the Contractor's personnel, equipment, and operating supplies to the site, and/or sites, and/or between sites;
  - (ii) Establishment of offices, buildings, other necessary general facilities and equipment parking/staging areas for the Contractor's operations at the site or sites;
  - (iii) Premiums paid for performance and payment bonds including coinsurance and reinsurance agreements as applicable;

- (iv) General cleanup and housekeeping needed maintain a neat and orderly project site(s);
- (v) Other job related items.
- (b) Demobilization shall include, but not be limited to:
  - (i) All activities and costs for transportation of personnel, equipment, and supplies not used in the project from the site, and/or sites, and/or between sites;
  - (ii) Disassembly, removal, and site cleanup and restoration of offices, buildings, and other facilities assembled on the site and/or sites;
  - (iii) Repair of access roads, temporary haul roads, and equipment parking areas leaving the project site in the same or better condition than at the start of the project;
  - (iv) General cleanup and housekeeping needed to restore a neat and orderly project site.

E2.5 Access to the site, equipment parking, and staging areas are limited to that shown on the drawings or as approved by the Contract Administrator.

#### MEASUREMENT AND PAYMENT

E2.6 The lump-sum price for the Mobilization and Demobilization bid item shall not exceed five percent (5.00%) of the total bid price for the Contract.

E2.6.1 Further to B9, B17, C12 and E2.6, should the lump sum price exceed 5% of the Total Bid Price the lump sum price will be reduced to 5% of the Total Bid Price, the Total Bid Price will be determined using the reduced lump sum price and payment will be based on the reduced lump sum price.

E2.7 Payment for Mobilization:

- (a) 60% of the lump-sum price will be paid to the contractor for Mobilization on the first Progress Estimate for the Contract.

E2.8 Payment for Demobilization:

- (a) The remaining 40% of the lump-sum price will be paid upon:
  - (i) Restoration of the site and/or sites to the satisfaction of the Contract Administrator;
  - (ii) Distribution of the Declaration of Total Performance.

E2.9 Pay Reduction for Accessibility Plan

- (a) The Demobilization payment will be reduced by the number of pay adjustments incurred in accordance with D11.1 and as determined by the Contract Administrator.

E2.10 Mobilization and Demobilization will be paid only once (to a maximum of 100%), regardless of the number of times the Contractor mobilizes to the site and/or sites.

### **E3. GEOTECHNICAL REPORT**

E3.1 Further to C3.1, the geotechnical report is provided to aid the Contractor's evaluation of the pavement structure and/or existing soil conditions. The geotechnical report is contained in Appendix 'A'.

### **E4. PROTECTION OF EXISTING TREES**

E4.1 The Contractor shall take the following precautionary steps to prevent damage from construction activities to existing boulevard trees within the limits of the construction area:

- (a) The Contractor shall not stockpile materials and soil or park vehicles and equipment on boulevards within 2 metres of trees.
- (b) Trees identified to be at risk by the Contract Administrator are to be strapped with 25 x 100 x 2400mm wood planks, or suitably protected as approved by the Contract Administrator.

- (c) Excavation shall be performed in a manner that minimizes damage to the existing root systems. Where possible, excavation shall be carried out such that the edge of the excavation shall be a minimum of 1.5 times the diameter (measured in inches), with the outcome read in feet, from the closest edge of the trunk. Where roots must be cut to facilitate excavation, they shall be pruned neatly at the face of excavation.
- (d) Operation of equipment within the dripline of the trees shall be kept to the minimum required to perform the work required. Equipment shall not be parked, repaired, refuelled; construction materials shall not be stored, and earth materials shall not be stockpiled within the driplines of trees. The dripline of a tree shall be considered to be the ground surface directly beneath the tips of its outermost branches. The Contractor shall ensure that the operations do not cause flooding or sediment deposition on areas where trees are located.
- (e) Work on-site shall be carried out in such a manner so as to minimize damage to existing tree branches. Where damage to branches does occur, they shall be neatly pruned.
- (f) Tree preservation and protection of existing trees or shrubs on University of Manitoba property shall follow the Specification included in Appendix "K".

E4.2 All damage to existing trees caused by the Contractor's activities shall be repaired to the requirements and satisfaction of the Contract Administrator and the City Forester or their designate.

E4.3 No separate measurement or payment will be made for the protection of trees.

E4.4 Except as required in E4.1(c) and E4.1(e), Elm trees shall not be pruned at any time between April 1 and July 31.

## **E5. TRAFFIC CONTROL**

E5.1 Further to 3.6, 3.7 and 3.8 of CW 1130:

- (a) Where directed by the Contract Administrator, the Contractor shall construct and maintain temporary asphalt ramps to alleviate vertical pavement obstructions such as manholes and planing drop-offs to the satisfaction of the Contract Administrator. Payment shall be in accordance with CW3410.
- (b) In accordance with the Manual of Temporary Traffic Control on City Streets (MTTC), the Contractor ("Construction Agency" in the Manual) shall be responsible for placing, maintaining and removing the appropriate temporary traffic control devices as specified by the MTTC, the Contract Drawings, Staging Plans and Traffic Management Plans or by the Traffic Management Branch of the City of Winnipeg Public Works Department. The Contractor shall bear all costs associated with the placement of temporary traffic control devices by their own forces or Subcontractor.
- (c) In addition, the Contractor shall be responsible for **supplying**, removing, placing and maintaining all regulatory signing including but not limited to:
  - (i) Parking restrictions;
  - (ii) Stopping restrictions;
  - (iii) Turn restrictions;
  - (iv) Diamond lane removal;
  - (v) Full or directional closures on a Regional Street;
  - (vi) Traffic routed across a median;
  - (vii) Full or directional closure of a non-regional street where there is a requirement for regulatory signs (turn restrictions, bus stop relocations, etc.) to implement the closure.
- (d) The Contractor shall remove and stockpile any regulatory signage not required during construction such as, but not limited to, parking restrictions, turn restrictions and loading restrictions.

- E5.2 Upon request from the Contract Administrator, the Contractor shall provide records demonstrating that the site has been maintained.
- E5.3 Further to E5.1(c) and E5.1(d) the Contractor shall make arrangements with the Traffic Services Branch of the City of Winnipeg to reinstall the permanent regulatory signs after the Contract Work is complete. The Contractor shall make arrangements to drop off the stockpiled materials to Traffic Services at 495 Archibald Street.
- E5.4 Any changes to the approved Traffic Management Plan must be submitted to the Contract Administrator a minimum of five (5) Working Days prior to the required change for approval.
- E5.5 If the Contract Administrator determines that the Contractor is not performing Traffic Control in accordance with this specification, Traffic Services may be engaged to perform the Traffic Control. In this event the Contractor shall bear costs charged to the project by the Traffic Services Branch of the City of Winnipeg in connection with the required Works.

## **E6. TRAFFIC MANAGEMENT**

- E6.1 Further to 3.7 of CW 1130:
- (a) Single lane closures on intersecting and/or adjoining Regional Streets shall only be permitted during non-peak periods when required for construction activities when approved by the Traffic Management Branch. Storage/parking of materials, equipment or vehicles is not permitted on Regional Streets at any time unless approved by the Contract Administrator, in consultation with the Traffic Management Branch.
- E6.1.1 The Contractor shall schedule construction activities to meet the traffic staging/ signage plans provided in E1.4.
- E6.1.2 **Sidewalk Renewals and Transit Stop Improvements:** lane closures for these streets to be temporary lane closures unless approved by Contract Administrator. No lane closures are permitted when there is no activity:
- E6.1.3 Should the Contractor be unable to maintain an existing access to a residence or business, they shall review the planned disruption with the business or residence and the Contract Administrator, and take reasonable measures to minimize the impact. The Contractor shall provide a minimum of 24 hours notification to the affected residence or business and the Contract Administrator, prior to disruption of access.
- E6.1.4 Pedestrian and ambulance/emergency vehicle access must be maintained at all times.
- E6.1.5 The following shall apply to streets with existing asphalt pavement structures (not including asphalt overlays):
- (a) Planing of existing asphalt pavement shall not commence until all proposed curb and gutter renewals, concrete sidewalk renewals, and concrete approach work has been completed.
- (b) The Contractor shall limit the use of his trucks to tandem size or smaller (ie. No large semi-trailers) on these streets unless otherwise agreed to by the Contract Administrator.

## **E7. REFUSE AND RECYCLING COLLECTION**

- E7.1 While access to refuse and/or recycling collection vehicles is restricted, on collection day(s) the Contractor shall move all of the affected property owners refuse and/or recycling materials to a nearby common area, prior to an established time, in accordance with E7.2 to permit the normal collection vehicles to collect the materials. Immediately following recycling collection the Contractor shall return recycling receptacles to the addresses marked on the receptacles.
- E7.2 Collection Schedule:

**Chancellor Drive (including Osgoode Place and Salem Place).**

*Collection Day(s):* **Wednesday B**

*Collection Time:* **06:00 to 18:00**

*Common Collection Area:* **Front street pickup. Contractor to relocate bins on collection day to an agreed upon safe collection point or allow access for the trucks to collect.**

**Kings Drive (including Seier Bay and Parkwood Place).**

*Collection Day(s):* **Wednesday B**

*Collection Time:* **06:00 to 18:00**

*Common Collection Area:* **Front street pickup. Contractor to relocate bins on collection day to an agreed upon safe collection point or allow access for the trucks to collect.**

**La Porte/ Le Maire Alley (addresses on La Porte Dr and Rue le Maire).**

*Collection Day(s):* **Wednesday B**

*Collection Time:* **06:00 to 18:00**

*Common Collection Area:* **Backlane pickup. Contractor to relocate bins on collection day to an agreed upon safe collection point or allow access for the trucks to collect.**

**Lamirande/ Dubois Alley (addresses on Nolan Pl, Lamirande Pl, Champagne Cr, Dubois Pl).**

*Collection Day(s):* **Wednesday B**

*Collection Time:* **06:00 to 18:00**

*Common Collection Area:* **Backlane pickup. Contractor to relocate bins on collection day to an agreed upon safe collection point or allow access for the trucks to collect.**

**Peacock.**

*Collection Day(s):* **Wednesday B**

*Collection Time:* **06:00 to 18:00**

*Common Collection Area:* **Front street pickup. Contractor to relocate bins on collection day to an agreed upon safe collection point or allow access for the trucks to collect.**

E7.3 No measurement or payment will be made for the work associated with this specification.

**E8. PEDESTRIAN SAFETY**

E8.1 During the project, a temporary snow fence shall be installed at the location listed below. The Contractor shall be responsible for maintaining the snow fence in a proper working condition. No measurement for payment shall be made for this work.

- (a) Around any open excavations adjacent to pedestrian facilities;
- (b) At existing trees and shrubs on University of Manitoba property in accordance with E4.1(f); and
- (c) In Kings Park to separate the construction from the park as shown on the Drawings.

**E9. WATER OBTAINED FROM THE CITY**

E9.1 Further to 3.7 of CW 1120, the Contractor shall pay for all costs, including sewer charges, associated with obtaining water from the City in accordance with the Waterworks and Sewer By-laws.

## **E10. SURFACE RESTORATIONS**

E10.1 Further to 3.3 of CW 1130, when Total Performance is not achieved in the year the Contract is commenced, the Contractor shall temporarily repair any Work commenced and not completed to the satisfaction of the Contract Administrator. The Contractor shall maintain the temporary repairs in a safe condition as determined by the Contract Administrator until permanent repairs are completed. The Contractor shall bear all costs associated with temporary repairs and their maintenance.

## **E11. INFRASTRUCTURE SIGNS**

E11.1 The Contractor shall obtain infrastructure signs from the Traffic Services Sign Shop at 495 Archibald Street. The Contractor shall mount each sign securely to a rigid backing material approved by the Contract Administrator. The Contractor shall fasten each sign to a suitable support and erect and maintain one sign at each street as directed by the Contract Administrator. When the Contract Administrator considers the Work on the street complete, the Contractor shall remove and dispose of the signs and supports. No measurement for payment will be made for performing all operations herein described and all other items incidental to the work described

## **TECHNICAL**

### **E12. ASPHALT PAVEMENT SPECIAL PROVISIONS**

E12.1 The asphalt pavement Special Provisions found in Appendix "B" apply to the Work.

### **E13. CITY OF WINNIPEG REVISED STANDARD DETAILS**

E13.1 The City of Winnipeg Revised Standard Details found in Appendix "C" supersede previous versions and apply to the Work.

### **E14. SIDEWALK EXPANSION JOINTS**

#### DESCRIPTION

E14.1 Further to CW 3325 - R5, CW 3235-R9 and CW 3310-R19, this specification covers the supply and installation of expansion joints to be constructed within concrete sidewalk.

E14.2 Referenced Standard Details

(a) SD-228D Sidewalk Expansion Joints (Appendix C)

#### MATERIALS

E14.3 Use only those materials listed as Approved Products for Surface Works. The Approved Products are available in Adobe Acrobat (.pdf) format at the City of Winnipeg, Corporate Finance, Material Management Internet site at:  
[https://legacy.winnipeg.ca/finance/findata/matmgt/std\\_const\\_spec/current/Docs/Approved\\_Product\\_Surface\\_Works.pdf](https://legacy.winnipeg.ca/finance/findata/matmgt/std_const_spec/current/Docs/Approved_Product_Surface_Works.pdf)

E14.4 Expansion Joint Filler

(a) Sidewalk expansion joints shall be a closed-cell expansion joint filler.

E14.5 Reinforcing Steel

(a) 300mm long 10M dowels. Dowel bars shall be plain round bars of grade 300 or better in accordance with CSA G40.21. Epoxy coating shall meet the requirements of ASTM Standard A934/A934M, Standard Specification for Epoxy-Coated Prefabricated Steel Reinforcing Bars.

- (b) The dowels shall be placed half depth of the sidewalk and aligned parallel to the centreline and surface of the slab with a maximum allowable tolerance of  $\pm 5$  mm. The dowels shall be positioned sufficiently rigid so the dowels are held in alignment within the specified tolerance, both horizontally and vertically, until the concrete placing and setting cycle is complete.
- (c) All areas of the dowel bar with damaged epoxy coating shall be cleaned and painted to the satisfaction of the Contract Administrator.
- (d) All dowels shall be thoroughly coated with a thin uniform coating of bond breaker or lubricant such as oil, grease, or synthetic materials to prevent bonding with the concrete for the length of the dowel. The bond breaker coating shall be smooth and free of voids.

#### CONSTRUCTION METHODS

- E14.6 Install sidewalk expansion joints as detailed in SD-228D Sidewalk Expansion Joints.
- E14.7 Expansion joints shall be constructed and installed as indicated in the Contract Documents or directed by the Contract Administrator.
- E14.8 The fiber joint filler shall extend the full width and depth of the sidewalk. Any excess material shall be trimmed to match the surface of the concrete.
- E14.9 Dowels shall be placed at 0.45m O/C spacing. Three dowels shall be installed at each expansion joint no closer than 0.15m from edge of concrete. If dowels are displaced during concrete placing operations, concrete placement shall cease and shall not resume until the displaced dowels have been reset to the true design position.
- E14.10 Once dowels are in position, they shall be inspected and approved by the Contract Administrator before any concrete is placed. Otherwise the concrete will be rejected by the Contract Administrator and shall be removed by the Contractor at his own expense.
- E14.11 Expansion joints shall be installed every 15 meters when constructing new or renewing existing sidewalk. If sidewalk is constructed during cold weather concreting period, expansion joints shall be installed every 12 meters. Expansion joints shall not be installed when renewing less than 15m of sidewalk.
- E14.12 Where the Drawings call for a new slab to be tied into an existing slab along a transverse joint, the Contractor shall construct an expansion joint and install dowels into the existing slab in accordance with Clause 6.3.2., CW 3310. Following installation of dowels, the ends of the dowels that extend into the new area shall be completely coated with a thin uniform coating of approved bond breaker or lubricant.
- E14.13 When replacing heaved panels in an existing sidewalk, expansion joints shall be installed on both ends of the replaced panels.
- E14.14 Expansion joints shall not be installed when constructing monolithic curb and sidewalk.
- E14.15 Expansion joints shall be installed when installing separate concrete splash strip.

#### MEASUREMENT AND PAYMENT

- E14.16 No payment shall be made for supplying all materials and for performing all operations herein described and all other items incidental to the Work included in this Specification

### **E15. HAULING AND PLACEMENT OF GRANULAR B RECYCLED CONCRETE AGGREGATE**

#### DESCRIPTION

- E15.1 General

- E15.1.1 This Specification covers the hauling from a designated supplier and installation of 100 mm Granular B Recycled Concrete Aggregate.
- E15.1.2 Referenced Standard Construction Specifications:  
(a) (a) CW 3110 – Sub-Grade, Sub-Base and Base Course Construction

#### MATERIALS

- E15.2 Materials will be provided to the Contractor in accordance with Tender 103-2025.

#### HAULING OF MATERIAL

- E15.3 The Contractor shall obtain the 100 mm Granular B Recycled Concrete Aggregate from a stockpile location within the limits of the City of Winnipeg.
- E15.4 The Customer will place orders before 4:00p.m. for each Business Day for the expected supply requirements for the following Business Day.
- E15.5 The material will be available for pick up between the following hours:  
(a) 0700 to 1800 from Monday to Friday  
(b) 0700 to 1400 on Saturday
- E15.6 Further to E15.5, material will not be available for pick up on general holidays in Manitoba.
- E15.7 Requests for pick-up outside of these hours will must be made a minimum of four (4) Business Days in advance to the Contract Administrator.
- E15.8 The Contractor will be provided use of the scale at the pick-up site to facilitate tare and gross vehicles weights. A printed ticket will be provided for each load.
- E15.9 The supplier shall load the material into the Contractors truck/truck trailer and shall facilitate unloading when a truck has been overloaded.

#### CONSTRUCTION METHODS

- E15.10 Construction methods will be in accordance with CW 3110.

#### QUALITY ASSURANCE TESTING

- E15.11 Quality Assurance Testing for physical properties as per CW 3110 will not be required. Field Density Testing will be required as per CW 3110.

#### MEASUREMENT AND PAYMENT

- E15.12 The hauling, placing and compaction of sub-base material will be measured on a weight basis and paid for at the Contract Unit Price per tonne for the “Hauling and Placing Sub-base Material” listed here below. The weight to be paid for will be the total number of tonnes of sub base material supplied, placed and compacted in accordance with this Specification, accepted and measured by the Contract Administrator.

#### Items of Work:

- (a) 100 mm Granular B Recycled Concrete
- E15.13 The weight to be paid for will the total number of tonnes of sub-base material as measured on a certified weight scale.
- E15.14 Only material placed within the limits of excavation will be included in the payment for the “Items of Work” listed for sub-base material.
- E15.15 No measurement or payment will be made for materials rejected by the Contract Administrator.

## **E16. TREE AND SHRUB REMOVAL**

### DESCRIPTION

- E16.1 This specification shall cover the removal of existing trees or shrubs and the pruning of existing trees.
- E16.1.1 Pruning of existing trees is required for the Killarney Avenue Cut Thru sidewalk renewal.
- E16.2 The Work to be done by the Contractor under this specification shall include the furnishing of all superintendence, overhead, labour, materials, equipment, tools, supplies and all things necessary for and incidental to the satisfactory performance and completion of all Work as hereinafter specified.
- E16.3 All work associated with this Specification shall be completed by an individual who has obtained accreditation from the Manitoba Arborists Training and Examination Program or the International Society of Arboriculture Arborist Certification Program (ISA).

### CONSTRUCTION METHODS

- E16.4 Tree and Shrub Removal
- E16.4.1 Prior to commencement of the Work the Contract Administrator shall identify all trees for removal. The Contractor shall cut down only trees designated to be removed and grub out all stumps and roots greater than 100 mm diameter to 400 mm below finished grade.
- E16.4.2 In general, the Contractor shall start at the top of the tree and remove branches or trunks not longer than 2 m. Trees are to be felled so as to land within the limits of the Works. The Contractor shall load and haul all trees, stumps, roots, logs, brush, rubbish and all other surface litter from the Site and dispose of these materials at an approved disposal Site, acceptable to the Contract Administrator.
- E16.4.3 Trees designated for removal from University of Manitoba property shall be mulched on-site and delivered to the dedicated stockpile area at the Environmental Safety Building located in Smartpark at 27 Service 2 Street SW.
- E16.4.4 The Contractor shall take all precautions to prevent damage to structures, adjacent property and to trees and shrubs. In the event of damage, the Contractor will be held liable and shall be required to provide appropriate restoration at their cost, to the satisfaction of the Contract Administrator.
- E16.5 Pruning Existing Trees
- E16.5.1 Prune horizontal and vertical within the limits of construction to ensure construction equipment can be operated without interfering with trees to remain.
- E16.5.2 Prune as required to remove dead, broken or damaged limbs.
- E16.5.3 Prune back to healthy growth while maintaining balanced crown shape.
- E16.5.4 Employ clean sharp tools.
- E16.5.5 Make cuts smooth and flush with outer edge of branch collar near the main stem or branch.
- E16.5.6 Cuts must be smooth and sloping to prevent accumulation of water on cut.
- E16.5.7 Do not leave little stumps ("horns") on trunks or main branches.
- E16.5.8 Prune according to accepted horticultural practices as outline in "The Pruning Manual", Publication No. 1505-1977 by Agriculture Canada
- E16.6 MEASUREMENT AND PAYMENT
- E16.7 Tree and Shrub Removal

E16.7.1 Removal of Trees will be measured on a unit basis and paid for at the Contract Unit Price for the "Tree Removal", which price shall be payment in full for removing and disposing all tree materials and for completing all operations herein described and all other items incidental to the work included in this Specification.

E16.8 Pruning Existing Trees and Shrubs

E16.8.1 Pruning existing trees and shrubs will not be measured and will be paid for at the Contract Lump Sum Price for "Tree Trimming" which shall be payment in full for performing all items described in this Specification.

## **E17. KINGS PARK SITE FURNISHINGS**

### DESCRIPTION

E17.1 This Specification shall cover the removal and disposal of existing waste receptacles and signage, removal and storage of existing Tache benches for reinstallation, the supply and installation of a waste receptacles, and the reinstallation of existing Tache benches.

### MATERIALS

E17.2 Waste receptacles (Standard Construction Detail SCD-119-R2 and SCD-119-R5) shall be acquired from the City of Winnipeg PWD Central manufacturing facility.

Contact for Waste Receptacles:

City of Winnipeg

Public Works Department

960 Thomas Avenue

Winnipeg, MB R2L 2E1

Email: [pwd-cps-orderdesk@winnipeg.ca](mailto:pwd-cps-orderdesk@winnipeg.ca)

E17.3 Reinstallation of the existing Tache bench shall conform to Standard Construction Detail SCD-121A-R5.

E17.4 All fasteners, anchors, and incidental materials required for installation shall be supplied by the Contractor and shall be suitable for the intended application.

### CONSTRUCTION METHODS

E17.5 The Contractor shall remove and dispose of existing waste receptacles at the locations indicated on the Drawings or as directed by the Contract Administrator.

E17.6 The Contractor shall remove and dispose of existing signage, including posts, foundations and associated hardware at the locations indicated on the Drawings or as directed by the Contract Administrator.

E17.7 Commemorative plaques on existing Tache benches will be removed by Parks staff prior to bench removal by the Contractor. The Contractor shall carefully remove the existing Tache benches designated for reuse and store it in a secure location to prevent damage until reinstallation.

E17.8 The Contractor shall pickup and install new waste receptacles in accordance with SCD-119-R2 or SCD-119-R5 at the locations shown on the Drawings or as directed by the Contract Administrator.

E17.9 The Contractor shall reinstall the salvaged Tache benches in accordance with SCD-121A at the location shown on the Drawings or as directed by the Contract Administrator.

- E17.10 All materials removed and not designated for salvage shall become the property of the Contractor and shall be disposed of off-site.

#### MEASUREMENT AND PAYMENT

- E17.11 Removal and disposal of existing waste receptacles shall be measured on a unit basis and paid for at the Contract Unit Price for "Remove and Dispose of Existing Waste Receptacles". The number to be paid for will be the total number of waste receptacles removed and disposed of in accordance with this Specification, accepted and measured by the Contract Administrator.
- E17.12 Removal and disposal of existing signage shall be measured on a unit basis and paid for at the Contract Unit Price for "Remove and Dispose of Existing Signage". The number to be paid for will be the total number of signs removed and disposed of in accordance with this Specification, accepted and measured by the Contract Administrator.
- E17.13 Removal and storage of existing Tache benches for reinstallation shall be measured on a unit basis and paid for at the Contract Unit Price for "Remove and Store Existing Tache Bench for Reinstallation". The number to be paid for will be the total number of benches removed and stored in accordance with this Specification, accepted and measured by the Contract Administrator.
- E17.14 Installation of waste receptacles shall be measured on a unit basis and paid for at the Contract Unit Price for "Supply and Install Waste Receptacle (SCD-119-R2)" or "Supply and Install Waste Receptacle (SCD-119-R5)". The number to be paid for will be the total number of waste receptacles supplied and installed in accordance with this Specification, accepted and measured by the Contract Administrator.
- E17.15 Reinstallation of existing Tache benches shall be measured on a unit basis and paid for at the Contract Unit Price for "Reinstall Existing Tache Benches (SCD-121A)". The number to be paid for will be the total number of benches reinstalled in accordance with this Specification, accepted and measured by the Contract Administrator.

### **E18. REMOVAL OF INTERLOCKING PAVING STONES**

#### DESCRIPTION

- E18.1 This Specification shall cover the removal, salvaging and/or disposal of existing interlocking concrete paving stones.

#### CONSTRUCTION METHODS

- E18.2 The Contractor shall carefully remove existing interlocking paving stones in areas indicated on the Drawings or as directed by the Contract Administrator.
- E18.3 Pavers designated to be removed from University of Manitoba property are to be stacked in an orderly manner by the Contractor on pallets provided by the University. The University will pickup the pallets from the site for storage.
- E18.4 Broken, damaged, or unsuitable paving stones shall be removed and disposed of off-site.

#### MEASUREMENT AND PAYMENT

- E18.5 Removal of existing interlocking paving stones shall be measured on an area basis and paid for at the Contract Unit Price for "Remove Interlocking Paving Stones". The area to be paid for will be the total number of square metres of interlocking paving stones removed in accordance with this Specification, accepted and measured by the Contract Administrator.

### **E19. PRECAST CONCRETE PARKING CURBS**

#### DESCRIPTION

- E19.1 This Specification shall cover the removal, salvaging and reinstalling of existing concrete parking curbs as well as the supply and installation of new concrete parking curbs.

#### MATERIALS

- E19.2 New concrete parking curbs shall be precast concrete parking curbs with dimensions 2438 x 203 x 140 mm
- E19.3 Tiebars shall be 600 mm long 15M bars.

#### CONSTRUCTION METHODS

- E19.4 The Contractor shall carefully remove and salvage existing precast concrete parking curbs to allow proposed construction.
- E19.5 The Contractor shall reinstall the precast concrete parking curbs with two (2) new tie-bars driven through each curb into the underlying ground.
- E19.6 Where precast concrete parking curbs are, in the opinion of the Contract Administrator, not salvageable, the Contractor shall remove and dispose of the existing parking curb and replace it with a new one.

#### MEASUREMENT AND PAYMENT

- E19.7 Removal, Salvaging and Reinstallation of existing precast concrete parking curbs shall be measured on a unit basis and paid for at the Contract Unit Price for "Remove, Salvage and Reinstall Existing Parking Curbs". The number to be paid for will be the total number of existing parking curbs removed, salvaged and reinstalled in accordance with this Specification, accepted and measured by the Contract Administrator.
- E19.8 Supply and Installation of new precast concrete parking curbs shall be measured on a unit basis and paid for at the Contract Unit Price for "Supply and Install New Parking Curbs". The number to be paid for will be the total number of precast concrete parking curbs supplied and installed in accordance with this Specification, accepted and measured by the Contract Administrator.

### **E20. CURBS FOR ASPHALT PAVEMENT**

#### DESCRIPTION

- E20.1 This Specification covers the construction of curbs for asphalt pavement.
- E20.2 The following Referenced Standard Details are provided in Appendix "C":
- (a) SD-200A – Barrier Curb for Asphalt Pavement
  - (b) SD-202F – Lip Curb with Integral Approach for Asphalt Pavement
  - (c) SD-203C – Modified Barrier Curb for Asphalt Pavement
  - (d) SD-229F – Curb Ramp for Asphalt Pavement

#### CONSTRUCTION METHODS

- E20.3 Further to CW 3310, the Contractor shall construct barrier curb, modified barrier curb and curb ramps for asphalt pavement as per the Standard Details listed in E20.2.
- (a) Drill holes into the sub-base as shown on the Standard Details with a drilling diameter of no more than 2 mm greater than the diameter of the tie bar.
  - (b) Provide a minimum of 40 mm cover between reinforcing steel and the finished concrete surface.
  - (c) Transverse joints will be saw cut every 3.0 meters. Transverse joints are to be saw cut to a maximum depth of 25mm, so as to not saw cut into the 10M longitudinal deformed bars and 19.1mm dowels.

- E20.4 Place concrete utilizing slip-form paving equipment in accordance with CW 3310 unless otherwise directed by the Contract Administrator.
- E20.5 Place and compact 50mm sub-base material as backfill behind barrier curb for asphalt pavement within excavated area approximately 150mm deep or as directed by the Contract Administrator. Place and compact suitable site material as backfill behind barrier curb to allow for 100mm of topsoil and sod below top of barrier curb. Care must be taken so as to not disturb the new barrier curb for asphalt pavement during placing and compaction of 50mm sub-base material and suitable site material.

#### MEASUREMENT AND PAYMENT

- E20.6 Construction of Barrier Curb for Asphalt Pavement shall be measured on a length basis and paid for at the Contract Unit Price per metre for the "Items of Work" listed here below. The length to be paid for shall be the total number of meters supplied and installed in accordance with this Specification, accepted and measured by the Contract Administrator:

##### Items of Work:

- (a) Construction of Type 2 Concrete Barrier Curb for Asphalt Pavement (100-150 mm reveal ht), Slip Form Paving.
  - (b) Construction of Type 2 Concrete Lip Curb for Asphalt Pavement (40 mm reveal ht).
  - (c) Construction of Type 2 Concrete Modified Barrier Curb for Asphalt Pavement (150 mm reveal ht).
  - (d) Construction of Type 2 Concrete Curb Ramp for Asphalt Pavement (8-12mm reveal ht).
- E20.7 The supply and installation of 20M tie-bars, 10M longitudinal deformed bars and 19.1mm dowels is incidental to "Construction of Barrier Curb for Asphalt Pavement", and "Construction of Modified Barrier Curb for Asphalt".

### **E21. SUPPLY AND INSTALL WATERMAIN AND WATER SERVICE INSULATION**

#### DESCRIPTION

- E21.1 Notwithstanding 3.12 of CW 2110, this specification covers the supply and installation of insulation in roadway excavations over watermains and water services.
- E21.2 Referenced Standard Construction Specifications
- (a) CW 2030 – Excavation Bedding and Backfill
  - (b) CW 3110 – Sub –grade, Sub-base and Base Course Construction
- E21.3 Referenced Standard Details
- (a) SD-018 - Watermain and Water Service Insulation

#### MATERIALS

- E21.4 Acceptable insulation is:
- (a) Extruded Polystyrene rigid foam insulation – Type 4, 4" in thickness.
    - DOW - Roofmate or Highload 40
    - Owen's Corning - Foamular 350 or Foamular 400.
    - 2" X 48" X 96", 2" X 24" X 96", 4" X 24" X 96"
- E21.5 Sand Bedding:
- (a) In accordance with CW 2030

## CONSTRUCTION METHODS

- E21.6 Prior to the installation of any sub-base material or geotextile material, locate all existing water services. Further to SD-018, where directed by the Contract Administrator, excavate the sub-grade to allow the top of the insulation to be installed flush with the surrounding sub-grade. Install the insulation on a level surface centered over the located watermain or water service for the full width of the roadway excavation. Install sand bedding if required to level the surface. Stockpile and dispose of excavated material in accordance with CW 3110.
- E21.7 Thickness of insulation is 100 mm ( 4"). If using 50 mm ( 2") panels 2 layers are required. Total width of insulation to be as directed by the Contract Administrator. Place sufficient full width panels to meet or exceed the specified width.
- E21.8 Place insulation panels adjacent to each other over the specified area with no gaps between panels and less than 15mm of elevation difference along the adjoined edges. Where 2" thick panels are being used, offset the top layer to prevent the panel joints from aligning with the joints in the lower layer.
- E21.9 Use full panels of insulation where possible. Where necessary cut insulation panels to obtain coverage to specified lengths. Insulation pieces shall be a minimum of dimension of 300 mm in width or length.
- E21.10 Take appropriate measures to ensure panels are not displaced when installing geotextiles and during backfilling operations.

## MEASUREMENT AND PAYMENT

- E21.11 Watermain and Water Service Insulation shall be measured on an area basis and paid for at the Contract Unit Price per square metre of "Watermain and Water Service Insulation". The area to be paid for shall be the total square meters of watermain and water service insulation supplied and installed in accordance with this specification, accepted and measured by the Contract Administrator.
- (a) Excavation of the roadway subgrade in accordance with E21.6 will not be measured for payment and will be included in the payment for "Watermain and Water Service Insulation".

## **E22. STUMP GRINDING**

### DESCRIPTION

- E22.1 This Specification shall cover the grinding of existing tree stumps shown on the drawings and as directed by the Contract Administrator. The work to be done under this Specification shall include the furnishing of all superintendence, overhead, labour, materials, equipment, tools, supplies, and all things necessary and incidental to the satisfactory performance and complete of all Work as specified. This Specification supplements CW 3010.

### CONSTRUCTION METHODS

- E22.2 The Contractor shall grind tree stumps to a minimum of 300mm below finished grade of the concrete sidewalk or boulevard. Finished grade shall be determined by the Contract Administrator
- E22.3 The Contractor shall remove and/or dispose of all material resulting from the Work immediately by removing to a landfill site.

### MEASUREMENT AND PAYMENT

- E22.4 Stump grinding will be measured on a unit basis and paid for at the Contract Unit Price for "Stump Grinding". The number to be paid for will be the total number of existing tree stumps removed and disposed of in accordance with this Specification, accepted and measured by the Contract Administrator.

## **E23. PARKING LOT LINE PAINTING**

### DESCRIPTION

E23.1 This Specification shall cover the supply and application of pavement line markings for parking stalls within the parking lot areas shown on the Drawings or as directed by the Contract Administrator.

### E23.2 MATERIALS

#### E23.3 Traffic Paint

E23.3.1 Paint for pavement markings shall be traffic line paint suitable for asphalt pavements.

E23.3.2 Paint shall be quick-drying and suitable for application by spray equipment.

E23.3.3 Parking stall lines shall be white in colour unless otherwise indicated on the Drawings.

E23.3.4 All paint materials shall be supplied by the Contractor.

### CONSTRUCTION METHODS

E23.4 The Contractor shall ensure that pavement surfaces to receive line markings are clean, dry, and free of dust, debris, oil, and other foreign materials prior to application of paint.

E23.5 The Contractor shall apply pavement line markings in accordance with the dimensions and layout shown on the Drawings or as directed by the Contract Administrator. Parking stall lines shall be 100 mm in width unless otherwise indicated on the Drawings

E23.6 Parking stall lines shall be applied using spray equipment capable of producing straight, uniform lines with clean edges.

E23.7 The Contractor shall protect freshly painted markings from traffic and damage until the paint has adequately dried.

### MEASUREMENT AND PAYMENT

E23.8 Parking lot line painting shall be measured on a linear metre basis and paid for at the Contract Unit Price for "Line Painting". The length to be paid for will be the total number of linear metres of pavement markings applied in accordance with this Specification, accepted and measured by the Contract Administrator.

## **E24. MANITOBA HYDRO GAS INFORMATION**

E24.1 While working in close proximity to Manitoba Hydro gas infrastructure, all procedures and precautions outlined in Appendix 'J' as well as any supplemental direction from Manitoba Hydro must be adhered to. Ensure that all locates and clearances are current and have been received and understood prior to construction.

E24.2 Any costs associated with the provision of Safety Watches for Manitoba Hydro gas infrastructure will be considered incidental to the Work and no payment will be made.

## **E25. INSTALLATION OF STREET LIGHTING AND ASSOCIATED WORKS**

### E25.1 DEFINITIONS

LIMITS OF APPROACH means the shortest distance that is permissible between live high voltage (>750 volts) conductors or apparatus and any part of a worker's body, material or tools being handled, or equipment operated.

MANITOBA HYDRO CENTRAL STORES means Manitoba Hydro's Waverley Service and Reclaim Centre - 1840 Chevrier Blvd - Winnipeg, Manitoba

OVERHEAD FEED means an electrical supply via an overhead conductor connected between streetlight standards. Typically strung between standards on a temporary basis.

OVERHEAD SOURCE means an electrical supply from Manitoba Hydro's system. (Typically, an overhead conductor from a wooden distribution pole or a DIP/RISER located on a wooden distribution pole.)

RECLAIM material means existing material that has been removed from Manitoba Hydro's system and to be returned to Manitoba Hydro.

SCRAP material means existing material that has been removed from Manitoba Hydro's system and to be recycled/disposed of by the Contractor.

SURPLUS material means new material that has been requisitioned by the Contractor and not incorporated into the work at the end of the Contract.

WORK CLEARANCE means an ELECTRICAL AND/OR NATURAL GAS FACILITIES LOCATE form (see SAMPLE ONLY included as Appendix "G") issued by each of Manitoba Hydro's Customer Service Centre (CSC) affected to permit work to commence (Permit to work).

## E25.2 DESCRIPTION

E25.2.1 The work shall consist of the supply of all supervision, labour, materials (except as indicated under MATERIAL SUPPLIED BY MANITOBA HYDRO below) insurance, tools, backfill and equipment (and their maintenance), transportation, fuel, oil, meals and lodging, mobilization and de-mobilization, and warranty of workmanship as required to install and remove temporary Overhead Feeds, remove existing street light poles as required, install new street light poles and associated underground cables/conduits, all in accordance with the requirements specified in the tender documents.

## E25.3 WORK LOCATIONS

E25.3.1 The proposed street light installation and removals are shown on construction drawings and are as follows:

(a) Chancellor Drive (north leg) from Markham Road to 1662 Chancellor Drive.

## E25.4 COORDINATION OF WORK

E25.4.1 The Contractor shall provide a minimum of ten (10) working days notice to Manitoba Hydro prior to the start of construction. The work shall be conducted and coordinated with Manitoba Hydro in a manner to ensure street lighting is maintained at all times for the duration of the work. The construction drawings provide the Proposed Sequence of Construction.

E25.4.2 The Contractor shall obtain Work Clearance from Manitoba Hydro's Customer Service Centre(s) (CSC) affected prior to the work commencing. No additional compensation shall be paid to the Contractor for delays obtaining Work Clearance for any reason.

E25.4.3 Manitoba Hydro's CSC will provide the Limits of Approach applicable to the Contractor on the Work Clearance form.

## E25.5 ORIENTATION

E25.5.1 Prior to the commencement of the proposed work, the Contractor's crew foremen, electricians, and other key personnel shall attend one (1) day of orientation provided by Manitoba Hydro for various operations such as cable handling, cable splicing/termination, installation of street light poles, concrete bases, luminaires and various other construction standards and procedures. The Contractor will be responsible for all costs associated with personnel salaries, travel, sustenance and overheads, etc., during training.

## E25.6 PRE-CONSTRUCTION MEETING

- E25.6.1 Prior to the commencement of the work, the Contractor shall attend a pre-construction meeting with Manitoba Hydro. The agenda for this meeting shall include but not be limited to the following:
- (a) Reference the Contractor's Safe work Procedures;
  - (b) Prime Contractor;
  - (c) materials;
  - (d) sequence of construction;
  - (e) communication plan;
  - (f) any training requirements & qualifications;
  - (g) Drawing and Project review;
  - (h) a review of the Contractor's proposed work schedule; and
  - (i) any and all other topics of clarification that the Contractor and the Contract Administrator may wish to discuss.

- E25.6.2 The Contractor's cost to attend this pre-construction meeting shall be incorporated into the unit prices for the work.

#### E25.7 QUALIFICATIONS AND CERTIFICATION

- E25.7.1 The Contractor's Crew Foreman, installers and other key Contractor's Personnel shall possess the necessary certification, licensing, training, experience and familiarity with safety rules, procedures and hazards relating to the work. Journeyman Power Line Technician (PLT), Journeyman Lineman, Journeyman Cableman or Journeyman Electricians shall be required to perform portions of this work.

- E25.7.2 Journeyman Power Line Technician (PLT), Journeyman Cableman and Journeyman Lineman are also required to possess a "Limited Specialized Trade Licence – 'M-P' Licence – Power Line" issued by the Province of Manitoba.

- E25.7.3 Office of the Fire Commissioner Bulletin OFC 18 – 002 dated May 23, 2018 regarding Electrician Licenses discusses the requirements for a "Limited Specialized Trade Licence – 'M-P' Licence – Power Line".

For more information contact:  
Office of the Fire Commissioner  
500-401 York Avenue  
Winnipeg, Manitoba R3C 0P8  
Tel. 204-945-3373  
Fax 204-948-2089  
Toll Free: 1-800-282-8069  
[firecomm@gov.mb.ca](mailto:firecomm@gov.mb.ca)

- E25.7.4 Licensed Journeyman Electricians or Journeyman PLT or Journeyman Cableman or Journeyman Lineman ARE REQUIRED for all cable handling operations included but not limited to: disconnecting cables in the handhole, installation and removal of temporary overhead feeds, installation and connection of ground rods, streetlight cable splices, termination of streetlight cables in handholds and at luminaires. The Contractor shall employ sufficient qualified personnel on its crews to conform to the Electrician's Licensing Act. The Contractor shall be prepared to provide proof of licences to Manitoba Hydro upon request.

- E25.7.5 The Contractor shall assess the hazards associated with the work and have documented Safe work Procedures to perform the work. It is the Contractor's responsibility to train employees on these procedures. The Contractor shall be prepared to provide proof of training to Manitoba Hydro upon request.

#### E25.8 REFERENCED STANDARD CONSTRUCTION SPECIFICATIONS

E25.8.1 In addition to these Specifications, the work to be performed by the Contractor relative to the installation and/or replacement of street lighting poles, concrete bases and associated cabling shall be in accordance with the following:

- (a) Manitoba Hydro 66kV and Below Standards;
- (b) CSA C22.3 No. 7 (latest edition);
- (c) Canadian Electrical Code (CEC) Part 1 (latest edition); and
- (d) Any other applicable codes
- (e) (collectively, the "Standards")

E25.8.2 Revisions and updates to the Manitoba Hydro 66kV and Below Standards are issued periodically and the latest issued version of the Standard will apply. For the convenience of the Contractor for bidding purposes, excerpts of the Manitoba Hydro 66kV and Below Standards have been included as Appendix "D".

E25.8.3 In some cases, Municipal, Provincial or Federal laws or this Technical Specification may be more stringent than the CSA Standards. Whenever conflict exists, the Contractor shall comply with the most stringent requirements applicable at the place of the work.

#### E25.9 TOOLS, EQUIPMENT AND MATERIALS

E25.9.1 The Contractor shall be required to provide all tools and equipment required for performing the specified tasks. Equipment shall be in good operating condition, shall be properly maintained using original equipment manufacturer replacement parts and shall be provided with letters of testing/inspection from the manufacturer when requested. Where the equipment is provided as a kit with multiple parts and tools, the kit shall be complete with all parts required to perform the designed task. Contractor fabricated tools or equipment will not be accepted for use.

E25.9.2 The Contractor shall obtain the following specific Electrical Equipment including but not limited to:

- (a) Compression tool or tools and associated dies to perform compressions to a maximum size of 1/0 Al (MD-6 compression tools shall not be used).
- (b) Approved compression tools are:

Manufacture	Type	Model No.	Range
Burndy	In-line, battery	PATMD68-14V	350 Kcmil AL
Cembre	In-line, battery	B54Y (06V081E)	4/0 AWG AL
Burndy	Pistol, battery	BUR PAT60018V	350 Kcmil AL

E25.9.3 Dies shall be of the type shown in Standard CD210-21 and CD 210-24 only, must have identical markings, and compression tool die must match die number stamped on connector.

- (a) Modiewark Model #4444 or Fluke 1AC-II Volt Alert potential Indicator
- (b) Voltage meter – Fluke model #T3C
- (c) Insulated wire cutters – used for cutting cable ends square.

E25.9.4 Alternative equipment manufacturers may be considered upon request by the Contractor and shall be approved for use by Manitoba Hydro prior to use.

E25.9.5 Manitoba Hydro may reject any tools or equipment that do not appear to be in good condition or fail to successfully provide the required function.

#### E25.10 MATERIAL SUPPLIED BY MANITOBA HYDRO

E25.10.1 Manitoba Hydro shall supply all street light poles, concrete bases, breakaway bases, luminaires, street light arms, ground rods, compression sleeves, grommets, nuts, electrical cables, conduits, relays, cable guards, Gel-caps and all other materials noted in the

Standards. The Contractor shall sign receipts indicating the location on which the materials are to be used. The material shall be picked up by the contractor from the following locations:

- E25.10.2 Manitoba Hydro Central Stores (contact personnel will be provided to the successful contractor).
- E25.10.3 Materials requested will be supplied to the Contractor by Manitoba Hydro upon presentation of Manitoba Hydro's Stores Material Order Form. The Contractor shall assume all responsibilities for the loading, unloading, transportation, proper handling, secure storage and working of the materials and shall make replacements at its own expense in case any material is damaged, stolen or lost due to improper handling, storage or poor workmanship.
- E25.10.4 The Contractor shall, at the time of materials release, check and confirm the quantity of materials. Shortages, discrepancies, or damages to materials shall be immediately reported in writing to Manitoba Hydro.
- E25.10.5 After commencing performance of the work, the Contractor shall continually monitor all material required for the timely completion of the work and shall report additional material requirements to Manitoba Hydro a minimum of 72 hours prior to materials being required to perform the work. No additional compensation shall be paid as a result of delays due to material shortages where additional material requirements were not reported a minimum of 72 hours prior to being required for the work on an active project.

#### E25.11 MATERIAL SUPPLIED BY CONTRACTOR

- E25.11.1 The Contractor shall be responsible to furnish gravel, sand, ¾" down limestone, ¼" down limestone, protective hose (i.e. typically 2" fire hose), duct seal and pit-run material for backfilling around street light poles and around cables as per the Standards. The cost of furnishing the above listed materials shall be incorporated into the unit prices for the work.

#### E25.12 SURPLUS, RECLAIM AND SCRAP MATERIAL

- E25.12.1 Upon completion of the work, the Contractor shall, at its own expense, deliver to Manitoba Hydro Central Stores, all Surplus materials furnished by Manitoba Hydro and not used in the work, regardless of the location of said material at that time.
- E25.12.2 In addition, the Contractor shall, at its own expense, deliver to Manitoba Hydro Central Stores all Reclaim materials from the work specifically HPS luminaires. Manitoba Hydro shall be responsible for the proper disposal of Reclaim HPS luminaires. The HPS bulb shall remain installed and unbroken in the Reclaim luminaire. The Contractor shall handle the Reclaim luminaires with care and shall avoid breaking the bulb or refractor.
- E25.12.3 Manitoba Hydro's preference is to recycle as much Scrap Material as practicable. The Contractor is responsible to remove the Scrap Material, transport to the recycler or Manitoba Hydro approved disposal site, pay for any disposal fees and may retain any recycling value.

#### E25.13 DE-ENERGIZATION AND LOCKOUT

- E25.13.1 **Manitoba Hydro** - Where a standard is supplied from an Overhead Source, Manitoba Hydro's staff shall be responsible to disconnect and isolate the street light standard or standards between the standard and Overhead Source. Some street light standards may be temporarily fed from an Overhead Source. This Overhead Source shall be disconnected and removed by Manitoba Hydro staff prior to commencing with the work. The streetlight circuits will not be Locked Out by Manitoba Hydro.
- E25.13.2 **The Contractor** - The Contractor shall assess the hazards associated with the work and employ its own Safe Work Procedure for the work to be performed. The Contractor's Safe Work Procedure shall include provisions that the street light circuits will not be Locked Out by Manitoba Hydro. The Contractor's Safe Work Procedure shall achieve Lock Out or techniques equivalent to Lock Out.

E25.13.3 The Contractor shall complete a job planning form (an example is included as Appendix "H") on a daily basis before any work commences and provide Manitoba Hydro with copies of the job plans if requested.

#### E25.14 TEMPORARY OVERHEAD FEEDS

E25.14.1 Manitoba Hydro in consultation with the Contractor will determine if temporary lighting will be provided by the existing street lights or from the new street lights.

E25.14.2 When using the existing poles for temporary lighting, Manitoba Hydro shall remove an Overhead Source in accordance with DE-ENERGIZATION AND LOCKOUT section above, prior to the Contractor installing a #4 duplex overhead conductor between the existing poles. The #4 duplex overhead conductor will normally be attached to the tenon of the davit arm near the luminaire with a pre-form grip. Older poles may require a spool insulator be attached to the pole using a pre-form grip to support the #4 duplex overhead conductor. A short length of 2C/#12 copper conductor is connected to the terminals of the luminaire brought out and connected to the #4 duplex overhead conductor. The final span to the Overhead Source shall be installed by Manitoba Hydro.

E25.14.3 When using the new poles for temporary lighting, the Contractor shall install the new bases, poles and #4 duplex overhead conductor. The #4 duplex overhead conductor will be attached to the tenon of the davit arm near the luminaire with a pre-form grip. A short length of 2C/#12 copper conductor is connected to the terminals of the luminaire brought out and connected to the #4 duplex overhead conductor. The final span to the Overhead Source shall be installed by Manitoba Hydro.

E25.14.4 All material used to provide the temporary overhead feed shall be returned to Manitoba Hydro. Care shall be taken to coil and tag Reclaim conductor for reuse. If used, insulators shall be handled carefully to prevent breakage.

#### E25.15 SAFE EXCAVATION

E25.15.1 The work shall be performed in accordance with the requirements of Manitoba Hydro's Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix "E" and Manitoba Workplace Safety and Health Regulation 217 latest revision.

#### E25.16 SAFE HANDLING

E25.16.1 The Contractor shall apply handling techniques in accordance with Manitoba Workplace Health and Safety Regulation 217 (latest revision).

#### E25.17 ELECTRIC CABLES AND CONDUITS

- (a) The Contractor shall use diligent care and proper equipment in handling of all cables, so as not to injure the jacket and avoid gouging, kinking, scratching or abrading the cables. If any material is damaged to any extent, the Contractor shall repair the damages at its own expense, in a manner approved by Manitoba Hydro or will be charged the full cost of the damaged items.
- (b) Cable reels shall not be dropped and must be handled and placed/stored in an upright position at all times and shall not be laid flat for any purpose or reason. Cable reels shall be adequately supported on hard surface to prevent the reel from sinking into the ground that can cause undue stress on the cables. Cable reels should be inspected for damages prior to use. If a cable reel is found to be defective, such defect shall be reported immediately to Manitoba Hydro.
- (c) The Contractor shall place all material and string the cables in such a manner as to cause the least interference with normal use of the land, street or roadway. All material shall be unloaded in a manner to preserve its condition, prevent loss and/or theft and permit easy access for Manitoba Hydro's inspection.

- (d) The Contractor shall provide Manitoba Hydro's inspector sufficient opportunity, in the sole discretion of Manitoba Hydro, to inspect the work.

#### E25.18 PRECAST CONCRETE BASES

- E25.18.1 The Contractor shall handle, store, transport and unload the precast concrete bases in a manner to prevent damage to the threaded bolts and conduit casing.
- E25.18.2 Precast Concrete Bases are extremely heavy. Approximate weight of pre-cast concrete bases are found in the Standards. The Contractor shall only use equipment rated for such weight.

#### E25.19 STREET LIGHT POLES AND ARMS

- E25.19.1 The Contractor shall handle, store, transport, and provide proper load securement for the poles and arms in a manner to prevent damage.

#### E25.20 LUMINAIRES

- E25.20.1 The Contractor shall handle, store, transport and unload the luminaires in their original packaging and in a manner to prevent damage.

#### E25.21 SMALL MATERIAL

- E25.21.1 Photo electric cells, shorting caps, shims, nut covers and associated supplies shall be kept in a suitable warehouse provided by the Contractor at its own expense. Photo electric cells shall be transported and stored in such a manner as to prevent breakage.

#### E25.22 CARE OF MATERIALS

- E25.22.1 The Contractor shall assume all responsibilities of all the materials and shall replace, at its own expense, any materials damaged, stolen or lost due to improper handling or poor workmanship.

#### E25.23 WIRE AND CABLE REEL STORAGE

- E25.23.1 Cable reels shall be stored with the flanges upright and resting on a hard surface. At temporary storage sites where the soil may be soft, preservative-treated plywood sheets may be used to keep the flanges from sinking into the ground.
- E25.23.2 If cable reels must be pancaked or stored on their side in vertical racks, do not lift the reel by the top flange. Spacers (two 2 X 4s placed wide side up) should be placed under the bottom flange and between the reels in order to create a space to insert the forks and lift the reels without damaging the cable.

#### E25.24 REEL HANDLING

- E25.24.1 When off-loading reels from a truck, reels shall be lowered using a hydraulic gate, hoist or forklift truck. When a reel is rolled from one point to another, care must be taken to see that the reel does not straddle objects such as rocks, pipes, curbs or wooden blocks which could damage the cable or protective covering. A reel should always be rolled on hard surfaces to avoid sinkage and in the opposite direction to the cable wraps to ensure that the reel is rolled in such a direction as to tighten the cable on the reel.
- E25.24.2 When using a hoist, install a mandrel through the reel arbour hole and attach a sling. Use a spreader bar approximately 6 inches longer than the overall reel width placed between the sling ends just above the reel flanges. This will prevent bending of the reel flanges and damage to the cable.
- E25.24.3 If a forklift is used to move a reel, the reel is to be approached from the flange side. Position the forks such that the reel is lifted by both reel flanges. The lift forks shall not contact the cable.

E25.24.4 Returnable reels shall be returned promptly to Manitoba Hydro Central Stores and in no case later than three (3) days after the completion of the work unless otherwise mutually agreed between the Contractor and Manitoba Hydro.

#### E25.25 PRESSURIZED WATER/VACUUM EXCAVATION

E25.25.1 Pressurized water/vacuum excavation (PW/VE) shall be used to daylight all buried utilities and structures where excavation by other mechanical means would be expected to provide a physical risk to that utility or structure.

E25.25.2 The work shall be performed in accordance with the requirements of Manitoba Hydro's Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix "E".

#### E25.26 REMOVAL STREET LIGHT POLE FROM EXISTING BASE

E25.26.1 This shall include all work required to remove a street light pole from an existing base as set forth in this Technical Specification. The pole may be on an existing precast concrete base, steel power installed screw base or poured in place concrete base.

E25.26.2 The Contractor shall furnish all labour, supplies and materials (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary for the removal of the street light pole from the existing base. Care shall be taken to preserve the luminaire. The luminaire shall be reinstalled on the new street light pole or returned to Manitoba Hydro's stores as instructed by the Manitoba Hydro.

E25.26.3 The Contractor shall be responsible to transport all Surplus and Reclaim materials to Manitoba Hydro Central Stores and transport and dispose of all Scrap material as set forth in this Specification.

#### E25.27 REMOVAL OF BASE AND DIRECT BURIED STREET LIGHT POLE

E25.27.1 This shall include all excavation, whether by auger, pressurized water/vacuum excavation, by hand, or by other methods which may be necessary to remove a base or direct buried street light pole. The base may be poured in place concrete, steel power installed or precast concrete.

E25.27.2 The Contractor shall be responsible to transport all Surplus and Reclaim materials to Manitoba Hydro Central Stores and transport and dispose of all Scrap material as set forth in this Specification.

E25.27.3 The Contractor is responsible to supply all backfill material as specified in the Standards and carry out all backfill, compacting and leveling of all excavations and voids for removed bases and direct buried street light poles so as to be ready for top soil and seed or sod or as directed by Manitoba Hydro.

#### E25.28 INSTALLATION OF FOUNDATION - CONCRETE BASE

E25.28.1 This shall include all excavation, whether by auger, pressurized water/vacuum excavation, by hand, or by other methods which may be necessary to replace or install a concrete base as set forth in this Specification.

E25.28.2 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary to install a new or replace a concrete base. Excavation for the precast concrete base shall be to a diameter and depth specified in Standard CD 300-6. All excess material is to be removed by the Contractor.

E25.28.3 The concrete base shall be set on a bed of ¾" down limestone. The concrete base backfill material shall be compacted in lifts no more than 150 mm. Backfill material shall be ¾" down limestone. Compacting of backfill material shall be done using a hydraulic tamper. Alternative tamping methods shall be approved by Manitoba Hydro. Underground cables entering the concrete base shall be protected by a length of protective hose supplied by the Contractor and a layer of sand surrounding the cables to protect it from the limestone.

The concrete base shall be installed level in all 4 directions. Final grade must be established prior to installing the concrete bases.

E25.28.4 The completed backfill shall be at least equal in compaction to undisturbed soil, as required by the Municipal authorities or elsewhere in this Specification. The Contractor shall level all excavations.

E25.28.5 Should settlement occur in the excavation and cause a depression in the surface, the Contractor shall repair the surface. Placing of additional backfill material due to settlement shall be at the Contractor's expense.

E25.28.6 The concrete base shall be oriented in the proper direction to allow the easy entrance of the underground cables into the plastic pipe preinstalled in the concrete base. Care shall be taken to prevent damage to the insulation or jacket of the conductors. The cable shall be left long enough to extend one (1) metre beyond the top of the hand hole.

#### E25.29 BASE MOUNTED STREET LIGHT POLES

E25.29.1 This shall include all work required to install the street light pole on the concrete base as set forth in this Specification.

E25.29.2 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary for the installation of the pole (straight shaft or davit) on the concrete base.

E25.29.3 Unless otherwise specified on the construction drawings, the Contractor shall orient the poles so that the hand hole is on the left side of the pole when viewed from the road. A worker should be able to see oncoming traffic when working in the hand hole.

E25.29.4 The Contractor shall level the street light pole in all 4 directions. Leveling shims may be used.

E25.29.5 Tightening of bolts shall be performed in a manner that brings the surfaces up evenly. All nuts shall be tightened and torqued in accordance with Standard CD 300-9. The Contractor shall install the nut covers included with the pole.

E25.29.6 Unless otherwise specified, excess underground cable and 2C-12 wire shall be left inside the hand hole with the hand hole cover loosely installed.

E25.29.7 Existing street light poles may have street signs attached. The Contractor shall remove the signs from the existing pole and temporarily reattach the signs to the new pole. The Contractor shall notify Manitoba Hydro of the location where the signs have been removed.

#### E25.30 LUMINAIRES AND ASSOCIATED WIRING

E25.30.1 The Contractor shall furnish labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary to install the luminaire and associated wiring. Unless otherwise specified, the luminaire shall be installed with a tilt of zero (0) degrees. The Contractor shall install a length of 2 conductor No. 12 gauge (2C-12) wire from the terminals of the luminaire, through the arm (if applicable), down the pole to the hand hole. One (1) metre of 2C-12 wire shall be left at the hand hole. Impact equipment (air or electric) shall not be used to tighten luminaire mounting bolts. The Contractor shall be liable for damage due to over tightening.

E25.30.2 The Contractor shall verify the luminaire voltage matches the source voltage as shown on the construction drawings. If luminaire voltage does not match the source voltage, the Contractor shall re-wire the luminaire in accordance with the wiring diagram provided.  
NOTE: Not applicable for LED luminaires.

E25.30.3 As specified on the construction drawings, the luminaire will require either a photo electric cell (PEC) or shorting cap installed. When installing the PEC the eye shall be oriented north. The Contractor shall also install the appropriate wattage bulb in the luminaire.  
NOTE: Bulb installation not applicable for LED luminaires.

### E25.31 BREAK AWAY BASES

- E25.31.1 Break away bases shall be installed in accordance with Standard CD 300-10. The height of the concrete base above grade shall not exceed 50mm. The surface of the concrete base shall be flat and level. A reaction plate shall be installed between the concrete base and the break-away base.
- E25.31.2 The Contractor shall torque the couplers in accordance with Standard CD 300-10. Impact tools shall not be used to tighten or torque couplers or nuts associated with a break away base.

### E25.32 SPLICING/CONNECTING CABLES

- E25.32.1 The electric cable shall be spliced/terminated as per Standards CD 215-12, CD 215-13, CD 310-1, CD 310-4, CD 310-9 and CD 310-10 with the exception that the Contractor will use a GELCAP-SL-2/0 splice kit (See Appendix "F"). Termination in the hand hole may include the installation of an inline fuse holder.
- E25.32.2 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary to splice/terminate the street light conductor(s).

### E25.33 EXCAVATION

- E25.33.1 The Contractor shall furnish all labour, supplies and material (except as indicated in the Section "MATERIAL SUPPLIED BY MANITOBA HYDRO") necessary for the completion and maintenance of grade and line of the street light cables and conduit including water control if found to be necessary. The trench shall be graded to conform to the street light cables and conduit so that the street light cables and conduit rest firmly on a smooth surface throughout its length. All stones or other objects which, in the opinion of Manitoba Hydro might damage the street light cable jacket and conduit shall be removed. Where the presence of rock or other condition prevent a satisfactory bed for the cables, 150 mm of well-tamped, clean soil or ¼" down crushed limestone shall be placed in the bottom of the trench. In this case, the spoil bank from trenching operations shall not be allowed to fall into the trench or mix with the soil to be used in backfilling the trench. Loose debris or foreign matter and the spoil bank shall be placed so as not to hinder drainage, damage property, or obstruct traffic.
- E25.33.2 Trenches shall be dug to such a depth that will provide a minimum cover of 600 mm from final grade in sodded areas and 1000 mm in roadways in accordance with Standard CD 305-1.

### E25.34 LAYING CABLES

- E25.34.1 Cables are to be lowered in the trench in an orderly fashion so as to maintain a consistent path and straight alignment. All cables shall be lowered in a continuous run (NO SPLICING) and in accordance with the construction drawings; and shall maintain the necessary separation, where required. All cables shall be of continuous runs and capped and sealed if they are not being installed in the pole at that time. Cables shall not be dragged over paved surfaces.
- E25.34.2 Once a cable is cut its ends must be sealed immediately with an approved and appropriately sized, heat shrink or cold shrink sealing cap to prevent moisture ingress unless the cable is being installed in the pole at that time.
- E25.34.3 During the removal of the cable, the reels shall be placed on jacks, stands or trailers with a bar through the arbour holes which will allow the reel to be turned easily, and the cable to be paid out. Cables can be paid out from the bottom or the top of the reel. Cable in coils shall be handled in a similar manner. This can be achieved by supporting the coil in a vertical plane and rotating it by hand as the cable is carefully uncoiled. The cable shall never be pulled over the flange of a reel, or pulled off the side of a coil, since this will introduce a twist in the cable.

E25.34.4 During installation, under no circumstance is the cable to be subjected to a bending radius tighter than that detailed in the Standards.

E25.34.5 Where specified in the Standards or on the construction drawings, the Contractor shall install the street light cable in a conduit.

#### E25.35 INSTALLING CONDUIT AND CABLE BY BORING (HORIZONTAL DIRECTIONAL DRILLING)

E25.35.1 The Contractor shall dig the approaches and openings necessary to install boring equipment, and the boring equipment used shall be of such a nature as to minimize the opening size required. The boring equipment shall produce a straight hole without unnecessary dips or bends. The bore hole shall be only slightly larger than the outside diameter of the conduits or cables to minimize possible settlement. Cables and conduits shall be pulled in with pulling eyes or using a killum grip in a manner so as to guard against damage.

E25.35.2 During construction as the drill bit crosses each existing facility a lookout shall be assigned by the Contractor to visually confirm the drill bit is maintaining a minimum 300 mm clearance from the existing facility all in accordance with Manitoba Hydro Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix "E". Maximum pulling tensions on any streetlight cable shall be limited to 2.9 kN/0.65 kips.

E25.35.3 Drilling fluids and associated waste materials shall be disposed of in a manner that minimizes environmental effects.

E25.35.4 The Contractor shall properly compact the backfill material and will be responsible for placing additional material should settlement occur for the duration of the warranty period.

#### E25.36 BURIED UTILITY CROSSINGS

E25.36.1 All buried obstructions are not necessarily shown on the reference drawings and the locations of those indicated are approximate only.

E25.36.2 The Contractor shall determine the location of all buried obstructions and shall notify the appropriate authorities and obtain all necessary permits prior to excavation, trenching and directional drilling near or across such obstructions. All buried obstructions where the new buried cable route crosses other utilities including but not limited to gas, water, sewer, telephone and electric lines shall be exposed as per each utilities guidelines by the Contractor, including the use of Pressurized Water/Vacuum Equipment (PW/VE) where necessary. Should any damage occur to such lines during the course of the work, the Contractor shall be responsible for the damage and the costs of repairs to buried obstructions caused by its operations and shall fully indemnify the City of Winnipeg and Manitoba Hydro from and against all claims arising out of such damage. Manitoba Hydro Safe Excavation and Safety Watch Guidelines (latest revision) included as Appendix "E" shall be followed when crossing natural gas pipelines and electrical cables by the directional boring method.

E25.36.3 The PW/VE technique, used to expose underground plant in certain conditions, must be performed in accordance with each utility's requirements, including but not limited to Manitoba Hydro, Manitoba Telecom Services, Shaw Cable, etc. PW/VE costs that the Contractor will incur during the work must be factored into the Contractor's bid prices. The Contractor shall not be entitled to extra compensation for the use of PW/VE on the work.

E25.36.4 The Contractor shall be responsible to supply all backfill material and carry out all backfill, compacting and leveling of all excavations so as to be ready for topsoil and seed or sod or as directed by Manitoba Hydro.

#### E25.37 BENDING CABLES/CONDUITS AND INSTALLATION INTO STANDARDS

E25.37.1 It is desired to reduce to a minimum the required number of bends and to lay the cables/conduits to conform to the contour of the ground and maintain a normal covering. This shall be accomplished by cutting the trench slightly deeper in approaches to road crossings and drainage ditches. It is intended that the Contractor shall eliminate

unnecessary bending by operating the trenching machine at various depths rather than by finishing grading the trench by hand whenever practical.

E25.37.2 Sharp bends of the cables/conduits shall be avoided at all times. All bends shall meet the requirements set out in this Specification. If excessive bending was exerted on any cable, the cable shall be replaced at the Contractor's cost. During installation, under no circumstance is the cable to be subjected to a bending radius tighter than that detailed in the Standards. At street light poles the Contractor shall install the ends of the cables into the plastic pipe preinstalled in the concrete base. Care shall be taken to prevent damage to the insulation or jacket of the conductors. Underground cables entering the concrete base shall be protected by a length of protective hose supplied by the Contractor and by a layer of sand surrounding the cables to protect it from the limestone. The cable shall be left long enough to extend one (1) metre beyond the hand hole. The street light cable in the trench shall be installed in conduit for mechanical protection and the ends sealed with duct seal supplied by the Contractor. Care shall be taken to prevent damaging the cable where it exits the conduit. The conduit shall only be installed into the concrete base if conduit sizes make it practicable.

E25.37.3 Unless otherwise directed, excess underground cable and 2C-12 wire shall be left inside the hand hole with the hand hole cover loosely installed.

#### E25.38 BACKFILL

E25.38.1 All backfilling material within 300 mm of the cables/conduits shall be clean, free of sod, vegetation, organic material, stones or other debris, and of a consistency as to not create significant voids or air spaces around the cables/conduits. Other backfilling material shall be free of stones greater than 150 mm on their maximum dimension. Where cinders or very acid soil are encountered or where gravel or incompressible fill is required by Municipal authorities, ¼" down crushed limestone shall be placed all around the cables for a depth of at least 300 mm. The completed backfill shall be at least equal in compaction to undisturbed soil or as directed by Manitoba Hydro. Backfill material is to be placed and compacted in lifts not exceeding 300 mm. All excess material is to be removed by the Contractor.

E25.38.2 Tamping or flushing methods must be used where necessary to give the required compaction. Where tamping is used, hand tampers shall be used to at least 300 mm above the cable before machine tamping may be used. The Contractor shall level all excavations so as to be ready for topsoil and seed or sod or as directed by the Manitoba Hydro. Should settlement occur in the excavation and cause a depression in the surface, the Contractor shall repair the surface to the satisfaction of the Manitoba Hydro at the Contractor's cost.

E25.38.3 Excavations remaining where poles have been removed shall be backfilled with spoil, pit run gravel or ¾" down limestone and compacted in lifts of 150mm as directed by Manitoba Hydro. The top 300 mm of the excavation shall be backfilled with topsoil.

E25.38.4 Excavations remaining where utility crossings have been exposed shall be backfilled with sand or clean spoil and compacted in lifts of 150mm. The top 300 mm of the excavation shall be backfilled with topsoil.

E25.38.5 Backfill of all excavations shall be in accordance with City of Winnipeg Standard Construction Specification CW 2030 (latest revision), to the satisfaction of the authority having jurisdiction and Manitoba Hydro.

#### E25.39 DEFECTIVE WORK & WARRANTY

E25.39.1 If any portion of the work fails to comply with the requirements of this Specification, fails within the Warranty period, or if the final tests prove or indicate the existence of any fault or defect in the work, or any part thereof, Manitoba Hydro may forthwith re-execute or make good the faulty or defective work or alter the same to make it comply with requirements of the Specification at the Contractor's expense. Manitoba Hydro shall give the Contractor notice together with particulars of such failure, fault or defect, Manitoba Hydro's cost to re-execute or make good the faulty or defective work and the Cost shall be deducted from the Contract.

E25.39.2 At the completion of the work for each location, Manitoba Hydro shall prepare and issue a Network Commissioning Report, a sample of which is included as Appendix "I", to the Contractor. The Network Commissioning Report shall be dated indicating the commencement of the Warranty period for the work performed at the location.

#### E25.40 AS-BUILT DRAWING

E25.40.1 The Contractor shall provide an as-built drawing or mark-up drawing to Manitoba Hydro which accurately displays the "as-built" location of the buried street light cables, conduits and street light poles.

#### E25.41 MEASUREMENT AND PAYMENT

E25.41.1 Removal of 25' to 35' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Removal of 25' to 35' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including removal of the pole, base, luminaire, appurtenances, use of pressurized water/vacuum excavation, transportation of Reclaim, Surplus and Scrap material, payment of associated disposal fees and all other items incidental to the work included in the Specification.

E25.41.2 Removal of 45' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Removal of 45' street light pole and precast, poured in place concrete, steel power installed base or direct buried including davit arm, luminaire and appurtenances". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including removal of the pole, base, luminaire, appurtenances, use of pressurized water/vacuum excavation, transportation of Reclaim, Surplus and Scrap material, payment of associated disposal fees and all other items incidental to the work included in the Specification.

E25.41.3 Installation of Conduit and #4 AL C/N or 1/0 AL Triplex Streetlight Cable in Conduit by Open Trench Method

- (a) This pay item will be measured on a linear metre basis and paid for at the Contract Unit Price per linear metre for "Installation of Conduit and #4 AL C/N or 1/0 AL Triplex streetlight cable in Conduit by open trench method." The number of meters to be paid for at the Contract Unit Price shall be measured and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the conduit, pulling cable into the conduit, backfilling the trench, buried utility crossings, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.

E25.41.4 Installation of 50 mm Conduit by Boring Method complete with Cable Insertion (#4 AL C/N or 1/0 AL Triplex)

- (a) This pay item will be measured on a linear metre basis and paid for at the Contract Unit Price per linear metre for "Installation of 50 mm conduit or conduits by boring method complete with cable insertion (#4 AL C/N or 1/0 AL Triplex)." The number of meters to be paid for at the Contract Unit Price shall be measured and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of 50mm conduit or conduits by boring method, inserting the #4

AL C/N or 1/0 AL Triplex streetlight cable into the conduit(s), buried utility crossings, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.

- E25.41.5 Installation of cable (#4 AL C/N or 1/0 AL Triplex) by boring method.
- (a) This pay item will be measured on a linear metre basis and paid for at the Contract Unit Price per linear metre for "Installation of cable(s) (#4 AL C/N or 1/0 AL Triplex) by boring method." The number of meters to be paid for at the Contract Unit Price shall be measured and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the cable or cables by boring method, buried utility crossings, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E25.41.6 Installation of 25'/35' Pole, Davit Arm and Precast Concrete Base Including Luminaire and Appurtenances
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of 25'/35' pole, davit arm and precast concrete base including luminaire and appurtenances." The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the pole, davit arm, base, luminaire, appurtenances, placing the cable(s) into the base, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E25.41.7 Installation of 45' Pole, Davit Arm and Precast Concrete Base Including Luminaire and Appurtenances
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of 45' pole, davit arm and precast concrete base including luminaire and appurtenances." The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the pole, davit arm, base, luminaire, appurtenances, placing the cable(s) into the base, use of pressurized water/vacuum excavation and all other items incidental to the work included in the Specification.
- E25.41.8 Installation of One (1) 10' Ground Rod at Every Third Street Light, at the End of a Street Light Circuit or Anywhere Else as Shown on the Design Drawings. Trench #4 Ground Wire up to 1 m From Rod Location to New Street Light and Connect (Hammerlock) to Top of Ground Rod
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of one (1) 10' ground rod at every third street light, at the end of a street light circuit or anywhere else as shown on the design drawings. Trench #4 ground wire up to 1 m from rod location to new street light and connect (hammerlock) to top of the ground rod." The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including install one (1) 10' ground rod, trench the #4 ground wire to the new streetlight pole, connect (hammerlock) ground wire to rod and all other items incidental to the work included in the Specification.
- E25.41.9 Installation of Lower 3 m of Cable Guard, Ground Lug, Cable Up Pole, and First 3 M Section of Ground Rod Per Standard CD 315-5
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Install/lower 3 m of Cable Guard, ground lug, cable up pole, and first 3 m section of ground rod per Standard CD 315-5". The

number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installing the lower section of cable guard, ground lug, ground rod, coiling cable(s) up the pole and all other items incidental to the work included in the Specification.

E25.41.10 Installation and Connection of Externally-Mounted Relay and PEC Per Standards CD 315-12 and CD 315-13

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation and connection of externally-mounted relay and PEC per Standards CD 315-12 and CD 315-13". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including mounting the relay, PEC, wiring as per the schematic and all other items incidental to the work included in the Specification.

E25.41.11 Termination of 2/C #12 Copper Conductor to Street Light Cables Per Standard CD310-4, CD310-9 or CD310-10

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Terminate 2/C #12 copper conductor to street light cables per Standard CD310-4, CD310-9 or CD310-10". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including connection of the 2/C # 12 copper conductor to the #4 C/N or 1/0 Al Triplex cable(s) using a GELCAP-SL-2/0 splice kit and all other items incidental to the work included in the Specification.

E25.41.12 Splicing #4 AL C/N or 2 Single Conductor Street Light Cables

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Splicing #4 Al C/N or 2 single conductor street light cables". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including splicing the #4 AL C/N or 2 single conductor cables in accordance with Standard CD 215-12 and CD 215-13 and all other items incidental to the work included in the Specification.

E25.41.13 Splicing 1/0 AL Triplex Cable or 3 Single Conductor Street Light Cables

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Splicing 1/0 AL triplex cable or 3 single conductor street light cables". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including splicing the 1/0 Al triplex cable or set of 3 single conductor cables in accordance with Standard CD 215-12 and CD 215-13 and all other items incidental to the work included in the Specification.

E25.41.14 Installation of Break-Away Base and Reaction Plate on Base-Mounted Poles up to 35'

- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Installation of break-away base and reaction plate on base mounted poles up to 35'". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including installation of the reaction plate, break-away base and all other items incidental to the work included in the Specification.

- E25.41.15 Installation of Overhead Span of #4 Duplex Between New or Existing Streetlight Poles and Connect Luminaire to Provide Temporary Overhead Feed
- (a) This pay item will be measured on per span basis and paid for at the Contract Unit Price per span for "Installation of Overhead Span of #4 duplex Between New or Existing Streetlight Poles and Connect Luminaire to Provide Temporary Overhead Feed". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including attachment of the #4 duplex overhead conductor using a perform grip (c/w spool insulator(s) to davit arm if necessary), sagging conductor, connection of luminaire using 2C#12 copper conductor and all other items incidental to the work included in the Specification.
- E25.41.16 Removal of Overhead Span of #4 Duplex Between New or Existing Streetlight Poles to Remove Temporary Overhead Feed
- (a) This pay item will be measured on a per span basis and paid for at the Contract Unit Price per span for "Removal of Overhead Span of #4 duplex Between New or Existing Streetlight Poles to Remove Temporary Overhead Feed". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by the Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including removal of the #4 duplex overhead conductor, spool insulator(s) and all other items incidental to the work included in the Specification.
- E25.41.17 Expose Underground Cable Entrance of Existing Streetlight Pole and Install New Streetlight Cable(s).
- (a) This pay item will be measured on a unit basis and paid for at the Contract Unit Price per unit for "Expose Underground Cable Entrance of Existing Streetlight Pole and Install New Streetlight Cable(s)". The number of units to be paid for at the Contract Unit Price shall be verified and accepted by Manitoba Hydro. The Price shall be payment in full for performing all operations herein described including excavation and exposure of the underground cable entrance by any means necessary including use of pressurized water/vacuum excavation, installation of the new streetlight cables(s), backfill, compaction and all other items incidental to the work included in the Specification.