

334-2026 ADDENDUM 2

CINDY KLASSEN RECREATION COMPLEX SPORT COURTS AND VALOUR C.C. BASKETBALL COURT REPAIR

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: June 11 2026
BY: IM
TELEPHONE NO. 204 451-3069

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Addendum 2026-03-10

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

FORM B: PRICES

Replace: 334-2026 Form B: Prices with 334-2026 Addendum 2 - Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Revise item 16 to read: Supply and install concrete catch basins with 900mm base diameter and 600mm sump. Refer to SD-025 and Drawing C.01.

Page numbering on some forms may be changed as a result.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **June 19, 2026.**

PART E – SPECIFICATIONS

Revise: E13.4 to read:

E13.4 Materials

E13.4.1 Electrical cable and conduit

- (a) Conduit shall be in 38 mm low density polyethylene conduit for outdoor use.
- (b) The contractor shall use NMWU, Teck 90 or other equivalent cable approved by the Contract Administrator and which is suitable for direct burial outdoors.
- (c) Wire size shall be chosen based off a maximum permitted voltage drop of 3% on each circuit. Contractor shall submit voltage drop calculation and wire type and sizing to Contract Administrator prior to construction. Minimum wire size shall be #12 CU AWG. **Proposed fixtures will be max. 200 watts LED sport court lights. Two fixtures per pole.**
- (d) Wire and cable shall be copper of standard AWG sizes with 600V (90° C) insulation. Insulation shall be X-Link Polyethylene unless otherwise noted on Drawings or prohibited by regulations. Aluminum conductors will not be accepted. Underground splicing of wire will not be permitted

Revise: E15 to read:

E15. DRAIN BASINS

E15.1 Description

- (a) This Specification shall cover the supply and installation of two (2) catch basins, frames, covers and any associated fittings or accessories and appurtenances as well as any necessary repairs to sidewalks, turf or otherwise.

E15.2 Materials

- (a) Two (2) 600 mm diameter concrete catch basins with 900mm base c/w Standard Ductile Iron Grate and Frame, 600 mm sump depth and all required fittings specified by the Manufacturer and as shown on SD-025 and Drawing C.01.

E15.3 Construction Methods

- (a) Catch basins are to be installed in the locations and to the design elevations shown on the Drawings.
- (b) The location of the catch basins shall be marked out on Site and reviewed by the Contract Administrator prior to installation.
- (c) Excavations at any time shall not exceed the amount of catch basins that can be installed and backfilled prior to the end of each Working Day.
- (d) Catch basin bedding and backfill in accordance with the Drawings, SCD-668, CW 2030 and SD-001 and SD-002.
- (e) The grades of the bottom of the catch basin are to be reviewed by the Contract Administrator prior to the installation of drain basin.
- (f) Non-woven filter fabric, as shown on the Drawings shall be supplied and installed in accordance with CW 3130.
- (g) Land Drainage Pipes shall be connected to each catch basin then finally, to the land drainage sewer as per CW2130 and the Drawings.

E15.4 Method of Measurement and Basis of Payment

E15.4.1 Method of Measurement shall be as follows:

- (a) (a) Catch basins will be measured on a lump sum basis for:
 - (i) "Supply & install concrete catch basin with 900mm base diameter and 600mm sump. Refer to SD-025 and Drawing C.01" on Form B: Prices.
- (b) No separate measurement shall be made for connections to drainage pipe as this work is incidental to the Work herein.

E15.4.2 Basis of Payment shall be as follows:

- (a) Supply and install catch basins will be paid for at the Contract Unit Prices. The amount to be paid for shall be the total number of units, as indicated on Form B: Prices. This price shall be full payment for supplying all labour, equipment and materials, and performing all operations herein described and all other items incidental to the Work and as accepted by the Contract Administrator

Revise: E22.2.5(a) to read: Speckle silver double powder-coated aluminum hoop rack x 3
(i) Finish: Powder-coated

DRAWINGS

Replace: 4B334-2026 _Drawing_C.80-B2 with 4B334-2026 _Addendum_2 Drawing_C.80-B2-R1