



519-2026 ADDENDUM 1

GOULET-DOUCET WATER MAIN CROSSING REHABILITATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: July 20, 2026
BY: Matt Krentz, C.E.T.
TELEPHONE NO. 431 336-5586

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2024-02-01

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, July 31, 2026.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D18.1 to read: The Contractor shall achieve Substantial Performance within thirty (30) consecutive Working Days of the commencement of the Work as specified in D14, or by December 14, 2026, whichever comes first.

PART E – SPECIFICATIONS

Add: E19.7.1(e) Provide heating and hoarding as required to facilitate the Work.

Add: E19.8.1(f) Heating and hoarding will be considered incidental to "Supply and Install 400 mm FFRP Liner" and will not be measured for payment. No additional payment will be made.

NOTE TO BIDDERS: QUESTIONS AND ANSWERS BELOW DO NOT FORM PART OF THE CONTRACT

QUESTIONS AND ANSWERS

Q1: Can record outside diameters of the existing 400 AC feeder main be provided?

A1: Record measurements indicate the outside diameter of the existing 400 AC feeder main is 19.10" at the west launch wye and 18.95" at the east launch wye.

Q2: Will the flange coupling adapters that connect the AC host pipe to the Primus liner termination require restraint?

A2: The flange coupling adapters connecting the AC host pipe to the Primus liner termination do not require restraint.

Q3: Is any CCTV footage available of the existing watermain for review?

A3: No CCTV footage is available.