

LBIS DONE June 28/99 m h.

CITY OF WINNIPEG - STREETS & TRANSPORTATION

District **North**

SERVICES PERMIT

Permit No. **101963**

(Inspector Copy)

Address: **785 MAIN ST**

Legal Description: Lot _____ Block _____ Plan _____

Details:

SPRINKLER REPAIR *RENEWAL*

Cut Permits:

2 MIN. SIDEWALK CUTS - 040458

Applicant **IMRIE HOLDINGS LTD.**

Address **363 WILLIAM AVENUE**

Phone **943-8000**

Type of Service

Size

WATER SERVICE

Water Renewals
Water Repairs
Meter Rentals
Hydrant Rentals
Use of Water
Multiple Metering
Sprinkler Repairs
After Hr. Water Inspection
Miscellaneous

*RENEWED SPRINKLER
SEE SKETCH*

SEWER SERVICE

Sewer Renewal
Sewer Repair
WWS Sewer
LDS Sewer
After Hr. Sewer Inspection
Miscellaneous

Date of Permit: **1/18/99**

Date Paid: **1/18/99**

WATER UTILITY DATA

Nature of Building *HOTEL*
Nature of Service *SPRINKLER*
Size of Main *8"*
Size *6"* S.C. Distance from Bldg *23' W.E.L. BLDG.*
Position of S.C. *28' N.N.L. SYRERLAND*
28' N.S.L. BLDG.
Position of C.C. *OPPOSITE*
Length of Service _____
Distance Main to S.C. *1.5'*
Depth of Service of S.C. *8'*
Depth of W.M. _____
Service Depth at Main _____
Connected to *6"* ☒ Plastic / ☐ Copper Pipe / Lead
Water _____ On _____ Off

CUTS:

No.	Type	Size
_____	Asphalt	_____
_____	Concrete	_____
_____	Mud or Gravel	_____
_____	Concrete Walk	_____
_____	Boulevard	_____

MATERIAL:

_____	Corp. Cock	_____
_____	Stop Cock	_____
_____	Pipe	_____
_____	Base	_____
_____	Block	_____
_____	Barrel	_____

REMARKS:

Size/Type

LDS Jct:

SEWER UTILITY DATA

Sewer Jct: _____
LDS Jct: _____
C.S. Jct: _____
Depth of waste water sewer below street level _____
Depth of land drainage sewer below street level _____
Depth of combined sewer below street level _____

INSPECTION COMPLETE:

Signature

Date

Mark Spence *Jan 21/99*

JAN 21/99. IMRIE
 6" P.V.C. SPRINKLER 785 MAIN⁶
 PIPE RETAIN.



8" Dresser CP (Rear)
 8" P.V.C. 14" Lg.
 8" x 8" P.V.C. Tee
 8" P.V.C. 11" Lg.
 8" Dresser CP
 (Rear)

(See Plan)

