



GENERAL NOTES

- ALL EQUIPMENT, DEVICES, FIXTURES REMOVED UNDER DEMOLITION SCOPE WILL BE FIRST OFFERED TO THE CITY FOR REFUSAL FOLLOWED BY CONTRACTOR AND FINALLY TO BE LEGALLY DISPOSED OF.
- FOR ALL EXISTING ELECTRICAL DEVICES, EQUIPMENT, ETC. THAT ARE REMOVED, REMOVE EXISTING CONDUIT, WIRING, ETC. BACK TO SOURCE UNLESS OTHERWISE NOTED.
- CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING EXACT LAYOUT, ROUTING, ETC. VERIFY EXISTING SERVICES ON SITE.
- VERIFY ALL EXISTING EQUIPMENT BEING RE-USED IS WORKING PRIOR TO INSTALLATION. SUPPLY NEW EQUIPMENT AS NECESSARY.
- CONTRACTOR TO DETERMINE EXACT CABLE ROUTES ON SITE. WHERE POSSIBLE FOLLOW EXISTING CABLE ROUTES THROUGH BUILDING. RE-USE EXISTING OPENINGS AND PENETRATIONS TO ROUTE CABLES. PROVIDE NEW PENETRATIONS WHERE EXISTING CANNOT BE RE-USED. SEAL ALL PENETRATIONS.
- SEAL ALL PENETRATIONS THROUGH FIRE RATED WALLS WITH FIRE STOP MATERIAL AS REQUIRED TO MAINTAIN ASSEMBLY RATING.
- COORDINATE FULLY WITH MECHANICAL FOR THE SEQUENCE OF DEMOLITION AND CONSTRUCTION.
- COORDINATE WITH THE CITY PRIOR TO SHUT DOWN OF EQUIPMENT.
- CONTRACTOR SHALL ENSURE COORDINATION BETWEEN ALL SUBCONTRACTORS AND CONTRACT ADMINISTRATOR, ON AND OFF SITE, AS REQUIRED FOR INSTALLATION OF ELECTRICAL EQUIPMENT.
- CONTRACTOR TO VISIT SITE DURING BID AND VERIFY ALL EXISTING SERVICES ON SITE PRIOR TO SUBMITTING BID. REPORT ANY DISCREPANCIES TO CONTRACT ADMINISTRATOR DURING BID PERIOD.
- THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATION FOR FURTHER INFORMATION.

DEMOLITION KEY NOTES

- DISCONNECT AND REMOVE EXISTING WIRE, CONDUIT, ETC. ASSOCIATED WITH EXISTING MAKE UP AIR UNIT AND ASSOCIATED CONTROLLER BACK TO EXISTING DISTRIBUTION. COORDINATE REMOVAL WITH MECHANICAL CONTRACTOR.
- DISCONNECT EXISTING WIRE, CONDUIT, ETC. ASSOCIATED WITH EXISTING GAS FIRED INFRARED HEATER. INFRARED HEATER TO BE PLACED WITH NEW IN SAME LOCATION. RE-USE CIRCUIT IN NEW CONSTRUCTION. REFER TO DRAWING E2.1 FOR FURTHER INFORMATION. COORDINATE REMOVAL WITH MECHANICAL CONTRACTOR.
- EXISTING EXHAUST FAN TO BE RELOCATED. REFER TO DRAWING E2.1 FOR FURTHER INFORMATION. COORDINATE RELOCATION WITH MECHANICAL CONTRACTOR.
- DISCONNECT AND REMOVE EXISTING JUNCTION BOXES AS REQUIRED TO NOT INTERFERE WITH NEW EXHAUST FAN LOCATION. PULL BACK WIRE, CONDUIT, ETC. TO ACCESSIBLE LOCATION AND RE-TERMINATE ONTO NEW JUNCTION BOXES. EXTEND WIRE, CONDUIT ETC. BETWEEN NEW JUNCTION BOXES. REFER TO NEW CONSTRUCTION FOR FURTHER INFORMATION.

1 PARTIAL MAIN FLOOR PLAN - ELECTRICAL - DEMOLITION
SCALE: 1/16" = 1'-0"

FILE NAME AND PATH: C:\Projects\2025\25-330 Transit East High Bay Ventilation Upgrade\03 CAD\24 ELEC\25330_E1-1.dwg
LAYOUT: E1.1
LAST SAVED BY: wsm
DATE PLOTTED: January 8, 2026 8:46:28 AM

0	ISSUED FOR CONSTRUCTION	AJS	27/03/2026
LETTER OR NUMBER	DESCRIPTION	BY	DD/MM/YY



Project Title
**TRANSIT MAINTENANCE
AND REPAIR BUILDING
MECHANICAL UPGRADE -
EAST HIGH BAY**

WINNIPEG

Drawing Title
**PARTIAL MAIN FLOOR PLAN -
ELECTRICAL - DEMOLITION**

Drawn By
WPD
Checked By
AJS
Approved By
AJS
Scale
AS NOTED
Date
MARCH 2026
Project No.
25-330-01

Revision Number
0
Drawing Number
E1.1
Sheet Order
1 OF 5

