



GENERAL NOTES

- A. ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- B. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.
- C. PRIOR TO DEMOLISHING AND REMOVAL OF THE EXISTING EQUIPMENT, COORDINATE WITH THE CITY. RETURN EQUIPMENT TO THE CITY AS REQUIRED.
- D. REFER TO ROOF DETAILS AND SPECIFICATIONS FOR ALL NEW AND CAPPED OPENINGS.
- E. THE WORK AREA IS OCCUPIED 24/7. DURING THE HOURS OF 7:00 AM TO 2:30 PM, IT IS THE BUSIEST TIME FOR THE AREA AND IT IS PREFERRED THAT NO MORE THAN TWO HOIST SPACES ARE IMPACTED BY THE SCOPE OF WORK BUT ADDITIONAL HOISTS MAY BE IMPACTED WITH SUFFICIENT NOTICE AND APPROVAL. DURING THE HOURS OF 2:30 PM TO 7:00 AM, THE AREA IS LESS BUSY AND APPROVAL FOR ADDITIONAL HOISTS TO BE IMPACTED WILL BE MORE EASILY OBTAINED. COORDINATE WITH THE CITY PRIOR TO COMMENCEMENT OF WORK. UPON COMPLETION OF WORK AT THE END OF EACH SHIFT, CLEAN UP THE AREA OF WORK TO ENSURE THE HOISTS ARE NOT IMPACTED.
- F. FOR DRAWING CLARITY, NOT ALL MECHANICAL EQUIPMENT, PIPING AND DUCTWORK HAS BEEN SHOWN.
- G. CAUTION SHOULD BE TAKEN TO PREVENT SILICA RELEASE AND FUMES INSIDE THE GARAGE

KEY NOTES @

- 1. SPRINKLER SYSTEM AT HIGH LEVEL NOT SHOWN. PROVIDE NEW SPRINKLER HEADS UNDER NEW DUCTWORK AS REQUIRED. PROVIDE LOWER LEVEL SPRINKLER HEADS UNDER NEW DUCTWORK AS FAR AWAY FROM BUS TAIL PIPES AS POSSIBLE.

 **1** PARTIAL MAIN FLOOR PLAN - FIRE PROTECTION - NEW CONSTRUCTION  
M3.1 SCALE: 1/16"=1'-0"



<div><div><div><div><div></div><div></div></div><div><div></div><div></div></div><div><div></div><div></div></div><div><div></div><div></div></div></div><div>ENGINEERS GEOSCIENTISTS MANITOBA Certificate of Authorization SMS Engineering Ltd. No. 166</div></div></div>				<div><div><div>PROVINCE OF MANITOBA REGISTERED PROFESSIONAL ENGINEER J. HORROCKS Member 24767 2026-03-27</div></div></div>	<div><div><div><div></div><div></div></div><div><div></div><div></div></div><div><div></div><div></div></div></div><div>SMS Engineering™</div><div>770 Bradford Street Winnipeg, Canada (204) 775-0291 smseng.com</div></div>	<div>Project Title TRANSIT MAINTENANCE AND REPAIR BUILDING MECHANICAL UPGRADE - EAST HIGH BAY</div> <div>WINNIPEG</div>	<div>Drawing Title PARTIAL MAIN FLOOR PLAN - FIRE PROTECTION - NEW CONSTRUCTION</div> <div>MAINTOBA</div>	<div>Drawn By AP Checked By AJ Approved By JH Scale AS NOTED Date MARCH 2026 Project No. 25-330-01</div> <div>Revision Number 0 Drawing Number M3.1 Sheet Order 08 OF 10</div>
--	--	--	--	--	---	---	---	--